

Lower Peace River MFL Rule and W.U.P. Modification

Agenda Item 15
September 1, 2010

Lower Peace River MFL

- SWFWMD adopted May 25, 2010
- In force August 2, 2010
- Seasonal Flow Schedule
- Combines flow at 3 gages
- Includes minimum trigger before withdrawals
- Includes Maximum withdrawal limit
- Revisit in 5 years



Permit or MFL	Available Water (%)	Minimum Flow Before Withdrawal	Maximum Withdrawal
Current Authority Permit	10%	84 MGD in Peace River @ Arcadia	90 MGD
MFL			
Block 1 (Apr. 20 – Jun. 25)	16%	84 MGD as sum of 3 gages	258 MGD
Block 2 (Oct. 27 – Apr. 19)	29%	84 MGD as sum of 3 gages	258 MGD
Block 3 (Jun. 26 – Oct. 26)	38%	84 MGD as sum of 3 gages	258 MGD

Authority Access to MFL

- Will Greatly Improve Peace River Facility Reliability
- Will not Require any Capital Improvements
- Makes Optimal Use of Existing Infrastructure
- Works Within Resource Protection Framework
- Would Leave Most of the MFL 'Available Quantity' Untouched
- Will Require W.U.P. Modification

Next

- Sept: Pre-Application Meeting with SWFWMD
- Sept - Oct: Meet with Customers and Stakeholders
- Oct - Nov: Submit Application

Questions