

July 5, 2022

Ref: Peace River/Manasota Regional Water Supply Authority  
(PWS #6142734 – Quarterly Compliance Monitoring)

Dear Members/Customers,

Enclosed are the compliance monitoring test results for samples collected and analyzed during the Second Quarter of 2022.

Should you have any questions or require additional information, please feel free to call me at (863) 993-4565.

Regards,

Michael P. Chell  
Peace River/Manasota Regional Water Supply Authority  
Operations Manager  
DEP License # DWA- 15153

cc: w/attachments

M. Coates (PRMRWSA) [Mcoates@regionalwater.org](mailto:Mcoates@regionalwater.org)  
R. Anderson (PRMRWSA) [RAnderson@regionalwater.org](mailto:RAnderson@regionalwater.org)  
M. Mylett (SCU) [mmylett@scgov.net](mailto:mmylett@scgov.net)  
G. Fischer (SCU) [gfischer@scgov.net](mailto:gfischer@scgov.net)  
T. Hill (CCU) [Tom.Hill@charlottecountyfl.gov](mailto:Tom.Hill@charlottecountyfl.gov)  
D. Watson (CCU) [Dave.Watson@charlottecountyfl.gov](mailto:Dave.Watson@charlottecountyfl.gov)  
M. Giardullo (DCU) [m.giardullo@desotobocc.com](mailto:m.giardullo@desotobocc.com)  
J. Tatum (DCU) [j.tatum@desotobocc.com](mailto:j.tatum@desotobocc.com)  
R. Reed (DCU) [r.reed@desotobocc.com](mailto:r.reed@desotobocc.com)  
N. Gallinaro (NP) [ngallinaro@cityofnorthport.com](mailto:ngallinaro@cityofnorthport.com)  
J. Desrosiers (NP) [jdesrosiers@cityofnorthport.com](mailto:jdesrosiers@cityofnorthport.com)  
M. Vuolo (NP) [mvuolo@cityofnorthport.com](mailto:mvuolo@cityofnorthport.com)  
S. Adams (PGU) [sadams@ci.punta-gorda.fl.us](mailto:sadams@ci.punta-gorda.fl.us)

File/Compliance Monitoring

**DISINFECTANT RESIDUAL (CHLORINE OR CHLORAMINES)  
EXAMPLE REPORTING FORMAT**

<b>QUARTERLY REPORTING PERIOD:</b> 2cnd quarter		<b>YEAR:</b> 2022
<b>SYSTEM INFORMATION</b>		
PWS NAME: Peace River/Manasota Regional Water Supply Authority		
PWS ID NUMBER: 6142734	COUNTY: Desoto	
CONTACT PERSON: Mike Chell	PHONE NUMBER: (863) 993-4565	
E-MAIL ADDRESS (optional):	FAX NUMBER (optional): (863) 993-4568	

DISINFECTANT RESIDUAL COMPLIANCE SUMMARY												
Last 12 Months	7	8	9	10	11	12	1	2	3	4	5	6
Actual Month/Year	Jul-21	Aug-21	Sep-21	Oct-21	Nov-21	Dec-21	Jan-22	Feb-22	Mar-22	Apr-22	May-22	Jun-22
Provide the number of disinfectant residual samples taken each month of the last quarter (include disinfectant residual samples taken for all total coliform samples, including repeat or additional total coliform samples)*	12	12	15	12	12	15	12	12	15	12	12	15
Provide the monthly arithmetic average of all samples taken in each month for the last 12 months (include disinfectant residual samples taken for all total coliform samples, including repeat or additional total coliform samples)	3.48	3.42	2.91	3.51	3.77	3.45	3.83	4.04	3.63	3.65	3.46	3.31
Calculate the Running Annual Average (RAA) (i.e., calculate the arithmetic average of the monthly averages for the last 12 months)												3.54
Does the RAA violate the Maximum Residual Disinfectant Level of 4.0 mg/l? (YES/NO)												NO

\*Also, for each disinfectant residual sample taken each month of the last quarter, provide the information requested in the table on page two of this format.

INSTRUCTIONS: This format should be completed and submitted WITHIN 10 DAYS AFTR THE END OF EACH QUARTER IN WHICH SAMPLES WERE COLLECTED, by all community or non-transient non-community water systems that add a chemical disinfectant and that serve at least 4,901 persons. For example, for disinfectant residual samples collected in the first quarter (January - March) of 2004, this format is due no later than April 0, 2004. Submit the completed form to the appropriate Department of Environmental Protection District Office or Approved County Health Department.

The following specific instructions are for the "Disinfectant Residual Analysis Results for Reporting Period" table on page two.

Attach additional sheets if necessary.

Analytical Method: In accordance with 40 CFR 141.31(c)(1), the approved methods for disinfectant residual compliance monitoring are as follows:

Free Chlorine: Standard Methods 4500-CI D, 4500-CI F, 4500-CI G (DPD Colorimetric), and 4500-CI H and ASTM Method D 1253-86

Combined Chlorine: Standard Methods 4500-CI D, 4500-CI F, and 4500-CI G (DPD Colorimetric) and ASTM Method D 1253-86

Total Chlorine: 4500CI-D, 4500-CI E, 4500-CI F, 4500-CI G (DPD Colorimetric), and 4500-CI I and ASTM Method D 1253-86

Enter in the space provided the analytical method that the person or laboratory is using to measure disinfectant residuals.

Analysis Information: In accordance with Florida Administrative Code (F.A.C.) subsections 62-550.550(1), 62-550.821(8), operators licensed under F.A.C. Chapter 62-602 and persons working under the direct supervision of a licensed operator, as well as laboratories certified by the Department of Health, are approved to measure disinfectant residuals. If the person measuring the disinfectant residual is a licensed operator or is working under the direct supervision of a licensed operator, enter the name and license number of the operator. In cases where certified laboratory personnel measuring the disinfectant residual, indicate the name and certification number of the laboratory.





## STAGE 2 TOTAL TRIHALOMETHANES (TTHM) AND HALOACETIC ACIDS FIVE (HAA5) EXAMPLE REPORTING FORMAT

Subpart H systems serving 500 or more persons and ground water systems serving 10,000 or more persons shall complete applicable pages of this format and submit them to the Department within 10 days after the end of any quarter in which TTHM/HAA5 monitoring is required. Systems on routine or reduced quarterly TTHM/HAA5 monitoring shall complete pages 1, 2, and 3 of this format. (Add additional rows to the tables on pages 2 and 3 as necessary.) Systems on reduced annual TTHM/HAA5 monitoring shall complete pages 1 and 4 of this format. Additionally, Subpart H systems seeking to qualify for, or remain on, reduced quarterly or annual TTHM/HAA5 monitoring shall complete page 5 of this format. (Add additional rows to the table on page 5 as necessary.)

D/DBPR = Disinfectant and Disinfection Byproducts Rule; LRAA = locational running annual average; MCL = maximum contaminant level; OE = operational evaluation; RAA = running annual average; TOC = total organic carbon.

**QUARTERLY MONITORING PERIOD\*:** April-June 2022

\*Indicate the quarterly monitoring period by months and year (e.g., April-June 2012).

### SYSTEM INFORMATION

PWS ID Number: 614-2734

PWS Name: Peace River Manasota Regional water supply authority

Source Water Type and Population Size Category:

Ground Water:

- 10,000 – 99,999
- 100,000 – 499,999
- ≥ 500,000

Subpart H:

- 500 – 3,300
- 3,301 – 9,999
- 10,000 – 49,999
- 50,000 – 249,999
- 250,000 – 999,999
- 1,000,000 – 4,999,999
- ≥ 5,000,000

Monitoring Mode\*:  Routine Monitoring  Reduced Monitoring

Monitoring Frequency\*:  Quarterly  Annually

Total Number Of Distribution System Monitoring Locations\*: 3

Contact Person: Richard Anderson

Phone Number: 863-993-4565

E-Mail Address (optional): randerson@regionalwater.org

Fax Number (optional): 863-993-4568

\* See 40 CFR 141.621 and 141.623 for more details.

<b>TTHM COMPLIANCE SUMMARY FOR SYSTEMS MONITORING QUARTERLY</b>										
Monitoring Location*	DOH Lab Certification No.	This Quarter				Previous Quarter	2 Quarters Ago	3 Quarters Ago	TTHM LRAA (µg/L)	TTHM OE Value (µg/L)
		No. of TTHM Samples Taken	Date Each TTHM Sample Taken (mo/da/yr)	TTHM Sample Result (µg/L)	TTHM Locational Quarterly Average (µg/L)	TTHM Locational Quarterly Average (µg/L)	TTHM Locational Quarterly Average (µg/L)	TTHM Locational Quarterly Average (µg/L)		
					A	B	C	D		
Peace River Facility (Finished- POE)	E84167	1	4/11/2022	30.9	30.9	32.4	25.2	24.6	28.28	29.85
Charlotte County Utility 10"	E84167	1	4/11/2022	29.4	29.4	35.4	24.8	25.4	28.75	29.75
Carlton 42" (NRTM)	E84167	1	4/11/2022	28.2	28.2	31.3	25.4	25.9	27.7	28.28
Does the TTHM LRAA at any monitoring location violate the TTHM MCL of 80 µg/L? (YES/NO)									NO	
Does the TTHM OE value at any monitoring location exceed 80 µg/L? (YES/NO) ****									NO	
If you are on reduced quarterly monitoring, does the TTHM LRAA exceed 0.040 µg/L at any monitoring location? (YES/NO/NA) *****									N/A	

\* Location names or numbers should correspond to those in your Stage 2 D/DBPR compliance monitoring plan required under 40 CFR 141.622.  
 \*\* Calculate and enter the LRAA beginning at the end of the fourth quarter of Stage 2 monitoring and at the end of each subsequent quarter. Also, if the LRAA calculated based on fewer than four quarters of data would cause the MCL to be exceeded regardless of the monitoring results of subsequent quarters, calculate and enter the LRAA (using zero for the results of subsequent quarters).  
 \*\*\* Calculate the OE value beginning at the end of the third quarter of Stage 2 monitoring and at the end of each subsequent quarter. Enter the OE value if it exceeds 80 µg/L.  
 \*\*\*\* If any TTHM OE value at any location exceeds 80 µg/L, conduct an OE and submit an OE report in accordance with 40 CFR 141.626.  
 \*\*\*\*\* If any TTHM LRAA at any location exceeds 40 µg/L, resume routine quarterly monitoring under 40 CFR 141.621.

<b>HAA5 COMPLIANCE SUMMARY FOR SYSTEMS MONITORING QUARTERLY</b>										
Monitoring Location*	DOH Lab Certification No.	This Quarter				Previous Quarter	2 Quarters Ago	3 Quarters Ago	HAA5 LRAA (µg/L)	HAA5 OE Value (µg/L)
		No. of HAA5 Samples Taken	Date Each HAA5 Sample Taken (mo/da/yr)	HAA5 Sample Result (ug/L)	HAA5 Locational Quarterly Average (µg/L)	HAA5 Locational Quarterly Average (µg/L)	HAA5 Locational Quarterly Average (µg/L)	HAA5 Locational Quarterly Average (µg/L)		
					A	B	C	D		
Peace River Facility (Finished- POE)	E84167	1	4/11/2022	13.6	13.6	26.8	17.7	11.6	17.43	17.93
Charlotte County Utility 10"	E84167	1	4/11/2022	9.7	9.7	23.6	21.6	12.7	16.9	16.15
Carlton 42" (NRTM)	E84167	1	4/11/2022	26.8	26.8	20.7	14.8	15.2	19.38	22.28
Does the HAA5 LRAA at any monitoring location violate the HAA5 MCL of 60 µg/L? (YES/NO)									NO	
Does the HAA5 OE value at any monitoring location exceed 60 µg/L? (YES/NO) ****									NO	
If you are on reduced quarterly monitoring, does the HAA5 LRAA exceed 30 µg/L at any monitoring location? (YES/NO/NA) *****									N/A	

\* Location names or numbers should correspond to those in your Stage 2 D/DBPR compliance monitoring plan required under 40 CFR 141.622.

\*\* Calculate and enter the LRAA beginning at the end of the fourth quarter of Stage 2 monitoring and at the end of each subsequent quarter. Also, if the LRAA calculated based on fewer than four quarters of data would cause the MCL to be exceeded regardless of the monitoring results of subsequent quarters, calculate and enter the LRAA (using zero for the results of subsequent quarters).


\*\*\* Calculate the OE value beginning at the end of the third quarter of Stage 2 monitoring and at the end of each subsequent quarter. Enter the OE value if it exceeds 60 µg/L.

\*\*\*\* If any HAA5 OE value at any location exceeds 60 µg/L, you must conduct an OE and submit an OE report in accordance with 40 CFR 141.626.

\*\*\*\*\* If any HAA5 LRAA at any location exceeds 30 µg/L, you must resume routine quarterly monitoring under 40 CFR 141.621.

# BENCHMARK

*EnviroAnalytical Inc.*



FDOH Certification #E84167

Peace River/Manasota R W S  
8998 S W County Road 769  
Arcadia, FL 34269

## ANALYTICAL TEST REPORT

THESE RESULTS MEET NELAC STANDARDS

### DISINFECTION BYPRODUCTS

62-550.310 (3)

REPORT NUMBER: 22040668 - 001


SYSTEM NAME: Carlton 42 (NRTM)

SYSTEM ID: 6142734

PARAMETER ID	PARAMETER NAME	MCL	UNITS	ANALYSIS RESULT	QUALIFIER	ANALYTICAL METHOD	MDL	ANALYSIS DATE	ANALYSIS TIME	LAB ID
2450	MONOCHLOROACETIC ACID	N/A	UG/L	0.5	U	552.2	0.5	04/13/2022	20:03	E84167
2451	DICHLOROACETIC ACID	N/A	UG/L	7.95		552.2	0.5	04/13/2022	20:03	E84167
2452	TRICHLOROACETIC ACID	N/A	UG/L	4.28		552.2	0.5	04/13/2022	20:03	E84167
2453	MONOBROMOACETIC ACID	N/A	UG/L	0.5	U	552.2	0.5	04/13/2022	20:03	E84167
2454	DIBROMOACETIC ACID	N/A	UG/L	2.46		552.2	0.5	04/13/2022	20:03	E84167
2456	TOTAL HAA(5)	60	UG/L	26.8		552.2	0.5	04/13/2022	20:03	E84167
2941	CHLOROFORM	N/A	UG/L	11.5		524.2	0.5	04/13/2022	06:07	E84167
2942	BROMOFORM	N/A	UG/L	0.730	I	524.2	0.5	04/13/2022	06:07	E84167
2943	BROMODICHLOROMETHANE	N/A	UG/L	11.3		524.2	0.5	04/13/2022	06:07	E84167
2944	DIBROMOCHLOROMETHANE	N/A	UG/L	4.64		524.2	0.5	04/13/2022	06:07	E84167
2950	TRIHALOMETHANES, TOTAL	80	UG/L	28.2		524.2	0.5	04/13/2022	06:07	E84167

# BENCHMARK

## *EnviroAnalytical Inc.*



FDOH Certification #E84167

Peace River/Manasota R W S  
8998 S W County Road 769  
Arcadia, FL 34269

### ANALYTICAL TEST REPORT

**THESE RESULTS MEET NELAC STANDARDS**

#### DISINFECTION BYPRODUCTS


62-550.310 (3)

REPORT NUMBER: 22040668 - 002  
SYSTEM NAME: Charlotte County Utility 10  
SYSTEM ID: 6142734

PARAMETER ID	PARAMETER NAME	MCL	UNITS	ANALYSIS RESULT	QUALIFIER	ANALYTICAL METHOD	MDL	ANALYSIS DATE	ANALYSIS TIME	LAB ID
2450	MONOCHLOROACETIC ACID	N/A	UG/L	0.5	U	552.2	0.5	04/13/2022	20:46	E84167
2451	DICHLOROACETIC ACID	N/A	UG/L	4.93		552.2	0.5	04/13/2022	20:46	E84167
2452	TRICHLOROACETIC ACID	N/A	UG/L	2.93		552.2	0.5	04/13/2022	20:46	E84167
2453	MONOBROMOACETIC ACID	N/A	UG/L	0.5	U	552.2	0.5	04/13/2022	20:46	E84167
2454	DIBROMOACETIC ACID	N/A	UG/L	1.84	I	552.2	0.5	04/13/2022	20:46	E84167
2456	TOTAL HAA(5)	60	UG/L	9.70		552.2	0.5	04/13/2022	20:46	E84167
2941	CHLOROFORM	N/A	UG/L	12.1		524.2	0.5	04/13/2022	06:37	E84167
2942	BROMOFORM	N/A	UG/L	0.5	U	524.2	0.5	04/13/2022	06:37	E84167
2943	BROMODICHLOROMETHANE	N/A	UG/L	12.1		524.2	0.5	04/13/2022	06:37	E84167
2944	DIBROMOCHLOROMETHANE	N/A	UG/L	5.23		524.2	0.5	04/13/2022	06:37	E84167
2950	TRIALOMETHANES, TOTAL	80	UG/L	29.4		524.2	0.5	04/13/2022	06:37	E84167

# BENCHMARK

*EnviroAnalytical Inc.*



FDOH Certification #E84167

Peace River/Manasota R W S  
8998 S W County Road 769  
Arcadia, FL 34269

## ANALYTICAL TEST REPORT

THESE RESULTS MEET NELAC STANDARDS

### DISINFECTION BYPRODUCTS

62-550.310 (3)

REPORT NUMBER: 22040668 - 003  
SYSTEM NAME: Peace River Facility  
SYSTEM ID: 6142734

PARAMETER ID	PARAMETER NAME	MCL	UNITS	ANALYSIS RESULT	QUALIFIER	ANALYTICAL METHOD	MDL	ANALYSIS DATE	ANALYSIS TIME	LAB ID
2450	MONOCHLOROACETIC ACID	N/A	UG/L	0.5	U	552.2	0.5	04/13/2022	21:29	E84167
2451	DICHLOROACETIC ACID	N/A	UG/L	6.75		552.2	0.5	04/13/2022	21:29	E84167
2452	TRICHLOROACETIC ACID	N/A	UG/L	4.54		552.2	0.5	04/13/2022	21:29	E84167
2453	MONOBROMOACETIC ACID	N/A	UG/L	0.5	U	552.2	0.5	04/13/2022	21:29	E84167
2454	DIBROMOACETIC ACID	N/A	UG/L	2.35		552.2	0.5	04/13/2022	21:29	E84167
2456	TOTAL HAA(5)	60	UG/L	13.6		552.2	0.5	04/13/2022	21:29	E84167
2941	CHLOROFORM	N/A	UG/L	12.2		524.2	0.5	04/13/2022	07:07	E84167
2942	BROMOFORM	N/A	UG/L	0.5	U	524.2	0.5	04/13/2022	07:07	E84167
2943	BROMODICHLOROMETHANE	N/A	UG/L	13.2		524.2	0.5	04/13/2022	07:07	E84167
2944	DIBROMOCHLOROMETHANE	N/A	UG/L	5.51		524.2	0.5	04/13/2022	07:07	E84167
2950	TRIHALOMETHANES, TOTAL	80	UG/L	30.9		524.2	0.5	04/13/2022	07:07	E84167

#### DATA QUALIFIERS THAT MAY APPLY:

I = Reported value is between the laboratory MDL and the PQL.  
J = Estimated value.  
J3 = Estimated value. Quality control criteria for precision or accuracy not met.  
J4 = Estimated value. Sample matrix interference suspected.  
Q = Sample held beyond accepted hold time.  
U = Analyte analyzed but not detected at the value indicated.  
V = Analyte detected in sample and method blank. Results for this analyte in associated samples may be biased high. Standard, Duplicate, and Spike values are within control limits. Reported data are usable.  
Y = Analysis performed on an improperly preserved sample. Data may be inaccurate.

#### NOTES:

PQL = 4 x MDL.  
ND = Not Detected at or above adjusted reporting limit.  
MBAS calculated as LAS; molecular weight = 340.

#### COMMENTS:

For questions or comments regarding these results, please contact us at (941)723-9986.  
Results relate only to the samples.

**Benchmark EnviroAnalytical, Inc.**

1711 Twelfth Street East  
 Palmetto, FL 34221  
 (941) 723-9986  
 (941) 723-6061 fax  
 WWW.Benchmarkea.com

**Client: Peace River/ Manasota RWS**  
 8998 SW County Road 769  
 Arcadia, FL 34269  
 (863) 993-4565  
 Fax: (863) 993-4568

COC # 63

Chain of Custody Form: Quarterly TTHM/HAA

Project Name: Peace River Facility Compliance Monitoring -- Qtly (Jan., April, July, Oct.) Laboratory Submission #:

Method of Discharge<sup>2</sup>: DW

22040668

Sample Name	Sample Type <sup>1</sup>	Collection		Container			Preservative <sup>4</sup>	Parameters for Analysis	Laboratory Sample #
		Date	Time	Qty	Capacity	Type <sup>3</sup>			
<b>Carlton 42 (NRTM)</b> Cl <sub>2</sub> @ time of collection: <u>2.5</u> pH @ time of collection: <u>7.86</u>	Grab	4/11/22	1110	1	250mL	Glass	NH <sub>4</sub> Cl	HAA's	1
				3	40mL*	Glass Vials	NaThio	THM's	
<b>Charlotte County Utility 10</b> Cl <sub>2</sub> @ time of collection: <u>4.1</u> pH @ time of collection: <u>7.81</u>	Grab	4/11/22	0955	1	250mL	Glass	NH <sub>4</sub> Cl	HAA's	2
				3	40mL*	Glass Vials	NaThio	THM's	
<b>Peace River Facility</b> Cl <sub>2</sub> @ time of collection: <u>4.5</u> pH @ time of collection: <u>7.99</u>	Grab	4/11/22	0900	1	250mL	Glass	NH <sub>4</sub> Cl	HAA's	3
				3	40mL*	Glass Vials	NaThio	THM's	

\* Fill all 3 Vials Full, no head space, sample can not have any air bubbles.

1 "Sample Type" is used to indicate whether the sample was a grab (G) or whether it was a composite (C).  
 2 "Sample Matrix" is used to indicate whether the sample is being discharged to drinking water (DW), groundwater (GW), surface water (SW), soil, sediment (SDMNT), or sludge (SLDG).  
 3 "Container Type" is used to indicate whether the container is plastic (P) or glass (G).  
 4 Sample must be refrigerated or stored in wet ice after collection. The temperature during storage should be less than or equal to 6°C (42.8°F).  
 Under "Preservative," list any preservatives that were added to the sample container.

Laboratory Sample Acceptability: pH < 8  
 BEA Temperature: 2.7°C

**Instructions:**  
 1. Each bottle has a label identifying sample ID, premeasured preservative contained in the bottle, sample type, client ID, and parameters for analysis.  
 2. The following information should be added to each bottle label after collection with permanent black ink: date and time of collection, sampler's name or initials, and any field number or ID.  
 3. All bottles not containing preservative may be rinsed with appropriate sample prior to collection.  
 4. The client is responsible for documentation of the sampling event. Please note special sampling events on the sample custody form.

1	Collector: <u>John Ramsey John Ramsey</u>	Date: <u>4/11/22</u>	Time: <u>1157</u>	Received By: <u>Melinda Merchant Melinda Merchant - BEAS</u>	Date: <u>4/11/22</u>	Time: <u>1157</u>
2	Relinquished by: <u>Melinda Merchant Melinda Merchant - BEAS</u>	Date: <u>4/11/22</u>	Time: <u>11:59</u>	Received By: <u>Muchall</u>	Date: <u>4/11/22</u>	Time: <u>11:59</u>
3	Relinquished by: <u>Muchall</u>	Date: <u>4/11/22</u>	Time: <u>1405</u>	Received By: <u>AHU Nathan Hadsell BEA</u>	Date: <u>4-11-22</u>	Time: <u>1405</u>
4	Relinquished by:	Date:	Time:	Received By:	Date:	Time:

**Florida Department of Environmental Protection  
Safe Drinking Water Program Laboratory Reporting Format**

**PUBLIC WATER SYSTEM INFORMATION** (to be completed by sampler - please type or print legibly)

System Name: Peace River Manasota Regional Water Supply Auth. PWS I.D. #: 6142734  
 System Type (check one):  Community  Nontransient Noncommunity  Transient Noncommunity  
 Address: 8998 S.W. County Rd. 769  
 City: Arcadia, Florida ZIP Code: 34269  
 Phone #: 863 993-4565 Fax #: 863 993-4568 E-Mail Address: randerson@regionalwater.org

**SAMPLE INFORMATION** (to be completed by sampler)

Sample Number: 22040668-001 Sample Date: 4/11/22 Sample Time: 1110  AM  PM (Circle One)  
 Sample Location (be specific): Carlton 42" Location Code: \_\_\_\_\_  
 Disinfectant Residual (Required when reporting results for trihalomethanes and haloacetic acids): 2.5 mg/L Field pH: 7.86

**Sample Type (Check Only One)**

- Distribution
- Entry Point (to Distribution)
- Plant Tap (not for compliance with 62-550)
- Raw (at well or intake)
- Max Residence Time
- Ave Residence Time
- Near First Customer

**Reason(s) for Sample (Check all that apply)**

- Routine Compliance with 62-550
- Confirmation of MCL Exceedance
- Composite of Multiple Sites\*\*
- Other: \_\_\_\_\_
- Replacement (of Invalidated Sample)
- Special (not for compliance with 62-550)
- Clearance (permitting)

Sampling Procedure Used or Other Comments:

TTM, HAA

\*See 62-550.500(6) for requirements and restrictions.  
And 62-550.512(3) for nitrate or nitrite exceedances.

\*\*See 62-550.550(4) for requirements and  
attach a results page for each site

**SAMPLER CERTIFICATION**

I, John Ramsey (Print Name), Ops Specialist (Print Title), do HEREBY CERTIFY

that the above public water system and sample collection information is complete and correct.

Signature: John Ramsey Date: 4/11/22  
 Certified Operator #: 4668 Phone #: 863 993-4565 Sampler's Fax #: 863 494-2622  
 Sampler's E-mail: jramsey@regionalwater.org

**Florida Department of Environmental Protection  
Safe Drinking Water Program Laboratory Reporting Format**

**PUBLIC WATER SYSTEM INFORMATION** (to be completed by sampler - please type or print legibly)

System Name: Peace River Manasota Regional Water Supply Auth. PWS I.D. #: 6142734  
 System Type (check one):  Community  Nontransient Noncommunity  Transient Noncommunity  
 Address: 8998 S.W. County Rd. 769  
 City: Arcadia, Florida ZIP Code: 34269  
 Phone #: 863 993-4565 Fax #: 863 993-4568 E-Mail Address: randerson@regionalwater.org

**SAMPLE INFORMATION** (to be completed by sampler)

Sample Number: 22040668 - 002 Sample Date: 4/11/22 Sample Time: 0955  AM  PM (Circle One)  
 Sample Location (be specific): Charlotte County 10" Location Code: \_\_\_\_\_  
 Disinfectant Residual (Required when reporting results for trihalomethanes and haloacetic acids): 4.1 mg/L Field pH: 7.8

**Sample Type (Check Only One)**

- Distribution
- Entry Point (to Distribution)
- Plant Tap (not for compliance with 62-550)
- Raw (at well or intake)
- Max Residence Time
- Ave Residence Time
- Near First Customer

**Reason(s) for Sample (Check all that apply)**

- Routine Compliance with 62-550
- Confirmation of MCL Exceedance\*
- Composite of Multiple Sites\*\*
- Other: \_\_\_\_\_
- Replacement (of Invalidated Sample)
- Special (not for compliance with 62-550)
- Clearance (permitting)

Sampling Procedure Used or Other Comments:

TTM, HAA

\*See 62-550.500(6) for requirements and restrictions. And 62-550.512(3) for nitrate or nitrite exceedances.

\*\*See 62-550.550(4) for requirements and attach a results page for each site

**SAMPLER CERTIFICATION**

I, John Ramsey (Print Name), Ops Specialist (Print Title), do HEREBY CERTIFY

that the above public water system and sample collection information is complete and correct.

Signature: John Ramsey Date: 4/11/22  
 Certified Operator #: 4668 Phone #: 863 993-4565 Sampler's Fax #: 863 494-2622  
 Sampler's E-mail: jramsey@regionalwater.org

**Florida Department of Environmental Protection  
Safe Drinking Water Program Laboratory Reporting Format**

**PUBLIC WATER SYSTEM INFORMATION** (to be completed by sampler - please type or print legibly)

System Name: Peace River Manasota Regional Water Supply Auth. PWS I.D. #: 6142734  
 System Type (check one):  Community  Nontransient Noncommunity  Transient Noncommunity  
 Address: 8998 S.W. County Rd. 769  
 City: Arcadia, Florida ZIP Code: 34269  
 Phone #: 863 993-4565 Fax #: 863 993-4568 E-Mail Address: randerson@regionalwater.org

**SAMPLE INFORMATION** (to be completed by sampler)

Sample Number: 22040668-003 Sample Date: 4/11/22 Sample Time: 0900  AM  PM (Circle One)  
 Sample Location (be specific): Peace River Facility Location Code: \_\_\_\_\_  
 Disinfectant Residual (Required when reporting results for trihalomethanes and haloacetic acids): 4.5 mg/L Field pH: 7.99

**Sample Type (Check Only One)**

- Distribution
- Entry Point (to Distribution)
- Plant Tap (not for compliance with 62-550)
- Raw (at well or intake)
- Max Residence Time
- Ave Residence Time
- Near First Customer

**Reason(s) for Sample (Check all that apply)**

- Routine Compliance with 62-550
- Confirmation of MCL Exceedance\*
- Composite of Multiple Sites\*\*
- Other: \_\_\_\_\_
- Replacement (of Invalidated Sample)
- Special (not for compliance with 62-550)
- Clearance (permitting)

Sampling Procedure Used or Other Comments:

TTHM, HAA

\*See 62-550.500(6) for requirements and restrictions  
And 62-550.512(3) for nitrate or nitrite exceedances

\*\*See 62-550.550(4) for requirements and  
attach a results page for each site

**SAMPLER CERTIFICATION**

I, John Ramsey (Print Name), Ops Specialist (Print Title), do HEREBY CERTIFY  
 that the above public water system and sample collection information is complete and correct.

Signature: John Ramsey Date: 4/11/22  
 Certified Operator #: 4668 Phone #: 863 993-4565 Sampler's Fax #: 863 494-2622  
 Sampler's E-mail: jramsey@regionalwater.org

# Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

## LABORATORY CERTIFICATION INFORMATION (to be completed by lab – please type or print legibly)

Lab Name: Benchmark EnviroAnalytical, Inc. Florida DOH Certification #: E84167 Certification Expiration Date: 06/30/2022

**ATTACH CURRENT DOH ANALYTE SHEET\***

Address: 1711 12th Street East, Palmetto, FL 34221 Phone #: 941-723-9986

Were any analyses subcontracted?  Yes  No If yes, please provide DOH certification number(s): \_\_\_\_\_

**ATTACH DOH ANALYTE SHEET FOR EACH SUBCONTRACTED LAB\***

## ANALYSIS INFORMATION (to be completed by lab) Date Sample(s) Received: 04/11/2022

PWS ID (From Page 1): 6142734 Sample Number (From Page 1): \_\_\_\_\_ Lab Assigned Report # or Job ID: 22040668-001


Group(s) Analyzed & Results attached for compliance with Chapter 62-550, F.A.C. (Check all that apply):

<u>Inorganics</u>	<u>Synthetic Organics</u>	<u>Volatile Organics</u>	<u>Disinfection Byproducts</u>	<u>Radionuclides</u>	<u>Secondaries</u>
<input type="checkbox"/> All Except Asbestos	<input type="checkbox"/> All 30	<input type="checkbox"/> All 21	<input checked="" type="checkbox"/> Trihalomethanes	<input type="checkbox"/> Single Sample	<input type="checkbox"/> All 14
<input type="checkbox"/> Partial	<input type="checkbox"/> All Except Dioxin	<input type="checkbox"/> Partial	<input checked="" type="checkbox"/> Haloacetic Acids	<input type="checkbox"/> Qtrly Composite**	<input type="checkbox"/> Partial
<input type="checkbox"/> Nitrate	<input type="checkbox"/> Partial		<input type="checkbox"/> Chlorite		
<input type="checkbox"/> Nitrite	<input type="checkbox"/> Dioxin Only		<input type="checkbox"/> Bromate		
<input type="checkbox"/> Asbestos					

## LAB CERTIFICATION

I, Dale Dixon / Tulay Tanrisever / Kara Peterson, Lab Director / Technical Director & QC Officer / QA Officer, do HEREBY CERTIFY  
(Print Name) (Print Title)

that all attached analytical data are correct and unless noted meet all requirements of the National Environmental Laboratory Accreditation Conference (NELAC).

Signature:  Date: 4/25/22

\* Failure to provide a valid and current Florida DOH lab certification number and a current Analyte Sheet for the attached analysis results will result in rejection of the report, possible enforcement against the public water system for failure to sample, and may result in notification of the DOH Bureau of Laboratory Services.

\*\* Please provide radiological sample dates & locations for each quarter.

**CONFIRMATION & NOTIFICATION IS REQUIRED WITHIN 24 HRS FOR NITRATE OR NITRITE MCL EXCEEDANCES  
NON-DETECTS ARE TO BE REPORTED AS THE MDL WITH A "U" QUALIFIER. (Non-detects reported as "BDL" or with a "<" are not acceptable.)**

## COMPLIANCE DETERMINATION (to be completed by DEP or DOH -- attach notes as necessary)

Sample Collection & Analysis Satisfactory:  Yes  No \_\_\_\_\_ Replacement Sample or Report Requested (circle or highlight group(s) above)

Person Notified: \_\_\_\_\_ Date Notified: \_\_\_\_\_ DEP/DOH Reviewing Official: \_\_\_\_\_

# Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

## LABORATORY CERTIFICATION INFORMATION (to be completed by lab – please type or print legibly)

Lab Name: Benchmark EnviroAnalytical, Inc. Florida DOH Certification #: E84167 Certification Expiration Date: 06/30/2022

**ATTACH CURRENT DOH ANALYTE SHEET\***

Address: 1711 12th Street East, Palmetto, FL 34221 Phone #: 941-723-9986

Were any analyses subcontracted?  Yes  No If yes, please provide DOH certification number(s): \_\_\_\_\_

**ATTACH DOH ANALYTE SHEET FOR EACH SUBCONTRACTED LAB\***

## ANALYSIS INFORMATION (to be completed by lab) Date Sample(s) Received: 04/11/2022

PWS ID (From Page 1): 6142734 Sample Number (From Page 1): \_\_\_\_\_ Lab Assigned Report # or Job ID: 22040668-002


Group(s) Analyzed & Results attached for compliance with Chapter 62-550, F.A.C. (Check all that apply):

<u>Inorganics</u>	<u>Synthetic Organics</u>	<u>Volatile Organics</u>	<u>Disinfection Byproducts</u>	<u>Radionuclides</u>	<u>Secondaries</u>
<input type="checkbox"/> All Except Asbestos	<input type="checkbox"/> All 30	<input type="checkbox"/> All 21	<input checked="" type="checkbox"/> Trihalomethanes	<input type="checkbox"/> Single Sample	<input type="checkbox"/> All 14
<input type="checkbox"/> Partial	<input type="checkbox"/> All Except Dioxin	<input type="checkbox"/> Partial	<input checked="" type="checkbox"/> Haloacetic Acids	<input type="checkbox"/> Qtrly Composite**	<input type="checkbox"/> Partial
<input type="checkbox"/> Nitrate	<input type="checkbox"/> Partial		<input type="checkbox"/> Chlorite		
<input type="checkbox"/> Nitrite	<input type="checkbox"/> Dioxin Only		<input type="checkbox"/> Bromate		
<input type="checkbox"/> Asbestos					

## LAB CERTIFICATION

I, Dale Dixon / Tulay Tanrisever / Kara Peterson, Lab Director / Technical Director & QC Officer / QA Officer, do HEREBY CERTIFY  
(Print Name) (Print Title)

that all attached analytical data are correct and unless noted meet all requirements of the National Environmental Laboratory Accreditation Conference (NELAC).

Signature:  Date: 4/25/22

\* Failure to provide a valid and current Florida DOH lab certification number and a current Analyte Sheet for the attached analysis results will result in rejection of the report, possible enforcement against the public water system for failure to sample, and may result in notification of the DOH Bureau of Laboratory Services.  
\*\* Please provide radiological sample dates & locations for each quarter.

**CONFIRMATION & NOTIFICATION IS REQUIRED WITHIN 24 HRS FOR NITRATE OR NITRITE MCL EXCEEDANCES  
NON-DETECTS ARE TO BE REPORTED AS THE MDL WITH A "U" QUALIFIER. (Non-detects reported as "BDL" or with a "<" are not acceptable.)**

## COMPLIANCE DETERMINATION (to be completed by DEP or DOH -- attach notes as necessary)

Sample Collection & Analysis Satisfactory:  Yes  No \_\_\_\_\_ Replacement Sample or Report Requested (circle or highlight group(s) above)

Person Notified: \_\_\_\_\_ Date Notified: \_\_\_\_\_ DEP/DOH Reviewing Official: \_\_\_\_\_

**Florida Department of Environmental Protection  
Safe Drinking Water Program Laboratory Reporting Format**

**LABORATORY CERTIFICATION INFORMATION** (to be completed by lab – please type or print legibly)

Lab Name: Benchmark EnviroAnalytical, Inc. Florida DOH Certification #: E84167 Certification Expiration Date: 06/30/2022

**ATTACH CURRENT DOH ANALYTE SHEET\***

Address: 1711 12th Street East, Palmetto, FL 34221 Phone #: 941-723-9986

Were any analyses subcontracted?  Yes  No If yes, please provide DOH certification number(s): \_\_\_\_\_

**ATTACH DOH ANALYTE SHEET FOR EACH SUBCONTRACTED LAB\***

**ANALYSIS INFORMATION** (to be completed by lab) Date Sample(s) Received: 04/11/2022

PWS ID (From Page 1): 6142734 Sample Number (From Page 1): \_\_\_\_\_ Lab Assigned Report # or Job ID: 22040668-003

Group(s) Analyzed & Results attached for compliance with Chapter 62-550, F.A.C. (Check all that apply):

<u>Inorganics</u>	<u>Synthetic Organics</u>	<u>Volatile Organics</u>	<u>Disinfection Byproducts</u>	<u>Radionuclides</u>	<u>Secondaries</u>
<input type="checkbox"/> All Except Asbestos	<input type="checkbox"/> All 30	<input type="checkbox"/> All 21	<input checked="" type="checkbox"/> Trihalomethanes	<input type="checkbox"/> Single Sample	<input type="checkbox"/> All 14
<input type="checkbox"/> Partial	<input type="checkbox"/> All Except Dioxin	<input type="checkbox"/> Partial	<input checked="" type="checkbox"/> Haloacetic Acids	<input type="checkbox"/> Qtrly Composite**	<input type="checkbox"/> Partial
<input type="checkbox"/> Nitrate	<input type="checkbox"/> Partial		<input type="checkbox"/> Chlorite		
<input type="checkbox"/> Nitrite	<input type="checkbox"/> Dioxin Only		<input type="checkbox"/> Bromate		
<input type="checkbox"/> Asbestos					

**LAB CERTIFICATION**

I, Dale Dixon / Tulay Tanrisever / Kara Peterson, Lab Director / Technical Director & QC Officer / QA Officer, do HEREBY CERTIFY  
(Print Name) (Print Title)

that all attached analytical data are correct and unless noted meet all requirements of the National Environmental Laboratory Accreditation Conference (NELAC).

Signature:  Date: 4/25/22

\* Failure to provide a valid and current Florida DOH lab certification number and a current Analyte Sheet for the attached analysis results will result in rejection of the report, possible enforcement against the public water system for failure to sample, and may result in notification of the DOH Bureau of Laboratory Services.  
\*\* Please provide radiological sample dates & locations for each quarter.

**CONFIRMATION & NOTIFICATION IS REQUIRED WITHIN 24 HRS FOR NITRATE OR NITRITE MCL EXCEEDANCES  
NON-DETECTS ARE TO BE REPORTED AS THE MDL WITH A "U" QUALIFIER. (Non-detects reported as "BDL" or with a "<" are not acceptable.)**

**COMPLIANCE DETERMINATION** (to be completed by DEP or DOH -- attach notes as necessary)

Sample Collection & Analysis Satisfactory:  Yes  No \_\_\_\_\_ Replacement Sample or Report Requested (circle or highlight group(s) above)

Person Notified: \_\_\_\_\_ Date Notified: \_\_\_\_\_ DEP/DOH Reviewing Official: \_\_\_\_\_

# Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

DISINFECTION BYPRODUCTS  
62-550.310(3)

Report Number / Job ID: 22040668-001

Disinfectant Residual (mg/L): 2.5

PWS ID (From Page 1): 6142734

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Regulatory MRL**	Analysis Date	Analysis Time	DOH Lab Certification #
1009	Chlorite	1000	µg/L					20***			E
1011	Bromate	10	µg/L					5.0 or 1.0****			E

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Regulatory MRL**	Analysis Date	Analysis Time	DOH Lab Certification #
2450	Monochloroacetic Acid	N/A	µg/L	0.5	U	552.2	0.5	2.0	4/13/2022	20:03	E84167
2451	Dichloroacetic Acid	N/A	µg/L	7.95		552.2	0.5	1.0	4/13/2022	20:03	E84167
2452	Trichloroacetic Acid	N/A	µg/L	4.28		552.2	0.5	1.0	4/13/2022	20:03	E84167
2453	Monobromoacetic Acid	N/A	µg/L	0.5	U	552.2	0.5	1.0	4/13/2022	20:03	E84167
2454	Dibromoacetic Acid	N/A	µg/L	2.46		552.2	0.5	1.0	4/13/2022	20:03	E84167
2456	Total Haloacetic Acids (HAA5)	60	µg/L	26.8		552.2	0.5	---	4/13/2022	20:03	E84167

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Regulatory MRL**	Analysis Date	Analysis Time	DOH Lab Certification #
2941	Chloroform	N/A	µg/L	11.5		524.2	0.5	1.0	4/13/2022	06:07	E84167
2942	Bromoform	N/A	µg/L	0.730	I	524.2	0.5	1.0	4/13/2022	06:07	E84167
2943	Bromodichloromethane	N/A	µg/L	11.3		524.2	0.5	1.0	4/13/2022	06:07	E84167
2944	Dibromochloromethane	N/A	µg/L	4.64		524.2	0.5	1.0	4/13/2022	06:07	E84167
2950	Total Trihalomethanes (TTHM)	80	µg/L	28.2		524.2	0.5	---	4/13/2022	06:07	E84167

\*\* Laboratories are required to adhere to the minimum reporting level (MRL) requirements of 40 CFR 141.131(b)(2)(iv).

\*\*\* Applicable to monitoring as prescribed in 40 CFR 141.132.(b)(2)(i)(B) and (b)(2)(ii).

\*\*\*\* Laboratories that use EPA Methods 317.0 Revision 2.0, 326.0 or 321.8 must meet a 1.0 µg/L MRL for bromate.

**NOTE:** Do not round values. Report results to the accuracy, precision, and sensitivity of the analytical method used.

# Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

DISINFECTION BYPRODUCTS  
62-550.310(3)

Report Number / Job ID: 22040668-002

Disinfectant Residual (mg/L): 4.1

PWS ID (From Page 1): 6142734

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Regulatory MRL**	Analysis Date	Analysis Time	DOH Lab Certification #
1009	Chlorite	1000	µg/L					20***			E
1011	Bromate	10	µg/L					5.0 or 1.0****			E

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Regulatory MRL**	Analysis Date	Analysis Time	DOH Lab Certification #
2450	Monochloroacetic Acid	N/A	µg/L	0.5	U	552.2	0.5	2.0	4/13/2022	20:46	E84167
2451	Dichloroacetic Acid	N/A	µg/L	4.93		552.2	0.5	1.0	4/13/2022	20:46	E84167
2452	Trichloroacetic Acid	N/A	µg/L	2.93		552.2	0.5	1.0	4/13/2022	20:46	E84167
2453	Monobromoacetic Acid	N/A	µg/L	0.5	U	552.2	0.5	1.0	4/13/2022	20:46	E84167
2454	Dibromoacetic Acid	N/A	µg/L	1.84	I	552.2	0.5	1.0	4/13/2022	20:46	E84167
2456	Total Haloacetic Acids (HAA5)	60	µg/L	9.70		552.2	0.5	---	4/13/2022	20:46	E84167

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Regulatory MRL**	Analysis Date	Analysis Time	DOH Lab Certification #
2941	Chloroform	N/A	µg/L	12.1		524.2	0.5	1.0	4/13/2022	06:37	E84167
2942	Bromoform	N/A	µg/L	0.5	U	524.2	0.5	1.0	4/13/2022	06:37	E84167
2943	Bromodichloromethane	N/A	µg/L	12.1		524.2	0.5	1.0	4/13/2022	06:37	E84167
2944	Dibromochloromethane	N/A	µg/L	5.23		524.2	0.5	1.0	4/13/2022	06:37	E84167
2950	Total Trihalomethanes (TTHM)	80	µg/L	29.4		524.2	0.5	---	4/13/2022	06:37	E84167

\*\* Laboratories are required to adhere to the minimum reporting level (MRL) requirements of 40 CFR 141.131(b)(2)(iv).

\*\*\* Applicable to monitoring as prescribed in 40 CFR 141.132.(b)(2)(i)(B) and (b)(2)(ii).

\*\*\*\* Laboratories that use EPA Methods 317.0 Revision 2.0, 326.0 or 321.8 must meet a 1.0 µg/L MRL for bromate.

**NOTE:** Do not round values. Report results to the accuracy, precision, and sensitivity of the analytical method used.

# Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

DISINFECTION BYPRODUCTS  
62-550.310(3)

Report Number / Job ID: 22040668-003

Disinfectant Residual (mg/L): 4.5

PWS ID (From Page 1): 6142734

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Regulatory MRL**	Analysis Date	Analysis Time	DOH Lab Certification #
1009	Chlorite	1000	µg/L					20***			E
1011	Bromate	10	µg/L					5.0 or 1.0****			E

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Regulatory MRL**	Analysis Date	Analysis Time	DOH Lab Certification #
2450	Monochloroacetic Acid	N/A	µg/L	0.5	U	552.2	0.5	2.0	4/13/2022	21:29	E84167
2451	Dichloroacetic Acid	N/A	µg/L	6.75		552.2	0.5	1.0	4/13/2022	21:29	E84167
2452	Trichloroacetic Acid	N/A	µg/L	4.54		552.2	0.5	1.0	4/13/2022	21:29	E84167
2453	Monobromoacetic Acid	N/A	µg/L	0.5	U	552.2	0.5	1.0	4/13/2022	21:29	E84167
2454	Dibromoacetic Acid	N/A	µg/L	2.35		552.2	0.5	1.0	4/13/2022	21:29	E84167
2456	Total Haloacetic Acids (HAA5)	60	µg/L	13.6		552.2	0.5	---	4/13/2022	21:29	E84167

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Regulatory MRL**	Analysis Date	Analysis Time	DOH Lab Certification #
2941	Chloroform	N/A	µg/L	12.2		524.2	0.5	1.0	4/13/2022	07:07	E84167
2942	Bromoform	N/A	µg/L	0.5	U	524.2	0.5	1.0	4/13/2022	07:07	E84167
2943	Bromodichloromethane	N/A	µg/L	13.2		524.2	0.5	1.0	4/13/2022	07:07	E84167
2944	Dibromochloromethane	N/A	µg/L	5.51		524.2	0.5	1.0	4/13/2022	07:07	E84167
2950	Total Trihalomethanes (TTHM)	80	µg/L	30.9		524.2	0.5	---	4/13/2022	07:07	E84167

\*\* Laboratories are required to adhere to the minimum reporting level (MRL) requirements of 40 CFR 141.131(b)(2)(iv).

\*\*\* Applicable to monitoring as prescribed in 40 CFR 141.132.(b)(2)(i)(B) and (b)(2)(ii).

\*\*\*\* Laboratories that use EPA Methods 317.0 Revision 2.0, 326.0 or 321.8 must meet a 1.0 µg/L MRL for bromate.

**NOTE:** Do not round values. Report results to the accuracy, precision, and sensitivity of the analytical method used.

**DATA QUALIFIERS THAT MAY APPLY:**

B = Results based upon colony counts outside the ideal range.

G1 = Accuracy standard does not meet method control limits but does meet lab control limits that are in agreement with USEPA generated data. USEPA letter available upon request.

G2 = Accuracy standard exceeds acceptable control limits. Duplicate and spike values are within control limits. Reported data are usable.

G3 = Precision measurement exceeded acceptable control limits. Standard and spike values are within control limits. Reported data are usable.

G4 = Spike recovery exceeds acceptable control limits. Standard and duplicate values are within control limits. Reported data are usable.

I = Reported value is between the laboratory MDL and the PQL.

J3 = Estimated value. Quality control criteria for precision and accuracy not met.

J4 = Estimated value. Sample matrix interference suspected.

J6 = Estimated value. SM5210B test replicates show more than 30% difference between high and low values, indicating potential presence of toxicity within the sample.

K = Off-scale low. Value is known to be < the value reported.

L = Off scale high; reported concentration exceeds the highest standard.

ND = Not Detected at or above adjusted reporting limit.

Q = Sample held beyond accepted hold time.

U = Analyte analyzed but not detected at the value indicated.

V = Analyte detected in sample and method blank. Results for this analyte in associated samples may be biased high. Standard, Duplicate and Spike values are within control limits. Reported data are usable.

X = Value exceed MCL.

Y = Analysis performed on an improperly preserved sample. Data may be inaccurate

Z = Too many colonies were present (TNTC). The numeric value represents the filtration volume



*Laboratory Scope of Accreditation*

Attachment to Certificate #: E84167-54, expiration date June 30, 2022. This listing of accredited analytes should be used only when associated with a valid certificate.

State Laboratory ID: E84167

EPA Lab Code: FL00289

(941) 723-9986

**E84167**  
**Benchmark EnviroAnalytical, Inc.**  
**1711 12th Street East**  
**Palmetto, FL 34221**

**Matrix: Drinking Water**

Analyte	Method/Tech	Category	Certification Type	Effective Date
1,1,1-Trichloroethane	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
1,1,2-Trichloroethane	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
1,1-Dichloroethylene	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
1,2,4-Trichlorobenzene	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
1,2-Dibromo-3-chloropropane (DBCP)	EPA 504.1	Synthetic Organic Contaminants	NELAP	4/20/2009
1,2-Dibromoethane (EDB, Ethylene dibromide)	EPA 504.1	Synthetic Organic Contaminants	NELAP	4/20/2009
1,2-Dichlorobenzene	EPA 524.2	Other Regulated Contaminants	NELAP	12/29/2015
1,2-Dichloroethane	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
1,4-Dichlorobenzene	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
Alkalinity as CaCO3	SM 2320 B	Primary Inorganic Contaminants	NELAP	12/29/2015
Aluminum	EPA 200.7	Secondary Inorganic Contaminants	NELAP	5/25/2004
Ammonia as N	EPA 350.1	Primary Inorganic Contaminants	NELAP	3/7/2011
Antimony	SM 3113 B	Primary Inorganic Contaminants	NELAP	1/3/2002
Arsenic	SM 3113 B	Primary Inorganic Contaminants	NELAP	1/3/2002
Barium	EPA 200.7	Primary Inorganic Contaminants	NELAP	5/25/2004
Benzene	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
Beryllium	EPA 200.7	Primary Inorganic Contaminants	NELAP	5/25/2004
Boron	EPA 200.7	Secondary Inorganic Contaminants	NELAP	3/7/2011
Bromate	EPA 300.1	Primary Inorganic Contaminants	NELAP	11/21/2008
Bromide	EPA 300.0	Primary Inorganic Contaminants	NELAP	5/25/2004
Bromoacetic acid	EPA 552.2	Group I Unregulated Contaminants	NELAP	4/20/2009
Bromodichloromethane	EPA 524.2	Group II Unregulated Contaminants	NELAP	9/28/2005
Bromoform	EPA 200.7	Group II Unregulated Contaminants	NELAP	9/28/2005
Cadmium	EPA 200.7	Primary Inorganic Contaminants	NELAP	5/25/2004
Calcium	EPA 200.7	Primary Inorganic Contaminants	NELAP	5/25/2004
Carbon tetrachloride	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
Chlorate	EPA 300.1	Secondary Inorganic Contaminants	NELAP	11/21/2008
Chloride	EPA 300.0	Secondary Inorganic Contaminants	NELAP	5/25/2004
Chlorine	SM 4500-Cl G	Primary Inorganic Contaminants	NELAP	3/7/2011
Chlorite	EPA 300.1	Primary Inorganic Contaminants	NELAP	11/21/2008
Chloroacetic acid	EPA 552.2	Group I Unregulated Contaminants	NELAP	4/20/2009
Chlorobenzene	EPA 524.2	Other Regulated Contaminants	NELAP	12/29/2015
Chloroform	EPA 524.2	Group II Unregulated Contaminants	NELAP	9/28/2005
Chromium	EPA 200.7	Primary Inorganic Contaminants	NELAP	5/25/2004
cis-1,2-Dichloroethylene	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005

**Clients and Customers are urged to verify the laboratory's current certification status with the Environmental Laboratory Certification Program.**

**Issue Date: 2/3/2022**

**Expiration Date: 6/30/2022**



*Laboratory Scope of Accreditation*

Attachment to Certificate #: E84167-54, expiration date June 30, 2022. This listing of accredited analytes should be used only when associated with a valid certificate.

State Laboratory ID: E84167 EPA Lab Code: FL00289 (941) 723-9986

E84167  
Benchmark EnviroAnalytical, Inc.  
1711 12th Street East  
Palmetto, FL 34221

Matrix: Drinking Water

Analyte	Method/Tech	Category	Certification Type	Effective Date
Color	SM 2120 B	Secondary Inorganic Contaminants	NELAP	7/31/2007
Conductivity	SM 2510 B	Primary Inorganic Contaminants	NELAP	5/25/2004
Copper	EPA 200.7	Primary Inorganic Contaminants; Secondary Inorganic Contaminants	NELAP	5/25/2004
Corrosivity (langlier index)	SM 2330 B	Secondary Inorganic Contaminants	NELAP	3/7/2011
Cyanide	EPA 335.4	Primary Inorganic Contaminants	NELAP	1/7/2021
Dibromoacetic acid	EPA 552.2	Group I Unregulated Contaminants	NELAP	4/20/2009
Dibromochloromethane	EPA 524.2	Group II Unregulated Contaminants	NELAP	9/28/2005
Dichloroacetic acid	EPA 552.2	Group I Unregulated Contaminants	NELAP	4/20/2009
Dissolved organic carbon (DOC)	SM 5310 B	Primary Inorganic Contaminants	NELAP	11/21/2008
Escherichia coli	SM 9223 B	Microbiology	NELAP	1/3/2002
Escherichia coli	SM 9223 B	Microbiology	NELAP	3/7/2011
Ethylbenzene	SM 9223 B /QUANTIT-TRAY	Other Regulated Contaminants	NELAP	9/28/2005
Fluoride	EPA 524.2	Primary Inorganic Contaminants; Secondary Inorganic Contaminants	NELAP	5/25/2004
Fluoride	EPA 300.0	Other Regulated Contaminants	NELAP	5/25/2004
Hardness	SM 2340 B	Secondary Inorganic Contaminants	NELAP	3/7/2011
Heterotrophic plate count	SDMP/LATE	Microbiology	NELAP	7/1/2016
Heterotrophic plate count	SM 9215 B	Microbiology	NELAP	5/25/2004
Hydrogen sulfide	SM 4500S= H (21st ed)	Primary Inorganic Contaminants	NELAP	3/7/2011
Iron	EPA 200.7	Secondary Inorganic Contaminants	NELAP	5/25/2004
Lead	SM 3113 B	Primary Inorganic Contaminants	NELAP	1/3/2002
Magnesium	EPA 200.7	Primary Inorganic Contaminants	NELAP	5/25/2004
Manganese	EPA 200.7	Secondary Inorganic Contaminants	NELAP	5/25/2004
Mercury	EPA 245.1	Primary Inorganic Contaminants	NELAP	1/3/2002
Methylene chloride	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
Molybdenum	EPA 200.7	Secondary Inorganic Contaminants	NELAP	3/7/2011
Nickel	EPA 200.7	Primary Inorganic Contaminants	NELAP	5/25/2004
Nitrate	EPA 353.2	Primary Inorganic Contaminants	NELAP	1/3/2002
Nitrate as N	EPA 300.0	Primary Inorganic Contaminants	NELAP	5/25/2004
Nitrite as N	EPA 300.0	Primary Inorganic Contaminants	NELAP	5/25/2004
Nitrite as N	EPA 353.2	Primary Inorganic Contaminants	NELAP	5/25/2004
Odor	EPA 140.1	Secondary Inorganic Contaminants	NELAP	1/3/2002
Orthophosphate as P	EPA 300.0	Primary Inorganic Contaminants	NELAP	3/7/2011
pH	SM 4500-H+-B	Secondary Inorganic Contaminants	NELAP	7/31/2007
Potassium	EPA 200.7	Secondary Inorganic Contaminants	NELAP	5/25/2004

Clients and Customers are urged to verify the laboratory's current certification status with the Environmental Laboratory Certification Program.

Issue Date: 2/3/2022

Expiration Date: 6/30/2022



## Laboratory Scope of Accreditation

Attachment to Certificate #: E84167-54, expiration date June 30, 2022. This listing of accredited analytes should be used only when associated with a valid certificate.

State Laboratory ID: E84167

EPA Lab Code:

FL00289

(941) 723-9986

E84167

Benchmark Environmental Analytical, Inc.  
1711 12th Street East  
Palmetto, FL 34221

Matrix: Drinking Water

Analyte	Method/Tech	Category	Certification Type	Effective Date
Residue-filterable (TDS)	SM 2540 C	Secondary Inorganic Contaminants	NELAP	7/31/2007
Selenium	SM 3113 B	Primary Inorganic Contaminants	NELAP	2/2/2022
Silica as SiO2	EPA 200.7	Primary Inorganic Contaminants	NELAP	5/25/2004
Silver	EPA 200.7	Secondary Inorganic Contaminants	NELAP	5/25/2004
Sodium	EPA 200.7	Primary Inorganic Contaminants	NELAP	5/25/2004
Styrene	EPA 524.2	Other Regulated Contaminants	NELAP	12/29/2015
Sulfate	EPA 300.0	Primary Inorganic Contaminants Secondary Inorganic Contaminants	NELAP	5/25/2004
Sulfide	SM 4500-S D/UV-VIS	Primary Inorganic Contaminants	NELAP	3/7/2011
Surfactants - MBAS	SM 5540 C	Secondary Inorganic Contaminants	NELAP	1/3/2002
Tetrachloroethylene (Perchloroethylene)	EPA 524.2	Other Regulated Contaminants	NELAP	12/29/2015
Thallium	EPA 200.9	Primary Inorganic Contaminants	NELAP	1/3/2002
Toluene	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
Total coliforms	SM 9223 B	Microbiology	NELAP	1/3/2002
Total coliforms	SM 9223 B /QUANTIT-TRAY	Microbiology	NELAP	3/7/2011
Total cyanide	EPA 335.4	Primary Inorganic Contaminants	NELAP	1/7/2021
Total haloacetic acids (HAA5)	EPA 552.2	Synthetic Organic Contaminants	NELAP	4/20/2009
Total nitrate-nitrite	EPA 300.0	Primary Inorganic Contaminants	NELAP	5/25/2004
Total nitrate-nitrite	EPA 353.2	Primary Inorganic Contaminants	NELAP	1/3/2002
Total organic carbon	SM 5310 B	Primary Inorganic Contaminants	NELAP	5/25/2004
Total trihalomethanes	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
trans-1,2-Dichloroethylene	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
Trichloroacetic acid	EPA 552.2	Group 1 Unregulated Contaminants	NELAP	10/14/2010
Trichloroethene (Trichloroethylene)	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
Turbidity	EPA 180.1	Secondary Inorganic Contaminants	NELAP	3/7/2011
UV 254	SM 5910 B	Primary Inorganic Contaminants	NELAP	11/16/2016
Vanadium	EPA 200.7	Secondary Inorganic Contaminants	NELAP	3/7/2011
Vinyl chloride	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
Xylene (total)	EPA 524.2	Other Regulated Contaminants	NELAP	12/29/2015
Zinc	EPA 200.7	Secondary Inorganic Contaminants	NELAP	5/25/2004

Clients and Customers are urged to verify the laboratory's current certification status with the Environmental Laboratory Certification Program.

Issue Date: 2/3/2022

Expiration Date: 6/30/2022

**QUARTERLY WORKSHEET FOR  
TOTAL ORGANIC CARBON MONTHLY OPERATION REPORT (TOC-MOR)  
FOR SURFACE WATER OR GROUND WATER SYSTEMS UNDER THE DIRECT INFLUENCE  
OF SURFACE WATER**

Qtr. 2	Year 2022
--------	-----------

PWS NAME: Peace River/Man. Reg. Water	PLANT NAME OR NUMBER: Peace River Water Facility
PWS ID NUMBER: 6142734	COUNTY: DeSoto
FACILITY CONTACT: Mike Chell	PHONE NUMBER: 863-993-4565

Type of Treatment: Conventional
---------------------------------

DATE	Monthly TOC Sample Set			Actual % TOC Removed	Step 1 Required % Removal	Step 1 Removal Ratio
	Raw Alkalinity	Treated TOC	Raw TOC			
4/7/2022	65	3	11.8	75	40	1.86
5/12/2022	65	4.49	11.3	60	40	1.51
6/9/2022	63	2.26	11.6	81	40	2.01

DATE	(1-Treated Water TOC % / Source Water TOC) x 100 = Monthly % TOC Removal
4/7/2022	$(1-3.0 / 11.8) \times 100 = 75$
5/12/2022	$(1-4.49 / 11.3) \times 100 = 60$
6/9/2022	$(1-2.26 / 11.6) \times 100 = 81$

DATE	Calculated Monthly TOC % Removal / Required TOC % Removal = Ratio	Ratio > 1.0
4/7/2022	1.86	YES
5/12/2022	1.51	YES
6/9/2022	2.01	YES

**QUARTERLY SAMPLE INFORMATION - 2nd QUARTER REPORT 2022**

Parameter	Number of Samples Collected	Number of paired (source water and treated water) samples collected	Sample Location	Name of the Individual Sampler	Laboratory Certification Number responsible for the analysis	Date(s) of Collection	Date of Analysis	Analytical Method Used		
Raw Alkalinity	3	3	Raw Water	John Ramsey	E84167	4/7/22	4/8/2022	SM2320B		
						5/12/22	5/19/2022	SM2320B		
						6/9/22	6/14/2022	SM2320B		
Raw TOC	3		3	Raw Water	John Ramsey	E84167	4/7/22	4/15/2022	SM5310B	
							5/12/22	5/18/2022	SM5310B	
							6/9/22	6/10/2022	SM5310B	
Treated TOC	3			3	Finish Water	John Ramsey	E84167	4/7/22	4/15/2022	SM5310B
								5/12/22	5/18/2022	SM5310B
								6/9/22	6/16/2022	SM5310B

\*I hereby certify that I am familiar with the information contained in this report and that, to the best of my knowledge, the information is true, complete and accurate.

Operator's Signature:           *J.R. Cliff*                6/21/2022

Certificate Number & Clas A 15153

Expiration Date:           4/30/2023

**TOTAL ORGANIC CARBON (TOC) ANNUAL REMOVAL SUMMARY**

	By Month for Past 12 Months											
	7	8	9	10	11	12	1	2	3	4	5	6
<b>Actual Month/Year</b>	Jul-21	Aug-21	Sep-21	Oct-21	Nov-21	Dec-21	Jan-22	Feb-22	Mar-22	Apr-22	May-22	Jun-22
Number of Paired (Source Water and Treated Water) TOC Samples Collected	1	1	1	1	1	1	1	1	1	1	1	1
Raw Water TOC Monthly Arithmetic Average	12	13.8	16.3	14.6	15.3	18.7	17.3	14.8	14.8	11.8	11.3	11.6
Treated Water TOC Monthly Arithmetic Average	3.53	3.2	3.92	3	3.9	4.63	4.7	3.86	4.35	3	4.49	2.26
Actual % TOC Removed *	71	77	76	79	75	75	73	74	71	75	60	81
% TOC Removed Quarterly Arithmetic Average			74			76			72			72
% TOC Removed 12 Month Running Arithmetic Average												74
Required % Removal	40	40	40	40	50	50	50	40	40	40	40	40
Monthly Actual/Required Ratio	1.76	1.92	1.90	1.99	1.49	1.50	1.46	1.85	1.77	1.86	1.51	2.01
Quarterly Average of Actual/Required Ratio			1.861			1.660			1.690			1.795
Running 12 Month Actual/Required Ratio												1.752


Does the system meet the enhanced coagulation or enhanced softening % removal requirements in 40 CFR 141.135(b) (2) or (3) for the past four quarters? (Yes/No)	<b>YES</b>
---	------------

\*Attach calculations for determining compliance with the TOC percent removal requirements, as provided in 40 CFR 141.135(e)(1). 40 CFR 141.135(3)(1), TOC removal requirements that are found in 40 CFR 141.135(e)(1) are calculated using the following formula:

(1- Treated water TOC/source water TOC) X 100 = Actual Monthly TOC Removal Percentage  
Removal Ratio = Calculated Monthly TOC % Removal/Required % Removal

# BENCHMARK

*EnviroAnalytical Inc.*



NELAC Certification #E84167

## ANALYTICAL TEST REPORT

THESE RESULTS MEET NELAC STANDARDS

Submission Number : 22040443

Peace River/Manasota R W S  
8998 S W County Road 769  
Arcadia, FL 34269

Project Name : MONTHLY ANALYSIS

PWS# 6142734

Date Received : 04/07/2022

Time Received : 1520

Submission Number: 22040443  
Sample Number: 001  
Sample Description: Raw Water

Sample Date: 04/07/2022  
Sample Time: 0915  
Sample Method: Grab

Parameter	Result	Units	MDL	PQL	Procedure	Analysis Date/Time	Analyst
TOTAL ALKALINITY (CACO3)	65.0	MG/L	0.594	2.376	SM2320B	04/08/2022 11:00	EG
TOTAL ORGANIC CARBON	11.8	MG/L	0.271	1.084	SM5310B	04/15/2022 12:59	PP


Submission Number: 22040443  
Sample Number: 002  
Sample Description: Transfer Station #4

Sample Date: 04/07/2022  
Sample Time: 0905  
Sample Method: Grab

Parameter	Result	Units	MDL	PQL	Procedure	Analysis Date/Time	Analyst
TOTAL ORGANIC CARBON	3.00	MG/L	0.271	1.084	SM5310B	04/15/2022 12:59	PP

# BENCHMARK

*EnviroAnalytical Inc.*



NELAC Certification #E84167

04/15/2022

Dale D. Dixon / Laboratory Director

Date

Tülay Tanrisever - Technical Director/QC Officer

Kara Peterson - QA Officer

## DATA QUALIFIERS THAT MAY APPLY:

A = Value reported is an average of two or more determinations.

B = Results based upon colony counts outside the ideal range.

H = Value based on field kit determination. Results may not be accurate.

I = Reported value is between the laboratory MDL and the PQL.

J1 = Estimated value. Surrogate recovery limits exceeded.

J2 = Estimated value. No quality control criteria exists for component.

J3 = Estimated value. Quality control criteria for precision or accuracy not met.

J4 = Estimated value. Sample matrix interference suspected.

J5 = Estimated value. Data questionable due to improper lab or field protocols.

K = Off-scale low. Value is known to be < the value reported.

L = Off-scale high. Value is known to be > the value reported.

N = Presumptive evidence of presence of material.

O = Sampled, but analysis lost or not performed.

Q = Sample held beyond accepted hold time.

T = Value reported is < MDL. Reported for informational purposes only and shall not be used in statistical analysis.

U = Analyte analyzed but not detected at the value indicated.

V = Analyte detected in sample and method blank. Results for this analyte in associated samples may be biased high. Standard, Duplicate and Spike values are within control limits. Reported data are usable.

Y = Analysis performed on an improperly preserved sample. Data may be inaccurate.

Z = Too many colonies were present (TNTC). The numeric value represents the filtration volume.

! = Data deviate from historically established concentration ranges.

? = Data rejected and should not be used. Some or all of QC data were outside criteria, and the presence or absence of the analyte cannot be determined from the data.

\* = Not reported due to interference.

Oil & Grease - If client does not send sufficient sample quantity for spike evaluation surface water samples are supplied by the laboratory.

## NOTES:

MBAS calculated as LAS; molecular weight = 340.

PQL = 4xMDL.

ND = Not detected at or above the adjusted reporting limit.

G1 = Accuracy standard does not meet method control limits, but does meet lab control limits that are in agreement with USEPA generated data. USEPA letter available upon request.

G2 = Accuracy standard exceeds acceptable control limits. Duplicate and spike values are within control limits. Reported data are usable.

## COMMENTS:

For questions or comments regarding these results, please contact us at (941) 723-9986.

*Results relate only to the samples.*

**Benchmark EnviroAnalytical, Inc.**

1711 Twelfth Street East  
 Palmetto, FL 34221  
 (941) 723-9986  
 (941) 723-6061 fax  
 www.benchmarkea.com

**Client: Peace River Regional Water Supply**

8998 SW County Road 769  
 Arcadia, FL 34269  
 (863) 993-4565  
 (863) 993-4568

COC #120

Chain of Custody Form: Monthly Analysis  
 Method of Discharge: DW (Benchmark report format)

Laboratory Submission #: <u>22040443</u>		Parameters for Analysis		Laboratory Sample #		
Sample Name	Sample Type <sup>1</sup>	Collection		Preservative <sup>4</sup>	Parameters for Analysis	Laboratory Sample #
		Date	Time			
Raw Water	Grab	4/7/22	0915	Plain	Total Alkalinity SM230B	1
		#4	Transfer Station	4/7/22	0905	
					TOC SM5310B	2

Chlorine residual at time of collection: 5.5 Temperature at time of collection: 23.9 Turbidity at time of collection: 1.0


Notes:  
 1. "Sample Type" is used to indicate whether the sample was a grab (G) or whether it was a composite (C).  
 2. "Sample Matrix" is used to indicate whether the sample is being discharged to drinking water (DW), groundwater (GW), surface water (SW), saline surface water (SSW), soil, sediment (SDMNT), or sludge (SLDG).  
 3. "Container Type" is used to indicate whether the container is plastic (P) or glass (G).  
 4. Sample must be refrigerated or stored in wet ice after collection. The temperature during storage should be less than or equal to 6°C (42.8°F).  
 5. Under "Preservative," list any preservatives that were added to the sample container. Lot Number of preservative used is specific to the bottles included in the kit. Na2Thio, H2SO4, and HNO3 do not have expiration dates per the manufacturer. Micro bottles are pre-preserved at manufacturing stage. 40mL vials are pre-preserved at manufacturing stage.

1	Collector & Affiliation: (Print & Sign) John Ramsey	Date: 4/7/22	Time: 1137	Received By & Affiliation: (Print & Sign) Melinda Merchant	Date: 4/7/22	Time: 1137
2	Relinquished By & Affiliation: (Print & Sign) Melinda Merchant - BEAs	Date: 4/7/22	Time: 11:42	Received By & Affiliation: (Print & Sign) Nathan Hodsell	Date: 4/7/22	Time: 11:42
3	Relinquished By & Affiliation: (Print & Sign) John Ramsey	Date: 4/7/22	Time: 1520	Received By & Affiliation: (Print & Sign) Nathan Hodsell BEA	Date: 4-7-22	Time: 1520
4	Relinquished By & Affiliation: (Print & Sign)	Date:	Time:	Received By & Affiliation: (Print & Sign)	Date:	Time:

Laboratory Sample Acceptability:  
 pH < 2.8 BEA Temperature: 1.8°C

# BENCHMARK

*EnviroAnalytical Inc.*



NELAC Certification #E84167

## ANALYTICAL TEST REPORT

THESE RESULTS MEET NELAC STANDARDS

Submission Number : 22050754

Peace River/Manasota R W S  
8998 S W County Road 769  
Arcadia, FL 34269

Project Name : MONTHLY ANALYSIS

PWS# 6142734

Date Received : 05/12/2022

Time Received : 1440

Submission Number: 22050754	Sample Date: 05/12/2022
Sample Number: 001	Sample Time: 0925
Sample Description: Raw Water	Sample Method: Grab


Parameter	Result	Units	MDL	PQL	Procedure	Analysis Date/Time	Analyst
TOTAL ALKALINITY (CACO3)	65	MG/L	0.594	2.376	SM2320B	05/19/2022 9:51	EG
TOTAL ORGANIC CARBON	11.3	MG/L	0.271	1.084	SM5310B	05/18/2022 10:41	BLB

Submission Number: 22050754	Sample Date: 05/12/2022
Sample Number: 002	Sample Time: 0910
Sample Description: Transfer Station #4	Sample Method: Grab


Parameter	Result	Units	MDL	PQL	Procedure	Analysis Date/Time	Analyst
TOTAL ORGANIC CARBON	4.49	MG/L	0.271	1.084	SM5310B	05/18/2022 10:41	BLB

# BENCHMARK

*EnviroAnalytical Inc.*



NELAC Certification #E84167

  
Dale D. Dixon / Laboratory Director

05/24/2022

Date

Tülay Tanrısever - Technical Director/QC Officer

Kara Peterson - QA Officer

### DATA QUALIFIERS THAT MAY APPLY:

A = Value reported is an average of two or more determinations.  
B = Results based upon colony counts outside the ideal range.  
H = Value based on field kit determination. Results may not be accurate.  
I = Reported value is between the laboratory MDL and the PQL.  
J1 = Estimated value. Surrogate recovery limits exceeded.  
J2 = Estimated value. No quality control criteria exists for component.  
J3 = Estimated value. Quality control criteria for precision or accuracy not met.  
J4 = Estimated value. Sample matrix interference suspected.  
J5 = Estimated value. Data questionable due to improper lab or field protocols.  
K = Off-scale low. Value is known to be < the value reported.  
L = Off-scale high. Value is known to be > the value reported.  
N = Presumptive evidence of presence of material.  
O = Sampled, but analysis lost or not performed.  
Q = Sample held beyond accepted hold time.

T = Value reported is < MDL. Reported for informational purposes only and shall not be used in statistical analysis.  
U = Analyte analyzed but not detected at the value indicated.  
V = Analyte detected in sample and method blank. Results for this analyte in associated samples may be biased high. Standard, Duplicate and Spike values are within control limits. Reported data are usable.  
Y = Analysis performed on an improperly preserved sample. Data may be inaccurate.  
Z = Too many colonies were present (TNTC). The numeric value represents the filtration volume.  
! = Data deviate from historically established concentration ranges.  
? = Data rejected and should not be used. Some or all of QC data were outside criteria, and the presence or absence of the analyte cannot be determined from the data.  
\* = Not reported due to interference.  
Oil & Grease - If client does not send sufficient sample quantity for spike evaluation surface water samples are supplied by the laboratory.

### NOTES:

MBAS calculated as LAS; molecular weight = 340.  
PQL = 4xMDL.  
ND = Not detected at or above the adjusted reporting limit.  
G1 = Accuracy standard does not meet method control limits, but does meet lab control limits that are in agreement with USEPA generated data. USEPA letter available upon request.  
G2 = Accuracy standard exceeds acceptable control limits. Duplicate and spike values are within control limits. Reported data are usable.

### COMMENTS:

For questions or comments regarding these results, please contact us at (941) 723-9986.

Results relate only to the samples.

**Benchmark EnviroAnalytical, Inc.**

1711 Twelfth Street East  
 Palmetto, FL 34221  
 (941) 723-9986  
 (941) 723-6061 fax  
 www.benchmarkea.com

**Client:**

**Peace River Regional Water Supply**  
 8998 SW County Road 769  
 Arcadia, FL 34269  
 (863) 993-4565  
 (863) 993-4568

COC #120

Chain of Custody Form: Monthly Analysis  
 Method of Discharge: DW (Benchmark report format)

Sample Name	Sample Type	Collection		Qty	Capacity	Type <sup>3</sup>	Preservative <sup>4</sup>	Parameters for Analysis	Laboratory Sample #
		Date	Time						
Raw Water	Grab	5/12/22	0925	1	1/2 Pint	Plastic	Plain	Total Alkalinity SM2320B	1
				1	40mL	Glass Vial	1:1 H <sub>3</sub> PO <sub>4</sub>	TOC SM5310B	
#4 Transfer Station	Grab	5/12/22	0910	1	40mL	Glass Vial	1:1 H <sub>3</sub> PO <sub>4</sub>	TOC SM5310B	2

Laboratory Submission #: 22050754

Chlorine residual at time of collection: 4.5 Temperature at time of collection: 27.1 Turbidity at time of collection: 0.11

Notes:  
 1. "Sample Type" is used to indicate whether the sample was a grab (G) or whether it was a composite (C).  
 2. "Sample Matrix" is used to indicate whether the sample is being discharged to drinking water (DW), groundwater (GW), surface water (SW), fresh surface water (FSW), saline surface water (SSW), soil, sediment (SDMNT), or sludge (SLDG).  
 3. "Container Type" is used to indicate whether the container is plastic (P) or glass (G).  
 4. Sample must be refrigerated or stored in wet ice after collection. The temperature during storage should be less than or equal to 6°C (42.8°F).  
 5. Under "Preservative," list any preservatives that were added to the sample container. Lot Number of preservative used is specific to the bottles included in the kit. NaThio, H<sub>2</sub>SO<sub>4</sub>, and HNO<sub>3</sub> do not have expiration dates per the manufacturer. Micro bottles are pre-preserved at manufacturing stage. 40mL vials are pre-preserved at manufacturing stage.


Instructions:  
 1. Each bottle has a label identifying sample ID, premeasured preservative contained in the bottle, sample type, client ID, and parameters for analysis.  
 2. The following information should be added to each bottle label after collection with permanent black ink: date and time of collection, sampler's name or initials, and any field number or ID.  
 3. All bottles not containing preservative may be rinsed with appropriate sample prior to collection.  
 4. The client is responsible for documentation of the sampling event. Please note special sampling events on the sample custody form.  
 5. Sample kit has been created by BEA using new, certified bottles unless otherwise noted.

Collector & Affiliation (Print & Sign)	Date	Time	Received By & Affiliation (Print & Sign)	Date	Time
Brook Waternick BEAS	5/12/22	1155	Received By & Affiliation (Print & Sign) Nathan Hudson BEA	5/12/22	1155
Received By & Affiliation (Print & Sign) Nathan Hudson BEA	5/12/22	1440	Received By & Affiliation (Print & Sign)	5/12/22	1440
Received By & Affiliation (Print & Sign)			Received By & Affiliation (Print & Sign)		

Laboratory Sample Acceptability:  
 pH <: 7 BEA Temperature: 27.1

# BENCHMARK

*EnviroAnalytical Inc.*



NELAC Certification #E84167

## ANALYTICAL TEST REPORT

THESE RESULTS MEET NELAC STANDARDS

Submission Number : 22060544

Peace River/Manasota R W S  
8998 S W County Road 769  
Arcadia, FL 34269

Project Name : MONTHLY ANALYSIS

PWS# 6142734

Date Received : 06/09/2022

Time Received : 1445

Submission Number: 22060544  
Sample Number: 001  
Sample Description: Raw Water

Sample Date: 06/09/2022  
Sample Time: 0900  
Sample Method: Grab

Parameter	Result	Units	MDL	PQL	Procedure	Analysis Date/Time	Analyst
TOTAL ALKALINITY (CACO3)	63.0	MG/L	0.594	2.376	SM2320B	06/14/2022 14:43	EG
TOTAL ORGANIC CARBON	11.6	MG/L	0.271	1.084	SM5310B	06/10/2022 15:25	CM


Submission Number: 22060544  
Sample Number: 002  
Sample Description: Transfer Station #4

Sample Date: 06/09/2022  
Sample Time: 0845  
Sample Method: Grab

Parameter	Result	Units	MDL	PQL	Procedure	Analysis Date/Time	Analyst
TOTAL ORGANIC CARBON	2.26	MG/L	0.271	1.084	SM5310B	06/16/2022 16:00	CM

# BENCHMARK

*EnviroAnalytical Inc.*



NELAC Certification #E84167

*Dale D. Dixon*

Dale D. Dixon / Laboratory Director

06/17/2022

Date

Tulay Tanrisever - Technical Director/QC Officer

Kara Peterson - QA Officer

#### DATA QUALIFIERS THAT MAY APPLY:

A = Value reported is an average of two or more determinations.  
B = Results based upon colony counts outside the ideal range.  
H = Value based on field kit determination. Results may not be accurate.  
I = Reported value is between the laboratory MDL and the PQL.  
J1 = Estimated value. Surrogate recovery limits exceeded.  
J2 = Estimated value. No quality control criteria exists for component.  
J3 = Estimated value. Quality control criteria for precision or accuracy not met.  
J4 = Estimated value. Sample matrix interference suspected.  
J5 = Estimated value. Data questionable due to improper lab or field protocols.  
K = Off-scale low. Value is known to be < the value reported.  
L = Off-scale high. Value is known to be > the value reported.  
N = Presumptive evidence of presence of material.  
O = Sampled, but analysis lost or not performed.  
Q = Sample held beyond accepted hold time.

T = Value reported is < MDL. Reported for informational purposes only and shall not be used in statistical analysis.  
U = Analyte analyzed but not detected at the value indicated.  
V = Analyte detected in sample and method blank. Results for this analyte in associated samples may be biased high. Standard, Duplicate and Spike values are within control limits. Reported data are usable.  
Y = Analysis performed on an improperly preserved sample. Data may be inaccurate.  
Z = Too many colonies were present (TNTC). The numeric value represents the filtration volume.  
! = Data deviate from historically established concentration ranges.  
? = Data rejected and should not be used. Some or all of QC data were outside criteria, and the presence or absence of the analyte cannot be determined from the data.  
\* = Not reported due to interference.  
Oil & Grease - If client does not send sufficient sample quantity for spike evaluation surface water samples are supplied by the laboratory.

#### NOTES:

MBAS calculated as LAS; molecular weight = 340.  
PQL = 4xMDL.  
ND = Not detected at or above the adjusted reporting limit.  
G1 = Accuracy standard does not meet method control limits, but does meet lab control limits that are in agreement with USEPA generated data. USEPA letter available upon request.  
G2 = Accuracy standard exceeds acceptable control limits. Duplicate and spike values are within control limits. Reported data are usable.

#### COMMENTS:

For questions or comments regarding these results, please contact us at (941) 723-9986.

Results relate only to the samples.

**Benchmark EnviroAnalytical, Inc.**  
 1711 Twelfth Street East  
 Palmetto, FL 34221  
 (941) 723-9986  
 (941) 723-6061 fax  
 www.benchmarkea.com

**Client: Peace River Regional Water Supply**  
 8998 SW County Road 769  
 Arcadia, FL 34269  
 (863) 993-4565  
 (863) 993-4568

COC #120

Chain of Custody Form: Monthly Analysis  
 Method of Discharge: DW (Benchmark report format)

Laboratory Submission #: <b>22060549</b>		Laboratory Sample #							
Sample Name	Sample Type	Collection		Qty	Capacity	Type <sup>3</sup>	Preservative <sup>4</sup>	Parameters for Analysis	Laboratory Sample #
		Date	Time						
Raw Water	Grab	6/9/22	0900	1	½ Pint	Plastic	Plain	Total Alkalinity SM2320B	1
Transfer Station #4	Grab	6/9/22	0845	1	40mL	Glass Vial	1:1 H <sub>3</sub> PO <sub>4</sub>	TOC SM5310B	2

Chlorine residual at time of collection: 4.6 Temperature at time of collection: 28.0 Turbidity at time of collection: 0.14

Notes:  
 1. "Sample Type" is used to indicate whether the sample was a grab (G) or whether it was a composite (C).  
 2. "Sample Matrix" is used to indicate whether the sample is being discharged to drinking water (DW), groundwater (GW), surface water (SW), fresh surface water (FSW), saline surface water (SSW), soil, sediment (SDMANT), or sludge (SLDG).  
 3. "Container Type" is used to indicate whether the container is plastic (P) or glass (G).  
 4. Sample must be refrigerated or stored in wet ice after collection. The temperature during storage should be less than or equal to 6°C (42.8°F).  
 5. Under "Preservative," list any preservatives that were added to the sample container. List Number of preservative used is specific to the bottles included in the kit. NaThio, H<sub>2</sub>SO<sub>4</sub>, and HNO<sub>3</sub> do not have expiration dates per the manufacturer. Micro bottles are pre-preserved at manufacturing stage. 40mL vials are pre-preserved at manufacturing stage.

Each bottle has a label identifying sample ID, unpreserved preservative contained in the bottle, sample type, client ID, and parameters for analysis.  
 All bottles not containing preservative may be rinsed with appropriate sample prior to collection.  
 The client is responsible for documentation of the sampling event. Please note special sampling events on the sample custody form.  
 Sample kit has been created by BFA using only certified bottles unless otherwise noted.

Collector & Affiliation: *John Ramsey*  
 Relinquished By & Affiliation: *John Ramsey*  
 Relinquished By & Affiliation: *John Ramsey*  
 Relinquished By & Affiliation: *John Ramsey*

1	Collector & Affiliation: <i>John Ramsey</i>	Date: 6/9/22	Time: 11:25	Received By & Affiliation: <i>Melinda Merchant</i>	Date: 6/9/22	Time: 11:35
2	Relinquished By & Affiliation: <i>Melinda Merchant - BEAS</i>	Date: 6/9/22	Time: 11:35	Received By & Affiliation: <i>John Ramsey</i>	Date: 6/9/22	Time: 11:35
3	Relinquished By & Affiliation: <i>John Ramsey</i>	Date: 6/9/22	Time: 11:45	Received By & Affiliation: <i>Nathan Hadsall</i>	Date: 6/9/22	Time: 11:45
4	Relinquished By & Affiliation:	Date:	Time:	Received By & Affiliation:	Date:	Time:

Laboratory Sample Acceptability:  
 pH < 7 BEA Temperature: 1.4°C

**AQUIFER STORAGE AND RECOVERY QUARTERLY SUMMARY REPORT (example reporting format)**

<b>QUARTERLY REPORTING PERIOD:</b> Quarter 2 2022	<b>Year:</b> 2022
<b>PWS NAME:</b> Peace River Regional Water Supply Authority	<b>PWS ID #</b> 6142734
<b>How Many ASR Wells Do You Have?</b>	<b>21</b>

ASR WELL COMPLIANCE SUMMARY 2009												
	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
<b>INJECTION YES/NO</b>	no	no	no	no	no	no						
Dates: From												
Dates: To												
ASR WELL # (s)												

<b>STORAGE Yes/No</b>	yes	yes	yes	No	No	yes						
Dates: From	1/1/2022	2/1/2022	3/1/2022			6/4/2022						
Dates: To	1/31/2022	2/28/2022	3/31/2022			6/30/2022						
ASR WELL # (s)	4,10,11,12, 13,14,15,1 6,17,18,19, 20,T1,S1,S2 ,S3,S5,S6,S 8,S7,S9	4,10,11,12, 13,14,15,1 6,17,18,19, 20,T1,S1,S2 ,S3,S5,S6,S 8,S7,S9	4,10,11,12, 13,14,15,1 6,17,18,19, 20,T1,S1,S2 ,S3,S5,S6,S 8,S7,S9			4,10,11,12, 13,14,15,1 6,17,18,19, 20,T1,S1,S2 ,S3,S5,S6,S 8,S7,S9						


<b>RECOVERY Yes/No</b>	no	yes	yes	yes	yes	yes						
Dates: From		2/15/2022	3/30/2022	4/1/2022	5/1/2022	6/1/2022						
Dates: To		2/16/2022	3/31/2022	4/30/2022	5/31/2022	6/4/2022						
ASR WELL # (s)		S5,S6,S7	4,10,11,12, 13,14,15,1 6,17,18,19, 20,	10,11,12,1 3,14,16,17, 18,19,20,T 1,S1,S2,S3, S5,S6,S8,S7 ,S9	10,11,12,1 3,14,16,17, 18,19,20,T 1,S1,S2,S3, S5,S6,S8,S7 ,S9	4,10,11,12, 13,14,16,1 7,18,19,20, T1,S1,S2,S3 ,S5,S6,S8,S 7,S9						

<b>SAMPLES COLLECTED Yes/No</b>	yes	yes	yes	yes	yes	yes						
* ARSENIC (number of samples collected)	1	1	1	1	1	1						
* RADIOLOGICALS (number of sets of samples collected) Gross Alpha, Radium 226 and 228 = 1 Set	1	1	1	1	1	1						

\* Attach laboratory analyses results in approved Drinking Water format.

# BENCHMARK

*EnviroAnalytical Inc.*



FDOH Certification #E84167

Peace River/Manasota R W S  
8998 S W County Road 769  
Arcadia, FL 34269

## ANALYTICAL TEST REPORT

THESE RESULTS MEET NELAC STANDARDS

### INORGANIC ANALYSIS

62-550.310 (1)

REPORT NUMBER: 22040038 - 001


SYSTEM NAME: Facility Lab Tap (Finish Water)

SYSTEM ID: 6142734

PARAMETER ID	PARAMETER NAME	MCL	UNITS	ANALYSIS RESULT	QUALIFIER	ANALYTICAL METHOD	MDL	ANALYSIS DATE	ANALYSIS TIME	LAB ID
1005	ARSENIC	0.010	MG/L	0.002	I	SM3113B	0.00069	04/05/2022	17:47	E84167
1052	SODIUM	160	MG/L	43.5		200.7	0.034	04/04/2022	20:03	E84167

# BENCHMARK

*EnviroAnalytical Inc.*



FDOH Certification #E84167

Peace River/Manasota R W S  
8998 S W County Road 769  
Arcadia, FL 34269

## ANALYTICAL TEST REPORT

THESE RESULTS MEET NELAC STANDARDS

### INORGANIC ANALYSIS

62-550.310 (1)

REPORT NUMBER: 22040038 - 002


SYSTEM NAME: Facility Influent (Raw)

SYSTEM ID: 6142734

PARAMETER ID	PARAMETER NAME	MCL	UNITS	ANALYSIS RESULT	QUALIFIER	ANALYTICAL METHOD	MDL	ANALYSIS DATE	ANALYSIS TIME	LAB ID
1005	ARSENIC	0.010	MG/L	0.004		SM3113B	0.00069	04/05/2022	17:54	E84167
1052	SODIUM	160	MG/L	22.6		200.7	0.034	04/04/2022	20:08	E84167

# BENCHMARK

## EnviroAnalytical Inc.



FDOH Certification #E84167

Peace River/Manasota R W S  
8998 S W County Road 769  
Arcadia, FL 34269

### ANALYTICAL TEST REPORT

**THESE RESULTS MEET NELAC STANDARDS**

#### RADIONUCLIDES

62-550.310 (6)

REPORT NUMBER: 22040038 - 003

SYSTEM NAME: Entry Point (Lab Tap)

SYSTEM ID: 6142734

PARAMETER ID	PARAMETER NAME	MCL	UNITS	ANALYSIS RESULT	QUALIFIER	ANALYTICAL METHOD	MDL	ANALYSIS DATE	ANALYSIS TIME	LAB ID
4002	GROSS ALPHA (INCL URANIUM)	15	PCI/L	2.1+/-1.5	U	900.0	2.1	04/08/2022	08:07	E83033
4020	RADIUM-226	5	PCI/L	0.8+/-0.3		903.1	0.2	04/14/2022	11:49	E83033
4030	RADIUM-228	5	PCI/L	0.5+/-0.4	U	Ra-05	0.5	04/13/2022	10:36	E83033

#### DATA QUALIFIERS THAT MAY APPLY:

I = Reported value is between the laboratory MDL and the PQL.  
 J = Estimated value.  
 J3 = Estimated value. Quality control criteria for precision or accuracy not met.  
 J4 = Estimated value. Sample matrix interference suspected.  
 Q = Sample held beyond accepted hold time.  
 U = Analyte analyzed but not detected at the value indicated.  
 V = Analyte detected in sample and method blank. Results for this analyte in associated samples may be biased high. Standard, Duplicate, and Spike values are within control limits. Reported data are usable.  
 Y = Analysis performed on an improperly preserved sample. Data may be inaccurate.

#### NOTES:

PQL = 4 x MDL.  
 ND = Not Detected at or above adjusted reporting limit.  
 MBAS calculated as LAS; molecular weight = 340.

#### COMMENTS:

For questions or comments regarding these results, please contact us at (941)723-9986.

*Results relate only to the samples.*

**Benchmark EnviroAnalytical, Inc. E84167**

1711 Twelfth Street East  
 Palmetto, FL. 34221  
 (941) 723-9986  
 (941) 723-6061 fax

www.Benchmarkea.com

Sample Temperature checked upon receipt with Temperature Gun ID #258

**Client: Peace River/ Manasota RWS**

8998 SW County Road 769  
 Arcadia, FL 34269  
 (863) 993-4565  
 (863) 993-4568 (Fax)

COC # 62

Chain of Custody Form: Peace River Monthly Finish, Raw  
 Project Name: Peace River Facility Monthly Quality Control  
 Method of discharge<sup>2</sup>: DW Sample Type<sup>1</sup>: Grab PWS #: 614-2734

Laboratory Submission #:	22040038
--------------------------	----------

Station ID	Parameters, Preservative <sup>4</sup> , Container Type <sup>3</sup> / Total Number of container = 4		Laboratory Sample #
	As (SM3113B) Na (200.7)	Gross Alpha Total Uranium* Radium 226 & 228	
	1.1 mL 1:4 HNO <sub>3</sub> pH<2 ☑ Acid Lot # 21-19	1.1 mL 1:4 HNO <sub>3</sub> pH<2 ☑ Acid Lot # 21-19	
	1 x 1/2 Pint Plastic	2 x 2 Quart Plastic	
Facility Lab Tap (Finish Water)	Date/Time: 4/1/22 0930 .		1
Facility Influent (Raw)	Date/Time: 4/1/22 0940 .		2
Entry Point (Lab Tap)		Date/Time: 4/1/22 0935 ..	3

\* Run Total Uranium only if the Gross Alpha is ≥15 pCi/L.

**Notes:**

- "Sample Type" is used to indicate whether the sample was a grab (G) or whether it was a composite (C).
- "Sample Matrix" is used to indicate whether the sample is being discharged to drinking water (DW), groundwater (GW), surface water (SW), fresh surface water (FSW), saline surface water (SSW), soil, sediment (SDMNT), or sludge (SLDG).
- "Container Type" is used to indicate whether the container is plastic (P) or glass (G).
- Sample must be refrigerated or stored in wet ice after collection. The temperature during storage should be less than or equal to 6°C (42.8°F).
- Under "Preservative," list any preservatives that were added to the sample container. Lot Number of preservative used is specific to the bottles included in the kit. NaThio, H<sub>2</sub>SO<sub>4</sub>, and HNO<sub>3</sub> do not have expiration dates per the manufacturer. Micro bottles are pre-preserved at manufacturing stage. 40mL vials are pre-preserved at manufacturing stage.

**Instructions:**

- Each bottle has a label identifying sample ID, premeasured preservative contained in the bottle, sample type, client ID, and parameters for analysis.
- The following information should be added to each bottle label after collection with permanent black ink: date and time of collection, sampler's name or initials, and any field number or ID.
- All bottles not containing preservative may be rinsed with appropriate sample prior to collection.
- The client is responsible for documentation of the sampling event. Please note special sampling events on the sample custody form.
- Sample kit has been created by BEA using new, certified bottles unless otherwise noted.

Laboratory Sample Acceptability:  
 pH < 2 ; BEA Temperature: 04°C

1	Collector & Affiliation: (Print & Sign) <i>John Ramsey</i> PR/M RWS	Date: 4/1/22	Time: 1100	Received By & Affiliation: (Print & Sign) <i>Brooke Kuterwick</i> BEAS	Date: 4/1/22	Time: 1100
2	Relinquished By & Affiliation: (Print & Sign) <i>Brooke Kuterwick</i> BEAS	Date: 4/1/22	Time: 11:30	Received By & Affiliation: (Print & Sign) <i>Mud Hall</i> MudHall	Date: 4/1/22	Time: 11:30
3	Relinquished By & Affiliation: (Print & Sign) <i>Mud Hall</i> Benchmark	Date: 4/1/22	Time: 1428	Received By & Affiliation: (Print & Sign) <i>Veronica</i> BEA	Date: 4/1/22	Time: 1428
4	Relinquished By & Affiliation: (Print & Sign)	Date:	Time:	Received By & Affiliation: (Print & Sign)	Date:	Time:

## INTERLABORATORY SAMPLE TRANSMITTAL FORM

Benchmark EnviroAnalytical, Inc.  
 1711 12<sup>th</sup> Street East  
 Palmetto, FL 34221  
 (941) 723-9986  
 (941) 723-6061 fax  
 WWW.Benchmarkea.com  
 Office QC Check: \_\_\_\_\_  
 Bottle Check: \_\_\_\_\_



Date:	04/04/22		
# of Samples:	1	Total # of Bottles:	2
Method of Shipment:	Hand Delivery		
Subcontract Laboratory:	Florida Radiochemistry 5456 Hoffner Ave. #201 Orlando, Fl. 32812 Phone: 407-382-7733 Fax: 407-382-7744		
Page	1	of	1

10 BUSINESS DAY T.A.T. PLEASE

Laboratory Submission #	Collection		Sample Matrix*	Collection Method**	Preservative	Container			Parameters	Conductivity** (µmhos)
	Date	Time				Qty	Capacity	Type***		
22040038-003	04/01/22	0935	DW	Grab	1:4 HNO <sub>3</sub>	2	2 Qt.	P	GROSS ALPHA, RADIUM 226/228 TOTAL URANIUM**	

\*\* Run Total Uranium only if Gross Alpha is greater than 15 pCi/L.

\* Sample Matrix abbreviations: Groundwater (GW), Surface Water (SW), Saline Surface Water (SSW), Fresh Surface Water(FSW), Drinking Water (DW), Sludge (Slgd), Solid (Sol), Soil (Soil), Domestic Effluent (Dom Eff), Industrial Effluent (Ind Eff).  
 \*\* Sample Method abbreviations: Grab (G), Composite (C), 24 Hour Composite (24HR Comp.).  
 \*\*\* Container Type abbreviations: Plastic (P), Glass (G).

Relinquished By: (Benchmark)	Sign Name:		Date:	4/4/22	Received By:		Date:	4-5-22
	Print Name:	Kara McGowan	Time:		MIKE JARAMAN	Time:	10:40	
Relinquished By:	Sign Name:		Date:		Received By:		Date:	
	Print Name:		Time:			Time:		

**Florida Department of Environmental Protection  
Safe Drinking Water Program Laboratory Reporting Format**

**PUBLIC WATER SYSTEM INFORMATION** (to be completed by sampler - please type or print legibly)

System Name: Peace River Manasota Regional Water Supply Auth. PWS I.D. #: 6142734  
 System Type (check one):  Community  Nontransient Noncommunity  Transient Noncommunity  
 Address: 8998 S.W. County Rd. 769  
 City: Arcadia, Florida ZIP Code: 34269  
 Phone #: 863 993-4565 Fax #: 863 993-4568 E-Mail Address: randerson@regionalwater.org

**SAMPLE INFORMATION** (to be completed by sampler)

Sample Number: 1 Sample Date: 4/1/22 Sample Time: 0930  AM  PM (Circle One)  
 Sample Location (be specific): Facility Lab Tap (Finish Water) Location Code: \_\_\_\_\_  
 Disinfectant Residual (Required when reporting results for trihalomethanes and haloacetic acids): 4.2 mg/L Field pH: 8.12  
Sample Type (Check Only One)

- Distribution
- Entry Point (to Distribution)
- Plant Tap (not for compliance with 62-550)
- Raw (at well or intake)
- Max Residence Time
- Ave Residence Time
- Near First Customer

- Reason(s) for Sample (Check all that apply)
- Routine Compliance with 62-550
  - Confirmation of MCL Exceedance
  - Composite of Multiple Sites\*\*
  - Other: \_\_\_\_\_
  - Replacement (of invalidated Sample)
  - Special (not for compliance with 62-550)
  - Clearance (permitting)

Sampling Procedure Used or Other Comments: As, Na

\*See 62-550.500(6) for requirements and restrictions. And 62-550.512(3) for nitrate or nitrite exceedances. \*\*See 62-550.550(4) for requirements and attach a results page for each site

**SAMPLER CERTIFICATION**

I, John Ramsey (Print Name), Ops Specialist (Print Title), do HEREBY CERTIFY that the above public water system and sample collection information is complete and correct.

Signature: John Ramsey Date: 4/1/22  
 Certified Operator #: 4668 Phone #: 863 993-4565 Sampler's Fax #: 863 494-2622  
 Sampler's E-mail: jramsey@regionalwater.org

**Florida Department of Environmental Protection  
Safe Drinking Water Program Laboratory Reporting Format**

**PUBLIC WATER SYSTEM INFORMATION** (to be completed by sampler - please type or print legibly)

System Name: Peace River Manasota Regional Water Supply Auth. PWS I.D. #: 6142734  
 System Type (check one):  Community  Nontransient Noncommunity  Transient Noncommunity  
 Address: 8998 S.W. County Rd. 769  
 City: Arcadia, Florida ZIP Code: 34269  
 Phone #: 863 993-4565 Fax #: 863 993-4568 E-Mail Address: randerson@regionalwater.org

**SAMPLE INFORMATION** (to be completed by sampler)

Sample Number: 2 Sample Date: 4/1/22 Sample Time: 0940  AM  PM (Circle One)  
 Sample Location (be specific): Facility Influent (Raw) Location Code: \_\_\_\_\_  
 Disinfectant Residual (Required when reporting results for trihalomethanes and haloacetic acids): 0 mg/L Field pH: 7.93

**Sample Type (Check Only One)**

- Distribution
- Entry Point (to Distribution)
- Plant Tap (not for compliance with 62-550)
- Raw (at well or intake)
- Max Residence Time
- Ave Residence Time
- Near First Customer

**Reason(s) for Sample (Check all that apply)**

- Routine Compliance with 62-550
- Confirmation of MCL Exceedance\*
- Composite of Multiple Sites\*\*
- Other: \_\_\_\_\_
- Replacement (of Invalidated Sample)
- Special (not for compliance with 62-550)
- Clearance (permitting)

**Sampling Procedure Used or Other Comments:**

As, Na

\*See 62-550.500(6) for requirements and restrictions.  
And 62-550.512(3) for nitrate or nitrite exceedances.

\*\*See 62-550.550(4) for requirements and attach a results page for each site.

**SAMPLER CERTIFICATION**

I, John Ramsey (Print Name), Ops. Specialist (Print Title), do HEREBY CERTIFY that the above public water system and sample collection information is complete and correct.

Signature: John Ramsey Date: 4/1/22  
 Certified Operator #: 4668 Phone #: 863 993-4565 Sampler's Fax #: 863 494-2622  
 Sampler's E-mail: jramsey@regionalwater.org

**Florida Department of Environmental Protection  
Safe Drinking Water Program Laboratory Reporting Format**

**PUBLIC WATER SYSTEM INFORMATION** (to be completed by sampler - please type or print legibly)

System Name: Peace River Manasota Regional Water Supply Auth. PWS I.D. #: 6142734  
 System Type (check one):  Community  Nontransient Noncommunity  Transient Noncommunity  
 Address: 8998 S.W. County Rd. 769  
 City: Arcadia, Florida ZIP Code: 34269  
 Phone #: 863 993-4565 Fax #: 863 993-4568 E-Mail Address: randerson@regionalwater.org

**SAMPLE INFORMATION** (to be completed by sampler)

Sample Number: 3 Sample Date: 4/1/22 Sample Time: 0935  AM  PM (Circle One)  
 Sample Location (be specific): Entry Point (Lab Tap) Location Code: \_\_\_\_\_  
 Disinfectant Residual (Required when reporting results for trihalomethanes and haloacetic acids): 4.2 mg/L Field pH: 8.12

**Sample Type (Check Only One)**

- Distribution
- Entry Point (to Distribution)
- Plant Tap (not for compliance with 62-550)
- Raw (at well or intake)
- Max Residence Time
- Ave Residence Time
- Near First Customer

**Reason(s) for Sample (Check all that apply)**

- Routine Compliance with 62-550
- Confirmation of MCL Exceedance
- Composite of Multiple Sites
- Other: \_\_\_\_\_
- Replacement (of Invalidated Sample)
- Special (not for compliance with 62-550)
- Clearance (permitting)

**Sampling Procedure Used or Other Comments:**

Gross Alpha Radium 226+228

\*See 62-550.500(6) for requirements and restrictions.  
And 62-550.512(3) for nitrate or nitrite exceedances.

\*\*See 62-550.550(4) for requirements and  
attach a results page for each site.

**SAMPLER CERTIFICATION**

I, John Ramsey (Print Name), Ops. Specialist (Print Title), do HEREBY CERTIFY  
 that the above public water system and sample collection information is complete and correct.

Signature: John Ramsey  
 Certified Operator #: 4668 Phone #: 863 993-4565  
 Sampler's E-mail: jramsey@regionalwater.org

Date: 4/1/22  
 Sampler's Fax #: 863 494-2622

**Florida Department of Environmental Protection  
Safe Drinking Water Program Laboratory Reporting Format**

**LABORATORY CERTIFICATION INFORMATION** (to be completed by lab – please type or print legibly)

Lab Name: Benchmark EnviroAnalytical, Inc. Florida DOH Certification #: E84167 Certification Expiration Date: 06/30/2022

**ATTACH CURRENT DOH ANALYTE SHEET\***

Address: 1711 12th Street East, Palmetto, FL 34221 Phone #: 941-723-9986

Were any analyses subcontracted?  Yes  No If yes, please provide DOH certification number(s): \_\_\_\_\_

**ATTACH DOH ANALYTE SHEET FOR EACH SUBCONTRACTED LAB\***

**ANALYSIS INFORMATION** (to be completed by lab) Date Sample(s) Received: 04/01/22

PWS ID (From Page 1): 6142734 Sample Number (From Page 1): \_\_\_\_\_ Lab Assigned Report # or Job ID: 22040038-001

Group(s) Analyzed & Results attached for compliance with Chapter 62-550, F.A.C. (Check all that apply):

- |  |  |                                  |   |  |                                  |
|--|--|----------------------------------|---|--|----------------------------------|
| <u>Inorganics</u>                            | <u>Synthetic Organics</u>                  | <u>Volatile Organics</u>         | <u>Disinfection Byproducts</u>            | <u>Radionuclides</u>                       | <u>Secondaries</u>               |
| <input type="checkbox"/> All Except Asbestos | <input type="checkbox"/> All 30            | <input type="checkbox"/> All 21  | <input type="checkbox"/> Trihalomethanes  | <input type="checkbox"/> Single Sample     | <input type="checkbox"/> All 14  |
| <input checked="" type="checkbox"/> Partial  | <input type="checkbox"/> All Except Dioxin | <input type="checkbox"/> Partial | <input type="checkbox"/> Haloacetic Acids | <input type="checkbox"/> Qtrly Composite** | <input type="checkbox"/> Partial |
| <input type="checkbox"/> Nitrate             | <input type="checkbox"/> Partial           |                                  | <input type="checkbox"/> Chlorite         |  |                                  |
| <input type="checkbox"/> Nitrite             | <input type="checkbox"/> Dioxin Only       |                                  | <input type="checkbox"/> Bromate          |  |                                  |
| <input type="checkbox"/> Asbestos            |  |                                  |   |  |                                  |

**LAB CERTIFICATION**

I, Dale Dixon / Tulay Tarrisever / Kara Peterson, Lab Director / Technical Director & QC Officer / QA Officer, do HEREBY CERTIFY  
(Print Name) (Print Title)

that all attached analytical data are correct and unless noted meet all requirements of the National Environmental Laboratory Accreditation Conference (NELAC).

Signature: \_\_\_\_\_ Date: 4/15/2022

\* Failure to provide a valid and current Florida DOH lab certification number and a current Analyte Sheet for the attached analysis results will result in rejection of the report, possible enforcement against the public water system for failure to sample, and may result in notification of the DOH Bureau of Laboratory Services.

\*\* Please provide radiological sample dates & locations for each quarter.

**CONFIRMATION & NOTIFICATION IS REQUIRED WITHIN 24 HRS FOR NITRATE OR NITRITE MCL EXCEEDANCES  
NON-DETECTS ARE TO BE REPORTED AS THE MDL WITH A "U" QUALIFIER. (Non-detects reported as "BDL" or with a "<" are not acceptable.)**

**COMPLIANCE DETERMINATION** (to be completed by DEP or DOH -- attach notes as necessary)

Sample Collection & Analysis Satisfactory:  Yes  No Replacement Sample or Report Requested (circle or highlight group(s) above)

Person Notified: \_\_\_\_\_ Date Notified: \_\_\_\_\_ DEP/DOH Reviewing Official: \_\_\_\_\_

**Florida Department of Environmental Protection  
Safe Drinking Water Program Laboratory Reporting Format**

**LABORATORY CERTIFICATION INFORMATION** (to be completed by lab – please type or print legibly)

Lab Name: Benchmark EnviroAnalytical, Inc. Florida DOH Certification #: E84167 Certification Expiration Date: 06/30/2022

**ATTACH CURRENT DOH ANALYTE SHEET\***

Address: 1711 12th Street East, Palmetto, FL 34221 Phone #: 941-723-9986

Were any analyses subcontracted?  Yes  No If yes, please provide DOH certification number(s): \_\_\_\_\_

**ATTACH DOH ANALYTE SHEET FOR EACH SUBCONTRACTED LAB\***

**ANALYSIS INFORMATION** (to be completed by lab) Date Sample(s) Received: 04/01/22

PWS ID (From Page 1): 6142734 Sample Number (From Page 1): \_\_\_\_\_ Lab Assigned Report # or Job ID: 22040038-002


Group(s) Analyzed & Results attached for compliance with Chapter 62-550, F.A.C. (Check all that apply):

<u>Inorganics</u>	<u>Synthetic Organics</u>	<u>Volatile Organics</u>	<u>Disinfection Byproducts</u>	<u>Radionuclides</u>	<u>Secondaries</u>
<input type="checkbox"/> All Except Asbestos	<input type="checkbox"/> All 30	<input type="checkbox"/> All 21	<input type="checkbox"/> Trihalomethanes	<input type="checkbox"/> Single Sample	<input type="checkbox"/> All 14
<input checked="" type="checkbox"/> Partial	<input type="checkbox"/> All Except Dioxin	<input type="checkbox"/> Partial	<input type="checkbox"/> Haloacetic Acids	<input type="checkbox"/> Qtrly Composite**	<input type="checkbox"/> Partial
<input type="checkbox"/> Nitrate	<input type="checkbox"/> Partial		<input type="checkbox"/> Chlorite		
<input type="checkbox"/> Nitrite	<input type="checkbox"/> Dioxin Only		<input type="checkbox"/> Bromate		
<input type="checkbox"/> Asbestos					

**LAB CERTIFICATION**

I, Dale Dixon / Tulay Tanrisever / Kara Peterson, Lab Director / Technical Director & QC Officer / QA Officer, do HEREBY CERTIFY  
(Print Name) (Print Title)

that all attached analytical data are correct and unless noted meet all requirements of the National Environmental Laboratory Accreditation Conference (NELAC).

Signature:  Date: 4/15/2022

\* Failure to provide a valid and current Florida DOH lab certification number and a current Analyte Sheet for the attached analysis results will result in rejection of the report, possible enforcement against the public water system for failure to sample, and may result in notification of the DOH Bureau of Laboratory Services.  
\*\* Please provide radiological sample dates & locations for each quarter.

**CONFIRMATION & NOTIFICATION IS REQUIRED WITHIN 24 HRS FOR NITRATE OR NITRITE MCL EXCEEDANCES  
NON-DETECTS ARE TO BE REPORTED AS THE MDL WITH A "U" QUALIFIER. (Non-detects reported as "BDL" or with a "<" are not acceptable.)**

**COMPLIANCE DETERMINATION** (to be completed by DEP or DOH -- attach notes as necessary)

Sample Collection & Analysis Satisfactory:  Yes  No \_\_\_\_\_ Replacement Sample or Report Requested (circle or highlight group(s) above)

Person Notified: \_\_\_\_\_ Date Notified: \_\_\_\_\_ DEP/DOH Reviewing Official: \_\_\_\_\_

**Florida Department of Environmental Protection  
Safe Drinking Water Program Laboratory Reporting Format**

**LABORATORY CERTIFICATION INFORMATION** (to be completed by lab – please type or print legibly)

Lab Name: Benchmark EnviroAnalytical, Inc. Florida DOH Certification #: E84167 Certification Expiration Date: 06/30/2022

**ATTACH CURRENT DOH ANALYTE SHEET\***

Address: 1711 12th Street East, Palmetto, FL 34221 Phone #: 941-723-9986

Were any analyses subcontracted?  Yes  No If yes, please provide DOH certification number(s): E83033

**ATTACH DOH ANALYTE SHEET FOR EACH SUBCONTRACTED LAB\***

**ANALYSIS INFORMATION** (to be completed by lab) Date Sample(s) Received: 04/01/22

PWS ID (From Page 1): 6142734 Sample Number (From Page 1): \_\_\_\_\_ Lab Assigned Report # or Job ID: 22040038-003

Group(s) Analyzed & Results attached for compliance with Chapter 62-550, F.A.C. (Check all that apply):

- |  |  |                                  |   |   |                                  |
|--|--|----------------------------------|---|---|----------------------------------|
| <u>Inorganics</u>                            | <u>Synthetic Organics</u>                  | <u>Volatile Organics</u>         | <u>Disinfection Byproducts</u>            | <u>Radionuclides</u>                              | <u>Secondaries</u>               |
| <input type="checkbox"/> All Except Asbestos | <input type="checkbox"/> All 30            | <input type="checkbox"/> All 21  | <input type="checkbox"/> Trihalomethanes  | <input checked="" type="checkbox"/> Single Sample | <input type="checkbox"/> All 14  |
| <input type="checkbox"/> Partial             | <input type="checkbox"/> All Except Dioxin | <input type="checkbox"/> Partial | <input type="checkbox"/> Haloacetic Acids | <input type="checkbox"/> Qtrly Composite**        | <input type="checkbox"/> Partial |
| <input type="checkbox"/> Nitrate             | <input type="checkbox"/> Partial           |                                  | <input type="checkbox"/> Chlorite         |   |                                  |
| <input type="checkbox"/> Nitrite             | <input type="checkbox"/> Dioxin Only       |                                  | <input type="checkbox"/> Bromate          |   |                                  |
| <input type="checkbox"/> Asbestos            |  |                                  |   |   |                                  |

**LAB CERTIFICATION**

I, Dale Dixon / Tulay Tanrisever / Kara Peterson, Lab Director / Technical Director & QC Officer / QA Officer, do HEREBY CERTIFY  
(Print Name) (Print Title)

that all attached analytical data are correct and unless noted meet all requirements of the National Environmental Laboratory Accreditation Conference (NELAC).

Signature:  Date: 4/15/2022

\* Failure to provide a valid and current Florida DOH lab certification number and a current Analyte Sheet for the attached analysis results will result in rejection of the report, possible enforcement against the public water system for failure to sample, and may result in notification of the DOH Bureau of Laboratory Services.  
\*\* Please provide radiological sample dates & locations for each quarter.

**CONFIRMATION & NOTIFICATION IS REQUIRED WITHIN 24 HRS FOR NITRATE OR NITRITE MCL EXCEEDANCES  
NON-DETECTS ARE TO BE REPORTED AS THE MDL WITH A "U" QUALIFIER. (Non-detects reported as "BDL" or with a "<" are not acceptable.)**

**COMPLIANCE DETERMINATION** (to be completed by DEP or DOH -- attach notes as necessary)

Sample Collection & Analysis Satisfactory:  Yes  No \_\_\_\_\_ Replacement Sample or Report Requested (circle or highlight group(s) above)

Person Notified: \_\_\_\_\_ Date Notified: \_\_\_\_\_ DEP/DOH Reviewing Official: \_\_\_\_\_

# Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

INORGANIC CONTAMINANTS  
62-550.310(1)

Report Number / Job ID: 22040038-001

PWS ID (From Page 1): 6142734

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Analysis Date	Analysis Time	DOH Lab Certification #
1040	Nitrate (as N)	10	mg/L							E
1041	Nitrite (as N)	1	mg/L							E
1005	Arsenic	0.010	mg/L	0.002	I	SM3113B	0.00069	04/05/22	17:47	E84167
1010	Barium	2	mg/L							E
1015	Cadmium	0.005	mg/L							E
1020	Chromium	0.1	mg/L							E
1024	Cyanide	0.2	mg/L							E
1025	Fluoride	4.0	mg/L							E
1030	Lead	0.015	mg/L							E
1035	Mercury	0.002	mg/L							E
1036	Nickel	0.1	mg/L							E
1045	Selenium	0.05	mg/L							E
1052	Sodium	160	mg/L	43.5		200.7	0.034	04/04/22	20:03	E84167
1074	Antimony	0.006	mg/L							E
1075	Beryllium	0.004	mg/L							E
1085	Thallium	0.002	mg/L							E
1094	Asbestos	7 MFL	MFL							E

\*Results must be reported with appropriate qualifiers in accordance with Florida Administrative Code Rule 62-160, Table 1. Results qualified with A, F, H, N, O, T, Z, ?, \*, are unacceptable for compliance with 62-550. Results qualified with a J, Q, R, or Y must be accompanied by written justification and will be evaluated on a case by case basis. To avoid a monitoring violation, unacceptable results must be replaced with acceptable results from samples collected during the same monitoring period.

**Florida Department of Environmental Protection  
Safe Drinking Water Program Laboratory Reporting Format**

INORGANIC CONTAMINANTS  
62-550.310(1)

Report Number / Job ID: 22040038-002

PWS ID (From Page 1): 6142734

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Analysis Date	Analysis Time	DOH Lab Certification #
1040	Nitrate (as N)	10	mg/L							E
1041	Nitrite (as N)	1	mg/L							E
1005	Arsenic	0.010	mg/L	0.004		SM3113B	0.00069	04/05/22	17:54	E84167
1010	Barium	2	mg/L							E
1015	Cadmium	0.005	mg/L							E
1020	Chromium	0.1	mg/L							E
1024	Cyanide	0.2	mg/L							E
1025	Fluoride	4.0	mg/L							E
1030	Lead	0.015	mg/L							E
1035	Mercury	0.002	mg/L							E
1036	Nickel	0.1	mg/L							E
1045	Selenium	0.05	mg/L							E
1052	Sodium	160	mg/L	22.6		200.7	0.034	04/04/22	20:08	E84167
1074	Antimony	0.006	mg/L							E
1075	Beryllium	0.004	mg/L							E
1085	Thallium	0.002	mg/L							E
1094	Asbestos	7 MFL	MFL							E

\*Results must be reported with appropriate qualifiers in accordance with Florida Administrative Code Rule 62-160, Table 1. Results qualified with A, F, H, N, O, T, Z, ?, \*, are unacceptable for compliance with 62-550. Results qualified with a J, Q, R, or Y must be accompanied by written justification and will be evaluated on a case by case basis. To avoid a monitoring violation, unacceptable results must be replaced with acceptable results from samples collected during the same monitoring period.

# Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

## RADIONUCLIDES

62-550.310(6)

Report Number / Job ID: 22040038-003

PWS ID (From Page 1): 6142734

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	RDL	Analysis Error	Analysis Date	Analysis Time	DOH Lab Certification #
4000	Gross Alpha (Excl Uranium)	15	pCi/L	**				3				
4002	Gross Alpha (Incl Uranium)	***	pCi/L	2.1	U	900.0	2.1	3	1.5	04/08/22	08:07	E83033
4006	Combined Uranium**** (U-234, U-235, & U-238)	20	pCi/L					.67				
		30	µg/L					1				
4020	Radium-226	5	pCi/L	0.8		903.1	0.2	1	0.3	04/14/22	11:49	E83033
4030	Radium-228			0.5	U	Ra-05	0.5	1	0.4	04/13/22	10:36	E83033

\*\* If the result exceeds 5 pCi/L, a measurement for radium-226 is required. Uranium is reported separately under Contam ID 4006.

\*\*\* If the results exceed 5 pCi/L, a measurement for radium-226 is required. If the results exceed 15 pCi/L, a measurement for Combined Uranium must be reported separately. The DEP/DOH will subtract the U value from the Gross Alpha (ID 4002) to determine compliance with MCL for Gross Alpha (Excl. U) of 15pCi/L. If the result for ID 4002 Gross Alpha (Including Uranium) does not exceed 15pCi/L, Combined Uranium need not be measured nor reported.

\*\*\*\* If using Uranium testing methods ASTM D5174 or EPA 200.8 only, then Analysis Error need not be reported.

**DATA QUALIFIERS THAT MAY APPLY:**

B = Results based upon colony counts outside the ideal range.

G1 = Accuracy standard does not meet method control limits but does meet lab control limits that are in agreement with USEPA generated data. USEPA letter available upon request.

G2 = Accuracy standard exceeds acceptable control limits. Duplicate and spike values are within control limits. Reported data are usable.

G3 = Precision measurement exceeded acceptable control limits. Standard and spike values are within control limits. Reported data are usable.

G4 = Spike recovery exceeds acceptable control limits. Standard and duplicate values are within control limits. Reported data are usable.

I = Reported value is between the laboratory MDL and the PQL.

J3 = Estimated value. Quality control criteria for precision and accuracy not met.

J4 = Estimated value. Sample matrix interference suspected.

J6 = Estimated value. SM5210B test replicates show more than 30% difference between high and low values, indicating potential presence of toxicity within the sample.

K = Off-scale low. Value is known to be < the value reported.

L = Off scale high; reported concentration exceeds the highest standard.

ND = Not Detected at or above adjusted reporting limit.

Q = Sample held beyond accepted hold time.

U = Analyte analyzed but not detected at the value indicated.

V = Analyte detected in sample and method blank. Results for this analyte in associated samples may be biased high. Standard, Duplicate and Spike values are within control limits. Reported data are usable.

X = Value exceed MCL.

Y = Analysis performed on an improperly preserved sample. Data may be inaccurate

Z = Too many colonies were present (TNTC). The numeric value represents the filtration volume



*Laboratory Scope of Accreditation*

Attachment to Certificate #: E84167-54, expiration date June 30, 2022. This listing of accredited analytes should be used only when associated with a valid certificate.

State Laboratory ID: E84167      EPA Lab Code: FL00289      (941) 723-9986  
**E84167**  
**Benchmark EnviroAnalytical, Inc.**  
**1711 12th Street East**  
**Palmetto, FL 34221**  
**Matrix: Drinking Water**

Analyte	Method/Tech	Category	Certification Type	Effective Date
1,1,1-Trichloroethane	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
1,1,2-Trichloroethane	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
1,1-Dichloroethylene	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
1,2,4-Trichlorobenzene	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
1,2-Dibromo-3-chloropropane (DBCP)	EPA 504.1	Synthetic Organic Contaminants	NELAP	4/20/2009
1,2-Dibromoethane (EDB, Ethylene dibromide)	EPA 504.1	Synthetic Organic Contaminants	NELAP	4/20/2009
1,2-Dichlorobenzene	EPA 524.2	Other Regulated Contaminants	NELAP	12/29/2015
1,2-Dichloroethane	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
1,2-Dichloropropane	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
1,4-Dichlorobenzene	EPA 524.2	Other Regulated Contaminants	NELAP	12/29/2015
Alkalinity as CaCO3	SM 2320 B	Primary Inorganic Contaminants	NELAP	5/25/2004
Aluminum	EPA 200.7	Secondary Inorganic Contaminants	NELAP	5/25/2004
Ammonia as N	EPA 350.1	Primary Inorganic Contaminants	NELAP	3/7/2011
Antimony	SM 3113 B	Primary Inorganic Contaminants	NELAP	1/3/2002
Arsenic	SM 3113 B	Primary Inorganic Contaminants	NELAP	5/25/2004
Barium	EPA 200.7	Other Regulated Contaminants	NELAP	9/28/2005
Benzene	EPA 524.2	Other Regulated Contaminants	NELAP	5/25/2004
Beryllium	EPA 200.7	Primary Inorganic Contaminants	NELAP	5/25/2004
Boron	EPA 200.7	Secondary Inorganic Contaminants	NELAP	3/7/2011
Bromate	EPA 300.1	Primary Inorganic Contaminants	NELAP	11/21/2008
Bromide	EPA 300.0	Primary Inorganic Contaminants	NELAP	5/25/2004
Bromoacetic acid	EPA 552.2	Group I Unregulated Contaminants	NELAP	4/20/2009
Bromodichloromethane	EPA 524.2	Group II Unregulated Contaminants	NELAP	9/28/2005
Bromoform	EPA 524.2	Group II Unregulated Contaminants	NELAP	9/28/2005
Cadmium	EPA 200.7	Primary Inorganic Contaminants	NELAP	5/25/2004
Calcium	EPA 200.7	Primary Inorganic Contaminants	NELAP	5/25/2004
Carbon tetrachloride	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
Chlorate	EPA 300.1	Secondary Inorganic Contaminants	NELAP	11/21/2008
Chloride	EPA 300.0	Secondary Inorganic Contaminants	NELAP	5/25/2004
Chlorine	SM 4500-Cl G	Secondary Inorganic Contaminants	NELAP	5/25/2004
Chlorite	EPA 300.1	Primary Inorganic Contaminants	NELAP	3/7/2011
Chloroacetic acid	EPA 552.2	Group I Unregulated Contaminants	NELAP	4/20/2009
Chlorobenzene	EPA 524.2	Other Regulated Contaminants	NELAP	12/29/2015
Chloroform	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
Chromium	EPA 200.7	Group II Unregulated Contaminants	NELAP	9/28/2005
cis-1,2-Dichloroethylene	EPA 524.2	Primary Inorganic Contaminants	NELAP	5/25/2004
	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005

**Clients and Customers are urged to verify the laboratory's current certification status with the Environmental Laboratory Certification Program.**

**Issue Date: 2/3/2022**

**Expiration Date: 6/30/2022**



## Laboratory Scope of Accreditation

Attachment to Certificate #: E84167-54, expiration date June 30, 2022. This listing of accredited analytes should be used only when associated with a valid certificate.

State Laboratory ID: E84167

EPA Lab Code: FL00289

(941) 723-9986

E84167

Benchmark EnviroAnalytical, Inc.  
1711 12th Street East  
Palmetto, FL 34221

Matrix: Drinking Water

Analyte	Method/Tech	Category	Certification Type	Effective Date
Residue-filterable (TDS)	SM 2540 C	Secondary Inorganic Contaminants	NELAP	7/31/2007
Selenium	SM 3113 B	Primary Inorganic Contaminants	NELAP	2/2/2022
Silica as SiO2	EPA 200.7	Primary Inorganic Contaminants	NELAP	5/25/2004
Silver	EPA 200.7	Secondary Inorganic Contaminants	NELAP	5/25/2004
Sodium	EPA 200.7	Primary Inorganic Contaminants	NELAP	5/25/2004
Styrene	EPA 524.2	Other Regulated Contaminants	NELAP	12/29/2015
Sulfate	EPA 300.0	Primary Inorganic Contaminants; Secondary Inorganic Contaminants	NELAP	5/25/2004
Sulfide	SM 4500-S D/UV-VIS	Primary Inorganic Contaminants	NELAP	3/7/2011
Surfactants - MBAS	SM 5540 C	Secondary Inorganic Contaminants	NELAP	1/3/2002
Tetrachloroethylene (Perchloroethylene)	EPA 524.2	Other Regulated Contaminants	NELAP	12/29/2015
Thallium	EPA 200.9	Primary Inorganic Contaminants	NELAP	1/3/2002
Toluene	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
Total coliforms	SM 9223 B	Microbiology	NELAP	1/3/2002
Total coliforms	SM 9223 B /QUANTIT-TRAY	Microbiology	NELAP	3/7/2011
Total cyanide	EPA 335.4	Primary Inorganic Contaminants	NELAP	1/7/2021
Total haloacetic acids (HAA5)	EPA 552.2	Synthetic Organic Contaminants	NELAP	4/20/2009
Total nitrate-nitrite	EPA 300.0	Primary Inorganic Contaminants	NELAP	5/25/2004
Total nitrate-nitrite	EPA 353.2	Primary Inorganic Contaminants	NELAP	1/3/2002
Total organic carbon	SM 5310 B	Primary Inorganic Contaminants	NELAP	5/25/2004
Total trihalomethanes	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
trans-1,2-Dichloroethylene	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
Trichloroacetic acid	EPA 552.2	Group I Unregulated Contaminants	NELAP	10/14/2010
Trichloroethene (Trichloroethylene)	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
Turbidity	EPA 180.1	Secondary Inorganic Contaminants	NELAP	3/7/2011
UV 254	SM 5910 B	Primary Inorganic Contaminants	NELAP	11/16/2016
Vanadium	EPA 200.7	Secondary Inorganic Contaminants	NELAP	3/7/2011
Vinyl chloride	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
Xylylene (total)	EPA 524.2	Other Regulated Contaminants	NELAP	12/29/2015
Zinc	EPA 200.7	Secondary Inorganic Contaminants	NELAP	5/25/2004

Clients and Customers are urged to verify the laboratory's current certification status with the Environmental Laboratory Certification Program.

Issue Date: 2/3/2022

Expiration Date: 6/30/2022



*Laboratory Scope of Accreditation*

Attachment to Certificate #: E83033-17, expiration date June 30, 2022. This listing of accredited analytes should be used only when associated with a valid certificate.

State Laboratory ID: E83033

EPA Lab Code: FL01113

(407) 382-7733

E83033  
Florida Radiochemistry Services, Inc.  
5456 Hoffner Rd, Suite 201  
Orlando, FL 32812

Matrix: Drinking Water

Analyte	Method/Tech	Category	Certification Type	Effective Date
Gross Alpha	EPA 900.0	Radiochemistry	NELAP	6/28/2001
Gross Beta	EPA 900.0	Radiochemistry	NELAP	6/28/2001
Radium-226	EPA 903.0	Radiochemistry	NELAP	12/15/2003
Radium-226	EPA 903.1	Radiochemistry	NELAP	6/28/2001
Radium-228	EPA Ra-05	Radiochemistry	NELAP	6/28/2001
Uranium (activity)	EPA 908.0	Radiochemistry	NELAP	6/28/2001


Clients and Customers are urged to verify the laboratory's current certification status with the Environmental Laboratory Certification Program.

Issue Date: 7/1/2021

Expiration Date: 6/30/2022

# BENCHMARK

*EnviroAnalytical Inc.*



FDOH Certification #E84167

Peace River/Manasota R W S  
8998 S W County Road 769  
Arcadia, FL 34269

## ANALYTICAL TEST REPORT

THESE RESULTS MEET NELAC STANDARDS

### INORGANIC ANALYSIS

62-550.310 (1)

REPORT NUMBER: 22050225 - 001


SYSTEM NAME: Facility Lab Tap (Finish Water)

SYSTEM ID: 6142734

PARAMETER ID	PARAMETER NAME	MCL	UNITS	ANALYSIS RESULT	QUALIFIER	ANALYTICAL METHOD	MDL	ANALYSIS DATE	ANALYSIS TIME	LAB ID
1005	ARSENIC	0.010	MG/L	0.001	I	SM3113B	0.00069	05/09/2022	11:48	E84167
1052	SODIUM	160	MG/L	48.7		200.7	0.034	05/05/2022	16:53	E84167

# BENCHMARK

*EnviroAnalytical Inc.*



FDOH Certification #E84167

Peace River/Manasota R W S  
8998 S W County Road 769  
Arcadia, FL 34269

## ANALYTICAL TEST REPORT

THESE RESULTS MEET NELAC STANDARDS

### INORGANIC ANALYSIS


62-550.310 (1)

REPORT NUMBER: 22050225 - 002  
SYSTEM NAME: Facility Influent (Raw)  
SYSTEM ID: 6142734

PARAMETER ID	PARAMETER NAME	MCL	UNITS	ANALYSIS RESULT	QUALIFIER	ANALYTICAL METHOD	MDL	ANALYSIS DATE	ANALYSIS TIME	LAB ID
1005	ARSENIC	0.010	MG/L	0.003		SM3113B	0.00069	05/09/2022	11:54	E84167
1052	SODIUM	160	MG/L	26.5		200.7	0.034	05/05/2022	16:57	E84167

# BENCHMARK

*EnviroAnalytical Inc.*



FDOH Certification #E84167

Peace River/Manasota R W S  
8998 S W County Road 769  
Arcadia, FL 34269

## ANALYTICAL TEST REPORT

THESE RESULTS MEET NELAC STANDARDS

### RADIONUCLIDES

62-550.310 (6)

REPORT NUMBER: 22050225 - 003

SYSTEM NAME: Entry Point (Lab Tap)

SYSTEM ID: 6142734

PARAMETER ID	PARAMETER NAME	MCL	UNITS	ANALYSIS RESULT	QUALIFIER	ANALYTICAL METHOD	MDL	ANALYSIS DATE	ANALYSIS TIME	LAB ID
4002	GROSS ALPHA (INCL URANIUM)	15	PCI/L	1.8+/-1.5	U	900.0	1.8	05/13/2022	06:12	E83033
4020	RADIUM-226	5	PCI/L	0.7+/-0.3		903.1	0.1	05/18/2022	12:23	E83033
4030	RADIUM-228	5	PCI/L	0.6+/-0.5		Ra-05	0.6	05/17/2022	11:32	E83033

#### DATA QUALIFIERS THAT MAY APPLY:

I = Reported value is between the laboratory MDL and the PQL.  
J = Estimated value.  
J3 = Estimated value. Quality control criteria for precision or accuracy not met.  
J4 = Estimated value. Sample matrix interference suspected.  
Q = Sample held beyond accepted hold time.  
U = Analyte analyzed but not detected at the value indicated.  
V = Analyte detected in sample and method blank. Results for this analyte in associated samples may be biased high. Standard, Duplicate, and Spike values are within control limits. Reported data are usable.  
Y = Analysis performed on an improperly preserved sample. Data may be inaccurate.

#### NOTES:

PQL = 4 x MDL.  
ND = Not Detected at or above adjusted reporting limit.  
MBAS calculated as LAS; molecular weight = 340.

#### COMMENTS:

For questions or comments regarding these results, please contact us at (941)723-9986.

Results relate only to the samples.

**Benchmark EnviroAnalytical, Inc. E84167**

1711 Twelfth Street East  
 Palmetto, FL. 34221  
 (941) 723-9986  
 (941) 723-6061 fax

[www.Benchmarkea.com](http://www.Benchmarkea.com)

Sample Temperature checked upon receipt with Temperature Gun ID #258

**Client: Peace River/ Manasota RWS**

8998 SW County Road 769  
 Arcadia, FL 34269  
 (863) 993-4565  
 (863) 993-4568 (Fax)

COC # 62

Chain of Custody Form: Peace River Monthly Finish, Raw  
 Project Name: Peace River Facility Monthly Quality Control  
 Method of discharge<sup>2</sup>: DW Sample Type<sup>1</sup>: Grab PWS #: 614-2734

Laboratory Submission #: **22050225**

Station ID	Parameters, Preservative <sup>4</sup> , Container Type <sup>3</sup> / Total Number of container = 4		Laboratory Sample #
	As (SM3113B) Na (200.7)	Gross Alpha Total Uranium* Radium 226 & 228	
	1.1 mL 1:4 HNO <sub>43</sub> pH<2 ✓ Acid Lot # 22-04	1.1 mL 1:4 HNO <sub>43</sub> pH<2 ✓ Acid Lot # 22-04	
	1 x 1/2 Pint Plastic	2 x 2 Quart Plastic	
Facility Lab Tap (Finish Water)	Date/Time: 5/4/22 1025		1
Facility Influent (Raw)	Date/Time: 5/4/22 1035		2
Entry Point (Lab Tap)		Date/Time: 5/4/22 1030	3

\* Run Total Uranium only if the Gross Alpha is ≥15 pCi/L.

**Notes:**

- "Sample Type" is used to indicate whether the sample was a grab (G) or whether it was a composite (C).
- "Sample Matrix" is used to indicate whether the sample is being discharged to drinking water (DW), groundwater (GW), surface water (SW), fresh surface water (FSW), saline surface water (SSW), soil, sediment (SDMNT), or sludge (SLDG).
- "Container Type" is used to indicate whether the container is plastic (P) or glass (G).
- Sample must be refrigerated or stored in wet ice after collection. The temperature during storage should be less than or equal to 6°C (42.8°F).
- Under "Preservative," list any preservatives that were added to the sample container. Lot Number of preservative used is specific to the bottles included in the kit. NaThio, H<sub>2</sub>SO<sub>4</sub>, and HNO<sub>3</sub>, do not have expiration dates per the manufacturer. Micro bottles are pre-preserved at manufacturing stage. 40mL vials are pre-preserved at manufacturing stage.

**Instructions:**

- Each bottle has a label identifying sample ID, premeasured preservative contained in the bottle, sample type, client ID, and parameters for analysis.
- The following information should be added to each bottle label after collection with permanent black ink: date and time of collection, sampler's name or initials, and any field number or ID.
- All bottles not containing preservative may be rinsed with appropriate sample prior to collection.
- The client is responsible for documentation of the sampling event. Please note special sampling events on the sample custody form.
- Sample kit has been created by BEA using new certified bottles unless otherwise noted.

Laboratory Sample Acceptability:  
 pH < 2 / BEA Temperature: 4.3°C

1	Collector & Affiliation: (Print & Sign) <i>John Ramsey</i> PR/MRWS	Date: 5/4/22	Time: 1129	Received By & Affiliation: (Print & Sign) <i>Brooke Kvaternik</i> Brooke Kvaternik BEAS	Date: 5/4/22	Time: 1129
2	Relinquished By & Affiliation: (Print & Sign) <i>Brooke Kvaternik</i> Brooke Kvaternik BEAS	Date: 5/4/22	Time: 11:55	Received By & Affiliation: (Print & Sign) <i>Michelle Hall</i> Michelle Hall BEA	Date: 5/4/22	Time: 11:55
3	Relinquished By & Affiliation: (Print & Sign) <i>Michelle Hall</i> Michelle Hall BEA	Date: 5/4/22	Time: 1440	Received By & Affiliation: (Print & Sign) <i>Annah Jensen</i> Annah Jensen BEA	Date: 05/04/22	Time: 1440
4	Relinquished By & Affiliation: (Print & Sign)	Date:	Time:	Received By & Affiliation: (Print & Sign)	Date:	Time:

## INTERLABORATORY SAMPLE TRANSMITTAL FORM

Benchmark EnviroAnalytical, Inc.  
 1711 12<sup>th</sup> Street East  
 Palmetto, FL 34221  
 (941) 723-9986  
 (941) 723-6061 fax  
 WWW.Benchmarkea.com  
 Office QC Check: \_\_\_\_\_  
 Bottle Check: \_\_\_\_\_

Date:	05/09/22		
# of Samples:	1	Total # of Bottles:	2
Method of Shipment:	Hand Delivery		
Subcontract Laboratory:	Florida Radiochemistry 5456 Hoffner Ave. #201 Orlando, FL 32812 Phone: 407-382-7733 Fax: 407-382-7744		
Page	1	of	1

### 10 BUSINESS DAY T.A.T. PLEASE




Laboratory Submission #	Collection		Sample Matrix*	Collection Method**	Preservative	Container			Parameters	Conductivity** (µmhos)
	Date	Time				Qty	Capacity	Type***		
22050225-003	05/04/22	1030	DW	Grab	1:4 HNO <sub>3</sub>	2	2 Qt.	P	GROSS ALPHA, RADIUM 226/228 TOTAL URANIUM**	

\*\* Run Total Uranium only if Gross Alpha is greater than 15 pCi/L.

\* Sample Matrix abbreviations: Groundwater (GW), Surface Water (SW), Saline Surface Water (SSW), Fresh Surface Water (FSW), Drinking Water (DW), Sludge (Slg), Solid (Sol), Soil (Soil), Domestic Effluent (Dom Eff), Industrial Effluent (Ind Eff).

\*\* Sample Method abbreviations: Grab (G), Composite (C), 24 Hour Composite (24HR Comp.).

\*\*\* Container Type abbreviations: Plastic (P), Glass (G).

Relinquished By: (Benchmark)	Sign Name:		Date:		Received By:		Date:	5/10/22
	Print Name:	Kara McGowan	Time:				Time:	10:33
Relinquished By:	Sign Name:		Date:		Received By:		Date:	
	Print Name:		Time:				Time:	

**Florida Department of Environmental Protection  
Safe Drinking Water Program Laboratory Reporting Format**

**PUBLIC WATER SYSTEM INFORMATION** (to be completed by sampler - please type or print legibly)

System Name: Peace River Manasota Regional Water Supply Auth. PWS I.D. #: 6142734  
 System Type (check one):  Community  Nontransient Noncommunity  Transient Noncommunity  
 Address: 8998 S.W. County Rd. 769  
 City: Arcadia, Florida ZIP Code: 34269  
 Phone #: 863 993-4565 Fax #: 863 993-4568 E-Mail Address: randerson@regionalwater.org

**SAMPLE INFORMATION** (to be completed by sampler)

Sample Number: 22050225-1001 Sample Date: 5/4/22 Sample Time: 1025  AM  PM (Circle One)  
 Sample Location (be specific): Facility Lab Tap (Finish Water) Location Code: \_\_\_\_\_  
 Disinfectant Residual (Required when reporting results for trihalomethanes and haloacetic acids): 4.4 mg/L Field pH: 8.00

**Sample Type (Check Only One)**

- Distribution
- Entry Point (to Distribution)
- Plant Tap (not for compliance with 62-550)
- Raw (at well or intake)
- Max Residence Time
- Ave Residence Time
- Near First Customer

**Reason(s) for Sample (Check all that apply)**

- Routine Compliance with 62-550
- Confirmation of MCL Exceedance\*
- Composite of Multiple Sites\*\*
- Other: \_\_\_\_\_
- Replacement (of Invalidated Sample)
- Special (not for compliance with 62-550)
- Clearance (permitting)

Sampling Procedure Used or Other Comments:

As, Na

\*See 62-550.500(6) for requirements and restrictions. And 62-550.512(3) for nitrate or nitrite exceedances.

\*\*See 62-550.550(4) for requirements and attach a results page for each site

**SAMPLER CERTIFICATION**

I, John Ramsey (Print Name), Ops. Specialist (Print Title), do HEREBY CERTIFY that the above public water system and sample collection information is complete and correct.

Signature: John Ramsey Date: 5/4/22  
 Certified Operator #: 4668 Phone #: 863 993-4565 Sampler's Fax #: 863 494-2622  
 Sampler's E-mail: jramsey@regionalwater.org

**Florida Department of Environmental Protection  
Safe Drinking Water Program Laboratory Reporting Format**

**PUBLIC WATER SYSTEM INFORMATION** (to be completed by sampler – please type or print legibly)

System Name: Peace River Manasota Regional Water Supply Auth. PWS I.D. #: 6142734  
 System Type (check one):  Community  Nontransient Noncommunity  Transient Noncommunity  
 Address: 8998 S.W. County Rd. 769  
 City: Arcadia, Florida ZIP Code: 34269  
 Phone #: 863 993-4565 Fax #: 863 993-4568 E-Mail Address: randerson@regionalwater.org

**SAMPLE INFORMATION** (to be completed by sampler)

Sample Number: 22050225-2 002 Sample Date: 5/4/22 Sample Time: 1035 (AM) PM (Circle One)  
 Sample Location (be specific): Facility Influent (Raw) Location Code: \_\_\_\_\_  
 Disinfectant Residual (Required when reporting results for trihalomethanes and haloacetic acids): 0 mg/L Field pH: 7.78

**Sample Type (Check Only One)**

- Distribution
- Entry Point (to Distribution)
- Plant Tap (not for compliance with 62-550)
- Raw (at well or intake)
- Max Residence Time
- Ave Residence Time
- Near First Customer

**Reason(s) for Sample (Check all that apply)**

- Routine Compliance with 62-550
- Confirmation of MCL Exceedance
- Composite of Multiple Sites\*\*
- Other: \_\_\_\_\_
- Replacement (of Invalidated Sample)
- Special (not for compliance with 62-550)
- Clearance (permitting)

**Sampling Procedure Used or Other Comments:**

As, Na

\*See 62-550.500(6) for requirements and restrictions.  
 And 62-550.512(3) for nitrate or nitrite exceedances.

\*\* See 62-550.550(4) for requirements and attach a results page for each site.

**SAMPLER CERTIFICATION**

I, John Ramsey (Print Name), Ops. Specialist (Print Title), do HEREBY CERTIFY

that the above public water system and sample collection information is complete and correct.

Signature: John Ramsey  
 Certified Operator #: 4668 Phone #: 863 993-4565  
 Sampler's E-mail: jramsey@regionalwater.org

Date: 5/4/22  
 Sampler's Fax #: 863 494-2622

**Florida Department of Environmental Protection  
Safe Drinking Water Program Laboratory Reporting Format**

**PUBLIC WATER SYSTEM INFORMATION** (to be completed by sampler - please type or print legibly)

System Name: Peace River Manasota Regional Water Supply Auth. PWS I.D. #: 6142734  
 System Type (check one):  Community  Nontransient Noncommunity  Transient Noncommunity  
 Address: 8998 S.W. County Rd. 769  
 City: Arcadia, Florida ZIP Code: 34269  
 Phone #: 863 993-4565 Fax #: 863 993-4568 E-Mail Address: randerson@regionalwater.org

**SAMPLE INFORMATION** (to be completed by sampler)

Sample Number: 22050225-3003 Sample Date: 5/4/22 Sample Time: 1030  AM  PM (Circle One)  
 Sample Location (be specific): Entry Point (Lab Tap) Location Code: \_\_\_\_\_  
 Disinfectant Residual (Required when reporting results for trihalomethanes and haloacetic acids): 4.4 mg/L Field pH: 8.00

**Sample Type (Check Only One)**

- Distribution
- Entry Point (to Distribution)
- Plant Tap (not for compliance with 62-550)
- Raw (at well or intake)
- Max Residence Time
- Ave Residence Time
- Near First Customer

**Reason(s) for Sample (Check all that apply)**

- Routine Compliance with 62-550
- Confirmation of MCL Exceedance
- Composite of Multiple Sites\*\*
- Other: \_\_\_\_\_
- Replacement (of Invalidated Sample)
- Special (not for compliance with 62-550)
- Clearance (permitting)

Sampling Procedure Used or Other Comments:

Gross Alpha Radium 226+228

\*See 62-550.500(6) for requirements and restrictions.  
And 62-550.512(3) for nitrate or nitrite exceedances.

\*\*See 62-550.550(4) for requirements and  
attach a results page for each site.

**SAMPLER CERTIFICATION**

I, John Ramsey (Print Name), Ops. Specialist (Print Title), do HEREBY CERTIFY

that the above public water system and sample collection information is complete and correct.

Signature: John Ramsey

Certified Operator #: 4668 Phone #: 863 993-4565

Sampler's E-mail: jramsey@regionalwater.org

Date: 5/4/22

Sampler's Fax #: 863 494-2622

# Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

## LABORATORY CERTIFICATION INFORMATION (to be completed by lab – please type or print legibly)

Lab Name: Benchmark EnviroAnalytical, Inc. Florida DOH Certification #: E84167 Certification Expiration Date: 06/30/2022

ATTACH CURRENT DOH ANALYTE SHEET\*

Address: 1711 12th Street East, Palmetto, FL 34221 Phone #: 941-723-9986

Were any analyses subcontracted?  Yes  No If yes, please provide DOH certification number(s): \_\_\_\_\_

ATTACH DOH ANALYTE SHEET FOR EACH SUBCONTRACTED LAB\*

## ANALYSIS INFORMATION (to be completed by lab) Date Sample(s) Received: 05/04/2022

PWS ID (From Page 1): 6142734 Sample Number (From Page 1): \_\_\_\_\_ Lab Assigned Report # or Job ID: 22050225-001


Group(s) Analyzed & Results attached for compliance with Chapter 62-550, F.A.C. (Check all that apply)

<u>Inorganics</u>	<u>Synthetic Organics</u>	<u>Volatile Organics</u>	<u>Disinfection Byproducts</u>	<u>Radionuclides</u>	<u>Secondaries</u>
<input type="checkbox"/> All Except Asbestos	<input type="checkbox"/> All 30	<input type="checkbox"/> All 21	<input type="checkbox"/> Trihalomethanes	<input type="checkbox"/> Single Sample	<input type="checkbox"/> All 14
<input checked="" type="checkbox"/> Partial	<input type="checkbox"/> All Except Dioxin	<input type="checkbox"/> Partial	<input type="checkbox"/> Haloacetic Acids	<input type="checkbox"/> Qtrly Composite**	<input type="checkbox"/> Partial
<input type="checkbox"/> Nitrate	<input type="checkbox"/> Partial		<input type="checkbox"/> Chlorite		
<input type="checkbox"/> Nitrite	<input type="checkbox"/> Dioxin Only		<input type="checkbox"/> Bromate		
<input type="checkbox"/> Asbestos					

## LAB CERTIFICATION

I, Dale Dixon / Tulay Tannisever / Kara Peterson, Lab Director / Technical Director & QC Officer / QA Officer, do HEREBY CERTIFY  
(Print Name) (Print Title)

that all attached analytical data are correct and unless noted meet all requirements of the National Environmental Laboratory Accreditation Conference (NELAC).

Signature:  Date: 5/20/22

\* Failure to provide a valid and current Florida DOH lab certification number and a current Analyte Sheet for the attached analysis results will result in rejection of the report, possible enforcement against the public water system for failure to sample, and may result in notification of the DOH Bureau of Laboratory Services.

\*\* Please provide radiological sample dates & locations for each quarter.

**CONFIRMATION & NOTIFICATION IS REQUIRED WITHIN 24 HRS FOR NITRATE OR NITRITE MCL EXCEEDANCES**  
**NON-DETECTS ARE TO BE REPORTED AS THE MDL WITH A "U" QUALIFIER.** (Non-detects reported as "BDL" or with a "<" are not acceptable.)

## COMPLIANCE DETERMINATION (to be completed by DEP or DOH -- attach notes as necessary)

Sample Collection & Analysis Satisfactory:  Yes  No \_\_\_\_\_ Replacement Sample or Report Requested (circle or highlight group(s) above)

Person Notified: \_\_\_\_\_ Date Notified: \_\_\_\_\_ DEP/DOH Reviewing Official: \_\_\_\_\_

**Florida Department of Environmental Protection  
Safe Drinking Water Program Laboratory Reporting Format**

**LABORATORY CERTIFICATION INFORMATION** (to be completed by lab -- please type or print legibly)

Lab Name: Benchmark EnviroAnalytical, Inc. Florida DOH Certification #: E84167 Certification Expiration Date: 06/30/2022

ATTACH CURRENT DOH ANALYTE SHEET\*

Address: 1711 12th Street East, Palmetto, FL 34221 Phone #: 941-723-9986

Were any analyses subcontracted?  Yes  No If yes, please provide DOH certification number(s): \_\_\_\_\_

ATTACH DOH ANALYTE SHEET FOR EACH SUBCONTRACTED LAB\*

**ANALYSIS INFORMATION** (to be completed by lab) Date Sample(s) Received: 05/04/2022

PWS ID (From Page 1): 6142734 Sample Number (From Page 1): \_\_\_\_\_ Lab Assigned Report # or Job ID: 22050225-002


Group(s) Analyzed & Results attached for compliance with Chapter 62-550, F.A.C. (Check all that apply)

<u>Inorganics</u>	<u>Synthetic Organics</u>	<u>Volatile Organics</u>	<u>Disinfection Byproducts</u>	<u>Radionuclides</u>	<u>Secondaries</u>
<input type="checkbox"/> All Except Asbestos	<input type="checkbox"/> All 30	<input type="checkbox"/> All 21	<input type="checkbox"/> Trihalomethanes	<input type="checkbox"/> Single Sample	<input type="checkbox"/> All 14
<input checked="" type="checkbox"/> Partial	<input type="checkbox"/> All Except Dioxin	<input type="checkbox"/> Partial	<input type="checkbox"/> Haloacetic Acids	<input type="checkbox"/> Qtrly Composite**	<input type="checkbox"/> Partial
<input type="checkbox"/> Nitrate	<input type="checkbox"/> Partial		<input type="checkbox"/> Chlorite		
<input type="checkbox"/> Nitrite	<input type="checkbox"/> Dioxin Only		<input type="checkbox"/> Bromate		
<input type="checkbox"/> Asbestos					

**LAB CERTIFICATION**

I, Dale Dixon / Tulay Tannrisever / Kara Peterson, Lab Director / Technical Director & QC Officer / QA Officer, do HEREBY CERTIFY  
(Print Name) (Print Title)

that all attached analytical data are correct and unless noted meet all requirements of the National Environmental Laboratory Accreditation Conference (NELAC).

Signature:  Date: 5/20/22

\* Failure to provide a valid and current Florida DOH lab certification number and a current Analyte Sheet for the attached analysis results will result in rejection of the report, possible enforcement against the public water system for failure to sample, and may result in notification of the DOH Bureau of Laboratory Services.

\*\* Please provide radiological sample dates & locations for each quarter.

**CONFIRMATION & NOTIFICATION IS REQUIRED WITHIN 24 HRS FOR NITRATE OR NITRITE MCL EXCEEDANCES  
NON-DETECTS ARE TO BE REPORTED AS THE MDL WITH A "U" QUALIFIER. (Non-detects reported as "BDL" or with a "<" are not acceptable.)**

**COMPLIANCE DETERMINATION** (to be completed by DEP or DOH -- attach notes as necessary)

Sample Collection & Analysis Satisfactory:  Yes  No Replacement Sample or Report Requested (circle or highlight group(s) above)

Person Notified: \_\_\_\_\_ Date Notified: \_\_\_\_\_ DEP/DOH Reviewing Official: \_\_\_\_\_

# Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

**LABORATORY CERTIFICATION INFORMATION** (to be completed by lab – please type or print legibly)

Lab Name: Benchmark EnviroAnalytical, Inc Florida DOH Certification #: E84167 Certification Expiration Date: 06/30/2022

ATTACH CURRENT DOH ANALYTE SHEET\*

Address: 1711 12<sup>th</sup> Street East, Palmetto, FL 34221

Phone #: 941-723-9986

Were any analyses subcontracted?  Yes  No If yes, please provide DOH certification number(s): E83033

ATTACH DOH ANALYTE SHEET FOR EACH SUBCONTRACTED LAB\*

**ANALYSIS INFORMATION** (to be completed by lab)

Date Sample(s) Received: 05/04/2022

PWS ID (From Page 1): 6142734 Sample Number (From Page 1): \_\_\_\_\_ Lab Assigned Report # or Job ID: 22050225-003

Group(s) Analyzed & Results attached for compliance with Chapter 62-550, F.A.C. (Check all that apply):

- |  |  |   |  |   |   |  |
|--|--|---|--|---|---|--|
| <p><u>Inorganics</u></p> <input type="checkbox"/> All Except Asbestos<br><input type="checkbox"/> Partial<br><input type="checkbox"/> Nitrate<br><input type="checkbox"/> Nitrite<br><input type="checkbox"/> Asbestos | <p><u>Synthetic Organics</u></p> <input type="checkbox"/> All 30<br><input type="checkbox"/> All Except Dioxin<br><input type="checkbox"/> Partial<br><input type="checkbox"/> Dioxin Only | <p><u>Volatile Organics</u></p> <input type="checkbox"/> All 21<br><input type="checkbox"/> Partial | <p><u>Disinfection Byproducts</u></p> <input type="checkbox"/> Trihalomethanes<br><input type="checkbox"/> Haloacetic Acids<br><input type="checkbox"/> Chlorite<br><input type="checkbox"/> Bromate | <p><u>Radionuclides</u></p> <input checked="" type="checkbox"/> Single Sample<br><input type="checkbox"/> Qtrly Composite** | <p><u>Secondaries</u></p> <input type="checkbox"/> All 14<br><input type="checkbox"/> Partial | <p><u>Other</u></p> <input type="checkbox"/> |
|--|--|---|--|---|---|--|

## LAB CERTIFICATION

I, Dale D. Dixon / Tülay Tarrisever / Kara Peterson, Lab Director / Technical Director & QC Officer / QA Officer, do HEREBY CERTIFY  
 (Print Name) (Print Title)

that all attached analytical data are correct and unless noted meet all requirements of the National Environmental Laboratory Accreditation Conference (NELAC).

Signature:  Date: 5/20/22

\* Failure to provide a valid and current Florida DOH lab certification number and a current Analyte Sheet for the attached analysis results will result in rejection of the report, possible enforcement against the public water system for failure to sample, and may result in notification of the DOH Bureau of Laboratory Services.  
 \*\* Please provide radiological sample dates & locations for each quarter.

**CONFIRMATION & NOTIFICATION IS REQUIRED WITHIN 24 HRS FOR NITRATE OR NITRITE MCL EXCEEDANCES  
 NON-DETECTS ARE TO BE REPORTED AS THE MDL WITH A "U" QUALIFIER.** (Non-detects reported as "BDL" or with a "<" are not acceptable.)

**COMPLIANCE DETERMINATION** (to be completed by DEP or DOH -- attach notes as necessary)

Sample Collection & Analysis Satisfactory:  Yes  No \_\_\_\_\_ Replacement Sample or Report Requested (circle or highlight group(s) above)

Person Notified: \_\_\_\_\_ Date Notified: \_\_\_\_\_ DEP/DOH Reviewing Official: \_\_\_\_\_

# Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

INORGANIC CONTAMINANTS  
62-550.310(1)

Report Number / Job ID: 22050225-001 \_\_\_\_\_

PWS ID (From Page 1): 6142734 \_\_\_\_\_

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Analysis Date	Analysis Time	DOH Lab Certification #
1040	Nitrate (as N)	10	mg/L							
1041	Nitrite (as N)	1	mg/L							
1005	Arsenic	0.010	mg/L	0.001	I	SM3113B	0.00069	05/09/22	11:48	E84167
1010	Barium	2	mg/L							
1015	Cadmium	0.005	mg/L							
1020	Chromium	0.1	mg/L							
1024	Cyanide	0.2	mg/L							
1025	Fluoride	4.0	mg/L							
1030	Lead	0.015	mg/L							
1035	Mercury	0.002	mg/L							
1036	Nickel	0.1	mg/L							
1045	Selenium	0.05	mg/L							
1052	Sodium	160	mg/L	48.7		200.7	0.034	05/05/22	16:53	E84167
1074	Antimony	0.006	mg/L							
1075	Beryllium	0.004	mg/L							
1085	Thallium	0.002	mg/L							
1094	Asbestos	7 MFL	MFL							E

# Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

INORGANIC CONTAMINANTS  
62-550.310(1)

Report Number / Job ID: 22050225-002\_\_\_\_\_

PWS ID (From Page 1): 6142734\_\_\_\_\_

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Analysis Date	Analysis Time	DOH Lab Certification #
1040	Nitrate (as N)	10	mg/L							
1041	Nitrite (as N)	1	mg/L							
1005	Arsenic	0.010	mg/L	0.003		SM3113B	0.00069	05/09/22	11:54	E84167
1010	Barium	2	mg/L							
1015	Cadmium	0.005	mg/L							
1020	Chromium	0.1	mg/L							
1024	Cyanide	0.2	mg/L							
1025	Fluoride	4.0	mg/L							
1030	Lead	0.015	mg/L							
1035	Mercury	0.002	mg/L							
1036	Nickel	0.1	mg/L							
1045	Selenium	0.05	mg/L							
1052	Sodium	160	mg/L	26.5		200.7	0.034	05/05/22	16:57	E84167
1074	Antimony	0.006	mg/L							
1075	Beryllium	0.004	mg/L							
1085	Thallium	0.002	mg/L							
1094	Asbestos	7 MFL	MFL							E

\*Results must be reported with appropriate qualifiers in accordance with Florida Administrative Code Rule 62-160, Table 1. Results qualified with A, F, H, N, O, T, Z, ?, \*, are unacceptable for compliance with 62-550. Results qualified with a J, Q, R, or Y must be accompanied by written justification and will be evaluated on a case by case basis. To avoid a monitoring violation, unacceptable results must be replaced with acceptable results from samples collected during the same monitoring period.

# Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

RADIONUCLIDES  
62-550.310(6)

Report Number / Job ID: 22050225-003\_\_\_\_\_

PWS ID (From Page 1): 6142734\_\_\_\_\_

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	RDL	Analysis Error	Analysis Date	Analysis Time	DOH Lab Certification #
4000	Gross Alpha (Excl Uranium)	15	pCi/L	**				3				E
4002	Gross Alpha (Incl Uranium)	***	pCi/L	1.8	U	900.0	1.8	3	1.5	05/13/22	06:12	E83033
4006	Combined Uranium**** (U-234, U-235, & U-238)	20	pCi/L					.67				E
		30	µg/L					1				E
4020	Radium-226	5	pCi/L	0.7		903.1	0.1	1	0.3	05/18/22	12:23	E83033
4030	Radium-228			0.6		Ra-05	0.6	1	0.5	05/17/22	11:32	E83033

\*\* If the result exceeds 5 pCi/L, a measurement for radium-226 is required. Uranium is reported separately under Contam ID 4006.

\*\*\* If the results exceed 5 pCi/L, a measurement for radium-226 is required. If the results exceed 15 pCi/L, a measurement for Combined Uranium must be reported separately. The DEP/DOH will subtract the U value from the Gross Alpha (ID 4002) to determine compliance with MCL for Gross Alpha (Excl. U) of 15pCi/L. If the result for ID 4002 Gross Alpha (Including Uranium) does not exceed 15pCi/L, Combined Uranium need not be measured nor reported.

\*\*\*\* If using Uranium testing methods ASTM D5174 or EPA 200.8 only, then Analysis Error need not be reported.

**DATA QUALIFIERS THAT MAY APPLY:**

B = Results based upon colony counts outside the ideal range.

G1 = Accuracy standard does not meet method control limits but does meet lab control limits that are in agreement with USEPA generated data. USEPA letter available upon request.

G2 = Accuracy standard exceeds acceptable control limits. Duplicate and spike values are within control limits. Reported data are usable.

G3 = Precision measurement exceeded acceptable control limits. Standard and spike values are within control limits. Reported data are usable.

G4 = Spike recovery exceeds acceptable control limits. Standard and duplicate values are within control limits. Reported data are usable.

I = Reported value is between the laboratory MDL and the PQL.

J3 = Estimated value. Quality control criteria for precision and accuracy not met.

J4 = Estimated value. Sample matrix interference suspected.

J6 = Estimated value. SM5210B test replicates show more than 30% difference between high and low values, indicating potential presence of toxicity within the sample.

K = Off-scale low. Value is known to be < the value reported.

L = Off scale high; reported concentration exceeds the highest standard.

ND = Not Detected at or above adjusted reporting limit.

Q = Sample held beyond accepted hold time.

U = Analyte analyzed but not detected at the value indicated.

V = Analyte detected in sample and method blank. Results for this analyte in associated samples may be biased high. Standard, Duplicate and Spike values are within control limits. Reported data are usable.

X = Value exceed MCL.

Y = Analysis performed on an improperly preserved sample. Data may be inaccurate

Z = Too many colonies were present (TNTC). The numeric value represents the filtration volume



Laboratory Scope of Accreditation

Attachment to Certificate #: E84167-54, expiration date June 30, 2022. This listing of accredited analytes should be used only when associated with a valid certificate.

State Laboratory ID: E84167      EPA Lab Code: FL00289      (941) 723-9986

E84167  
Benchmark EnviroAnalytical, Inc.  
1711 12th Street East  
Palmetto, FL 34221

Matrix: Drinking Water

Analyte	Method/Tech	Category	Certification Type	Effective Date
1,1,1-Trichloroethane	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
1,1,2-Trichloroethane	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
1,1-Dichloroethylene	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
1,2,4-Trichlorobenzene	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
1,2-Dibromo-3-chloropropane (DBCP)	EPA 504.1	Synthetic Organic Contaminants	NELAP	4/20/2009
1,2-Dibromoethane (EDB, Ethylene dibromide)	EPA 504.1	Synthetic Organic Contaminants	NELAP	4/20/2009
1,2-Dichlorobenzene	EPA 524.2	Other Regulated Contaminants	NELAP	12/29/2015
1,2-Dichloroethane	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
1,2-Dichloropropane	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
1,4-Dichlorobenzene	EPA 524.2	Other Regulated Contaminants	NELAP	12/29/2015
Alkalinity as CaCO3	SM 2320 B	Primary Inorganic Contaminants	NELAP	5/25/2004
Aluminum	EPA 200.7	Secondary Inorganic Contaminants	NELAP	5/25/2004
Ammonia as N	EPA 350.1	Primary Inorganic Contaminants	NELAP	3/7/2011
Antimony	SM 3113 B	Primary Inorganic Contaminants	NELAP	1/3/2002
Arsenic	SM 3113 B	Primary Inorganic Contaminants	NELAP	1/3/2002
Barium	EPA 200.7	Primary Inorganic Contaminants	NELAP	5/25/2004
Benzene	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
Beryllium	EPA 200.7	Other Regulated Contaminants	NELAP	5/25/2004
Boron	EPA 200.7	Secondary Inorganic Contaminants	NELAP	3/7/2011
Bromate	EPA 300.1	Primary Inorganic Contaminants	NELAP	11/21/2008
Bromide	EPA 300.0	Primary Inorganic Contaminants	NELAP	5/25/2004
Bromoacetic acid	EPA 552.2	Group I Unregulated Contaminants	NELAP	4/20/2009
Bromodichloromethane	EPA 524.2	Group II Unregulated Contaminants	NELAP	9/28/2005
Bromoform	EPA 524.2	Group II Unregulated Contaminants	NELAP	9/28/2005
Cadmium	EPA 200.7	Primary Inorganic Contaminants	NELAP	5/25/2004
Calcium	EPA 200.7	Primary Inorganic Contaminants	NELAP	5/25/2004
Carbon tetrachloride	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
Chlorate	EPA 300.1	Secondary Inorganic Contaminants	NELAP	11/21/2008
Chloride	EPA 300.1	Secondary Inorganic Contaminants	NELAP	11/21/2008
Chlorine	SM 4500-Cl G	Primary Inorganic Contaminants	NELAP	3/7/2011
Chlorite	EPA 300.1	Primary Inorganic Contaminants	NELAP	11/21/2008
Chloroacetic acid	EPA 552.2	Group I Unregulated Contaminants	NELAP	4/20/2009
Chlorobenzene	EPA 524.2	Other Regulated Contaminants	NELAP	12/29/2015
Chloroform	EPA 524.2	Group II Unregulated Contaminants	NELAP	9/28/2005
Chromium	EPA 200.7	Primary Inorganic Contaminants	NELAP	5/25/2004
cis-1,2-Dichloroethylene	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005

Clients and Customers are urged to verify the laboratory's current certification status with the Environmental Laboratory Certification Program.

Issue Date: 2/3/2022

Expiration Date: 6/30/2022



*Laboratory Scope of Accreditation*

Attachment to Certificate #: E84167-54, expiration date June 30, 2022. This listing of accredited analytes should be used only when associated with a valid certificate.

State Laboratory ID: E84167      EPA Lab Code: FL00289      (941) 723-9986

E84167  
Benchmark EnviroAnalytical, Inc.  
1711 12th Street East  
Palmetto, FL 34221

Matrix: Drinking Water

Analyte	Method/Tech	Category	Certification Type	Effective Date
Residue-filterable (TDS)	SM 2540 C	Secondary Inorganic Contaminants	NELAP	7/3/2007
Selenium	SM 3113 B	Primary Inorganic Contaminants	NELAP	2/2/2022
Silica as SiO2	EPA 200.7	Primary Inorganic Contaminants	NELAP	5/25/2004
Silver	EPA 200.7	Secondary Inorganic Contaminants	NELAP	5/25/2004
Sodium	EPA 200.7	Primary Inorganic Contaminants	NELAP	5/25/2004
Styrene	EPA 524.2	Other Regulated Contaminants	NELAP	12/29/2015
Sulfate	EPA 300.0	Primary Inorganic Contaminants	NELAP	5/25/2004
Sulfide	SM 4500-S D/UV-VIS	Primary Inorganic Contaminants	NELAP	3/7/2011
Surfactants - MBAS	SM 5540 C	Secondary Inorganic Contaminants	NELAP	1/3/2002
Tetrachloroethylene (Perchloroethylene)	EPA 524.2	Other Regulated Contaminants	NELAP	12/29/2015
Thallium	EPA 200.9	Primary Inorganic Contaminants	NELAP	1/3/2002
Toluene	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
Total coliforms	SM 9223 B	Microbiology	NELAP	1/3/2002
Total coliforms	SM 9223 B /QUANTIT-TRAY	Microbiology	NELAP	3/7/2011
Total cyanide	EPA 335.4	Primary Inorganic Contaminants	NELAP	1/7/2021
Total haloacetic acids (HAA5)	EPA 552.2	Synthetic Organic Contaminants	NELAP	4/20/2009
Total nitrate-nitrite	EPA 300.0	Primary Inorganic Contaminants	NELAP	5/25/2004
Total nitrate-nitrite	EPA 353.2	Primary Inorganic Contaminants	NELAP	1/3/2002
Total organic carbon	SM 5310 B	Primary Inorganic Contaminants	NELAP	5/25/2004
Total trihalomethanes	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
trans-1,2-Dichloroethylene	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
Trichloroacetic acid	EPA 552.2	Group 1 Unregulated Contaminants	NELAP	10/14/2010
Trichloroethene (Trichloroethylene)	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
Turbidity	EPA 180.1	Secondary Inorganic Contaminants	NELAP	3/7/2011
UV 254	SM 5910 B	Primary Inorganic Contaminants	NELAP	11/16/2016
Vanadium	EPA 200.7	Secondary Inorganic Contaminants	NELAP	3/7/2011
Vinyl chloride	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
Xylene (total)	EPA 524.2	Other Regulated Contaminants	NELAP	12/29/2015
Zinc	EPA 200.7	Secondary Inorganic Contaminants	NELAP	5/25/2004

Clients and Customers are urged to verify the laboratory's current certification status with the Environmental Laboratory Certification Program.

Issue Date: 2/3/2022

Expiration Date: 6/30/2022



*Laboratory Scope of Accreditation*

Attachment to Certificate #: E83033-17, expiration date June 30, 2022. This listing of accredited analytes should be used only when associated with a valid certificate.

State Laboratory ID: E83033      EPA Lab Code: FL01113      (407) 382-7733

E83033  
Florida Radiochemistry Services, Inc.  
5456 Hoffner Rd, Suite 201  
Orlando, FL 32812

Matrix: Drinking Water

Analyte	Method/Tech	Category	Certification Type	Effective Date
Gross Alpha	EPA 900.0	Radiochemistry	NELAP	6/28/2001
Gross Beta	EPA 900.0	Radiochemistry	NELAP	6/28/2001
Radium-226	EPA 903.0	Radiochemistry	NELAP	12/15/2003
Radium-226	EPA 903.1	Radiochemistry	NELAP	6/28/2001
Radium-228	EPA Ra-05	Radiochemistry	NELAP	6/28/2001
Uranium (activity)	EPA 908.0	Radiochemistry	NELAP	6/28/2001


Clients and Customers are urged to verify the laboratory's current certification status with the Environmental Laboratory Certification Program.

Issue Date: 7/1/2021

Expiration Date: 6/30/2022

# BENCHMARK

*EnviroAnalytical Inc.*



FDOH Certification #E84167

Peace River/Manasota R W S  
8998 S W County Road 769  
Arcadia, FL 34269

## ANALYTICAL TEST REPORT

THESE RESULTS MEET NELAC STANDARDS

### INORGANIC ANALYSIS

62-550.310 (1)

REPORT NUMBER: 22060202 - 001


SYSTEM NAME: Facility Lab Tap (Finished Wat

SYSTEM ID: 6142734

PARAMETER ID	PARAMETER NAME	MCL	UNITS	ANALYSIS RESULT	QUALIFIER	ANALYTICAL METHOD	MDL	ANALYSIS DATE	ANALYSIS TIME	LAB ID
1005	ARSENIC	0.010	MG/L	0.00069	U	SM3113B	0.00069	06/16/2022	11:35	E84167
1052	SODIUM	160	MG/L	50.8		200.7	0.034	06/14/2022	13:35	E84167

# BENCHMARK

*EnviroAnalytical Inc.*



FDOH Certification #E84167

Peace River/Manasota R W S  
8998 S W County Road 769  
Arcadia, FL 34269

## ANALYTICAL TEST REPORT

THESE RESULTS MEET NELAC STANDARDS

### INORGANIC ANALYSIS


62-550.310 (1)

REPORT NUMBER: 22060202 - 002  
SYSTEM NAME: Facility Influent (Raw)  
SYSTEM ID: 6142734

PARAMETER ID	PARAMETER NAME	MCL	UNITS	ANALYSIS RESULT	QUALIFIER	ANALYTICAL METHOD	MDL	ANALYSIS DATE	ANALYSIS TIME	LAB ID
1005	ARSENIC	0.010	MG/L	0.002	I	SM3113B	0.00069	06/16/2022	11:41	E84167
1052	SODIUM	160	MG/L	27.6		200.7	0.034	06/14/2022	13:39	E84167

# BENCHMARK

*EnviroAnalytical Inc.*



FDOH Certification #E84167

Peace River/Manasota R W S  
8998 S W County Road 769  
Arcadia, FL 34269

## ANALYTICAL TEST REPORT

THESE RESULTS MEET NELAC STANDARDS

### RADIONUCLIDES

62-550.310 (6)

REPORT NUMBER: 22060202 - 003

SYSTEM NAME: Entry Point (Lab Tap)

SYSTEM ID: 6142734

PARAMETER ID	PARAMETER NAME	MCL	UNITS	ANALYSIS RESULT	QUALIFIER	ANALYTICAL METHOD	MDL	ANALYSIS DATE	ANALYSIS TIME	LAB ID
4002	GROSS ALPHA (INCL URANIUM)	15	PCI/L	1.3+/-1.0	U	900.0	1.3	06/14/2022	10:11	E83033
4020	RADIUM-226	5	PCI/L	0.5+/-0.2		903.1	0.2	06/17/2022	09:51	E83033
4030	RADIUM-228	5	PCI/L	0.9+/-0.6	U	Ra-05	0.9	06/16/2022	12:39	E83033

#### DATA QUALIFIERS THAT MAY APPLY:

I = Reported value is between the laboratory MDL and the PQL.  
J = Estimated value.  
J3 = Estimated value. Quality control criteria for precision or accuracy not met.  
J4 = Estimated value. Sample matrix interference suspected.  
Q = Sample held beyond accepted hold time.  
U = Analyte analyzed but not detected at the value indicated.  
V = Analyte detected in sample and method blank. Results for this analyte in associated samples may be biased high. Standard, Duplicate, and Spike values are within control limits. Reported data are usable.  
Y = Analysis performed on an improperly preserved sample. Data may be inaccurate.

#### NOTES:

PQL = 4 x MDL.  
ND = Not Detected at or above adjusted reporting limit.  
MBAS calculated as LAS; molecular weight = 340.

#### COMMENTS:

For questions or comments regarding these results, please contact us at (941)723-9986.

*Results relate only to the samples.*

**Benchmark EnviroAnalytical, Inc. E84167**

1711 Twelfth Street East  
 Palmetto, FL. 34221  
 (941) 723-9986  
 (941) 723-6061 fax

[www.Benchmarkea.com](http://www.Benchmarkea.com)

Sample Temperature checked upon receipt with Temperature Gun ID #258

**Client: Peace River/ Manasota RWS**

8998 SW County Road 769  
 Arcadia, FL 34269  
 (863) 993-4565  
 (863) 993-4568 (Fax)

COC # 62

Chain of Custody Form: Peace River Monthly Finish, Raw  
 Project Name: Peace River Facility Monthly Quality Control  
 Method of discharge: DW Sample Type: Grab PWS #: 614-2734

Laboratory Submission #:	22060202
--------------------------	----------

Station ID	Parameters, Preservative <sup>4</sup> , Container Type <sup>3</sup> / Total Number of container = 4		Laboratory Sample #
	As (SM3113B) Na (200.7)	Gross Alpha Total Uranium* Radium 226 & 228	
	1.1 mL 1:4 HNO <sub>3</sub> pH<2 <input checked="" type="checkbox"/> Acid Lot # 22-06	1.1 mL 1:4 HNO <sub>3</sub> pH<2 <input checked="" type="checkbox"/> Acid Lot # 22-06	
	1 x 1/2 Pint Plastic	2 x 2 Quart Plastic	
Facility Lab Tap (Finish Water)	Date/Time: 6/3/22 0905		1
Facility Influent (Raw)	Date/Time: 6/3/22 0910		2
Entry Point (Lab Tap)		Date/Time: 6/3/22 0915	3

\* Run Total Uranium only if the Gross Alpha is ≥15 pCi/L.

**Notes:**

- "Sample Type" is used to indicate whether the sample was a grab (G) or whether it was a composite (C).
- "Sample Matrix" is used to indicate whether the sample is being discharged to drinking water (DW), groundwater (GW), surface water (SW), fresh surface water (FSW), saline surface water (SSW), soil, sediment (SDMNT), or sludge (SLDG).
- "Container Type" is used to indicate whether the container is plastic (P) or glass (G).
- Sample must be refrigerated or stored in wet ice after collection. The temperature during storage should be less than or equal to 6°C (42.8°F).
- Under "Preservative," list any preservatives that were added to the sample container. Lot Number of preservative used is specific to the bottles included in the kit. NaThio, H<sub>2</sub>SO<sub>4</sub>, and HNO<sub>3</sub> do not have expiration dates per the manufacturer. Micro bottles are pre-preserved at manufacturing stage. 40mL vials are pre-preserved at manufacturing stage.

**Instructions:**

- Each bottle has a label identifying sample ID, premeasured preservative contained in the bottle, sample type, client ID, and parameters for analysis.
- The following information should be added to each bottle label after collection with permanent black ink: date and time of collection, sampler's name or initials, and any field number or ID.
- All bottles not containing preservative may be rinsed with appropriate sample prior to collection.
- The client is responsible for documentation of the sampling event. Please note special sampling events on the sample custody form.
- Sample kit has been created by BEA using new, certified bottles unless otherwise noted.

Laboratory Sample Acceptability:  
 pH < 8 BEA Temperature: 0.8°C

1	Collector & Affiliation: (Print & Sign) John Ramsey PR/MRWS	Date: 6/3/22	Time: 1054	Received By & Affiliation: (Print & Sign) Melinda Merchant - BEAS	Date: 6/3/22	Time: 1054
2	Relinquished By & Affiliation: (Print & Sign) Melinda Merchant - BEAS	Date: 6/3/22	Time: 11:40	Received By & Affiliation: (Print & Sign) Ben Charsank - MR HALL	Date: 6/3/22	Time: 11:40
3	Relinquished By & Affiliation: (Print & Sign) Ben Charsank - MR HALL	Date: 6/3/22	Time: 1445	Received By & Affiliation: (Print & Sign) Nathan Hadsell BEA	Date: 6-3-22	Time: 1445
4	Relinquished By & Affiliation: (Print & Sign)	Date:	Time:	Received By & Affiliation: (Print & Sign)	Date:	Time:

## INTERLABORATORY SAMPLE TRANSMITTAL FORM

Benchmark EnviroAnalytical, Inc.  
 1711 12<sup>th</sup> Street East  
 Palmetto, FL 34221  
 (941) 723-9986  
 (941) 723-6061 fax  
 WWW.Benchmarkea.com  
 Office QC Check: \_\_\_\_\_  
 Bottle Check: \_\_\_\_\_

Date:	06/06/22		
# of Samples:	1	Total # of Bottles:	2
Method of Shipment:	Hand Delivery		
Subcontract Laboratory:	Florida Radiochemistry 5456 Hoffner Ave. #201 Orlando, Fl. 32812 Phone: 407-382-7733 Fax: 407-382-7744		
Page	1	of	1

### 10 BUSINESS DAY T.A.T. PLEASE



Laboratory Submission #	Collection		Sample Matrix*	Collection Method**	Preservative	Container			Parameters	Conductivity** (µmhos)
	Date	Time				Qty	Capacity	Type***		
22060202-003	06/03/22	0915	DW	Grab	1:4 HNO <sub>3</sub>	2	2 Qt.	P	GROSS ALPHA, RADIUM 226/228 TOTAL URANIUM**	

\*\* Run Total Uranium only if Gross Alpha is greater than 15 pCi/L.

\* Sample Matrix abbreviations: Groundwater (GW), Surface Water (SW), Saline Surface Water (SSW), Fresh Surface Water(FSW), Drinking Water (DW), Sludge (Sldg), Solid (Sol), Soil (Soil), Domestic Effluent (Dom Eff), Industrial Effluent (Ind Eff).

\*\* Sample Method abbreviations: Grab (G), Composite (C), 24 Hour Composite (24HR Comp.).

\*\*\* Container Type abbreviations: Plastic (P), Glass (G).

Relinquished By: (Benchmark)	Sign Name:		Date:		Received By:		Date:	6-7-22
	Print Name:	Kara McGowan	Time:			MIKE NAJMAN	Time:	10:35
Relinquished By:	Sign Name:		Date:		Received By:		Date:	
	Print Name:		Time:				Time:	

**Florida Department of Environmental Protection  
Safe Drinking Water Program Laboratory Reporting Format**

**PUBLIC WATER SYSTEM INFORMATION** (to be completed by sampler -- please type or print legibly)

System Name: Peace River Manasota Regional Water Supply Auth. PWS I.D. #: 6142734  
 System Type (check one):  Community  Nontransient Noncommunity  Transient Noncommunity  
 Address: 8998 S.W. County Rd. 769  
 City: Arcadia, Florida ZIP Code: 34269  
 Phone #: 863 993-4565 Fax #: 863 993-4568 E-Mail Address: randerson@regionalwater.org

**SAMPLE INFORMATION** (to be completed by sampler)

Sample Number: 22060202-001 Sample Date: 6/3/22 Sample Time: 0905  AM  PM (Circle One)  
 Sample Location (be specific): Facility Lab Tap (Finish Water) Location Code: \_\_\_\_\_  
 Disinfectant Residual (Required when reporting results for trihalomethanes and haloacetic acids): 4.2 mg/L Field pH: 8.43

**Sample Type (Check Only One)**

- Distribution
- Entry Point (to Distribution)
- Plant Tap (not for compliance with 62-550)
- Raw (at well or intake)
- Max Residence Time
- Ave Residence Time
- Near First Customer

**Reason(s) for Sample (Check all that apply)**

- Routine Compliance with 62-550
- Confirmation of MCL Exceedance
- Composite of Multiple Sites\*\*
- Other: \_\_\_\_\_
- Replacement (of Invalidated Sample)
- Special (not for compliance with 62-550)
- Clearance (permitting)

Sampling Procedure Used or Other Comments:

As, Na

\*See 62-550.500(6) for requirements and restrictions.  
 And 62-550.512(3) for nitrate or nitrite exceedances

\*\*See 62-550.550(4) for requirements and  
 attach a results page for each site

**SAMPLER CERTIFICATION**

I, John Ramsey (Print Name), Ops Specialist (Print Title), do HEREBY CERTIFY  
 that the above public water system and sample collection information is complete and correct.

Signature: John Ramsey Date: 6/3/22  
 Certified Operator #: 4668 Phone #: 863 993-4565 Sampler's Fax #: 863 494-2622  
 Sampler's E-mail: jramsey@regionalwater.org

**Florida Department of Environmental Protection  
Safe Drinking Water Program Laboratory Reporting Format**

**PUBLIC WATER SYSTEM INFORMATION** (to be completed by sampler – please type or print legibly)

System Name: Peace River Manasota Regional Water Supply Auth. PWS I.D. #: 6142734  
 System Type (check one):  Community  Nontransient Noncommunity  Transient Noncommunity  
 Address: 8998 S.W. County Rd. 769  
 City: Arcadia, Florida ZIP Code: 34269  
 Phone #: 863 993-4565 Fax #: 863 993-4568 E-Mail Address: randerson@regionalwater.org

**SAMPLE INFORMATION** (to be completed by sampler)

Sample Number: 22060203-002 Sample Date: 6/3/22 Sample Time: 0910  AM  PM (Circle One)  
 Sample Location (be specific): Facility Influent (Raw) Location Code: \_\_\_\_\_  
 Disinfectant Residual (Required when reporting results for trihalomethanes and haloacetic acids): 0 mg/L Field pH: 7.98

**Sample Type (Check Only One)**

- Distribution
- Entry Point (to Distribution)
- Plant Tap (not for compliance with 62-550)
- Raw (at well or intake)
- Max Residence Time
- Ave Residence Time
- Near First Customer

**Reason(s) for Sample (Check all that apply)**

- Routine Compliance with 62-550
- Confirmation of MCL Exceedance\*
- Composite of Multiple Sites\*\*
- Other: \_\_\_\_\_
- Replacement (of Invalidated Sample)
- Special (not for compliance with 62-550)
- Clearance (permitting)

Sampling Procedure Used or Other Comments:

As, Na

\*See 62-550.500(6) for requirements and restrictions.  
And 62-550.512(3) for nitrate or nitrite exceedances.

\*\*See 62-550.550(4) for requirements and attach a results page for each site.

**SAMPLER CERTIFICATION**

I, John Ramsey (Print Name), Ops Specialist (Print Title), do HEREBY CERTIFY that the above public water system and sample collection information is complete and correct.

Signature: John Ramsey Date: 6/3/22  
 Certified Operator #: 4668 Phone #: 863 993-4565 Sampler's Fax #: 863 494-2622  
 Sampler's E-mail: jramsey@regionalwater.org

**Florida Department of Environmental Protection  
Safe Drinking Water Program Laboratory Reporting Format**

**PUBLIC WATER SYSTEM INFORMATION** (to be completed by sampler - please type or print legibly)

System Name: Peace River Manasota Regional Water Supply Auth. PWS I.D. #: 6142734  
 System Type (check one):  Community  Nontransient Noncommunity  Transient Noncommunity  
 Address: 8998 S.W. County Rd. 769  
 City: Arcadia, Florida ZIP Code: 34269  
 Phone #: 863 993-4565 Fax #: 863 993-4568 E-Mail Address: randerson@regionalwater.org

**SAMPLE INFORMATION** (to be completed by sampler)

Sample Number: 22060202-003 Sample Date: 6/3/22 Sample Time: 0915  AM  PM (Circle One)  
 Sample Location (be specific): Entry Point (Lab Tap) Location Code: \_\_\_\_\_  
 Disinfectant Residual (Required when reporting results for trihalomethanes and haloacetic acids): 4.2 mg/L Field pH: 8.43

**Sample Type (Check Only One)**

- Distribution
- Entry Point (to Distribution)
- Plant Tap (not for compliance with 62-550)
- Raw (at well or intake)
- Max Residence Time
- Ave Residence Time
- Near First Customer

**Reason(s) for Sample (Check all that apply)**

- Routine Compliance with 62-550
- Confirmation of MCL Exceedance\*
- Composite of Multiple Sites\*\*
- Other: \_\_\_\_\_
- Replacement (of invalidated Sample)
- Special (not for compliance with 62-550)
- Clearance (permitting)

Sampling Procedure Used or Other Comments:

Gross Alpha Radium 226+228

\*See 62-550.500(6) for requirements and restrictions.  
And 62-550.512(3) for nitrate or nitrite exceedances.

\*\*See 62-550.550(4) for requirements and attach a results page for each site.

**SAMPLER CERTIFICATION**

I, John Ramsey (Print Name), Ops Specialist (Print Title), do HEREBY CERTIFY

that the above public water system and sample collection information is complete and correct.

Signature: John Ramsey Date: 6/3/22  
 Certified Operator #: 4668 Phone #: 863 993-4565  
 Sampler's E-mail: jramsey@regionalwater.org Sampler's Fax #: 863 494-2622

# Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

## LABORATORY CERTIFICATION INFORMATION (to be completed by lab – please type or print legibly)

Lab Name: Benchmark EnviroAnalytical, Inc. Florida DOH Certification #: E84167 Certification Expiration Date: 06/30/2022

**ATTACH CURRENT DOH ANALYTE SHEET\***

Address: 1711 12th Street East, Palmetto, FL 34221 Phone #: 941-723-9986

Were any analyses subcontracted?  Yes  No If yes, please provide DOH certification number(s): \_\_\_\_\_

**ATTACH DOH ANALYTE SHEET FOR EACH SUBCONTRACTED LAB\***

**ANALYSIS INFORMATION** (to be completed by lab) Date Sample(s) Received: 06/03/22

PWS ID (From Page 1): 6142734 Sample Number (From Page 1): \_\_\_\_\_ Lab Assigned Report # or Job ID: 22060202-001

Group(s) Analyzed & Results attached for compliance with Chapter 62-550, F.A.C. (Check all that apply):

- |  |  |                                  |   |  |                                  |
|--|--|----------------------------------|---|--|----------------------------------|
| <u>Inorganics</u>                            | <u>Synthetic Organics</u>                  | <u>Volatile Organics</u>         | <u>Disinfection Byproducts</u>            | <u>Radionuclides</u>                       | <u>Secondaries</u>               |
| <input type="checkbox"/> All Except Asbestos | <input type="checkbox"/> All 30            | <input type="checkbox"/> All 21  | <input type="checkbox"/> Trihalomethanes  | <input type="checkbox"/> Single Sample     | <input type="checkbox"/> All 14  |
| <input checked="" type="checkbox"/> Partial  | <input type="checkbox"/> All Except Dioxin | <input type="checkbox"/> Partial | <input type="checkbox"/> Haloacetic Acids | <input type="checkbox"/> Qtrly Composite** | <input type="checkbox"/> Partial |
| <input type="checkbox"/> Nitrate             | <input type="checkbox"/> Partial           |                                  | <input type="checkbox"/> Chlorite         |  |                                  |
| <input type="checkbox"/> Nitrite             | <input type="checkbox"/> Dioxin Only       |                                  | <input type="checkbox"/> Bromate          |  |                                  |
| <input type="checkbox"/> Asbestos            |  |                                  |   |  |                                  |

## LAB CERTIFICATION

I, Dale Dixon / Tulay Tanrisever / Kara Peterson, Lab Director / Technical Director & QC Officer / QA Officer, do HEREBY CERTIFY  
(Print Name) (Print Title)

that all attached analytical data are correct and unless noted meet all requirements of the National Environmental Laboratory Accreditation Conference (NELAC).

Signature:  Date: 6/21/2022

\* Failure to provide a valid and current Florida DOH lab certification number and a current Analyte Sheet for the attached analysis results will result in rejection of the report, possible enforcement against the public water system for failure to sample, and may result in notification of the DOH Bureau of Laboratory Services.  
\*\* Please provide radiological sample dates & locations for each quarter.

**CONFIRMATION & NOTIFICATION IS REQUIRED WITHIN 24 HRS FOR NITRATE OR NITRITE MCL EXCEEDANCES  
NON-DETECTS ARE TO BE REPORTED AS THE MDL WITH A "U" QUALIFIER. (Non-detects reported as "BDL" or with a "<" are not acceptable.)**

## COMPLIANCE DETERMINATION (to be completed by DEP or DOH -- attach notes as necessary)

Sample Collection & Analysis Satisfactory:  Yes  No \_\_\_\_\_ Replacement Sample or Report Requested (circle or highlight group(s) above)

Person Notified: \_\_\_\_\_ Date Notified: \_\_\_\_\_ DEP/DOH Reviewing Official: \_\_\_\_\_

# Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

**LABORATORY CERTIFICATION INFORMATION** (to be completed by lab – please type or print legibly)

Lab Name: Benchmark EnviroAnalytical, Inc. Florida DOH Certification #: E84167 Certification Expiration Date: 06/30/2022

**ATTACH CURRENT DOH ANALYTE SHEET\***

Address: 1711 12th Street East, Palmetto, FL 34221 Phone #: 941-723-9986

Were any analyses subcontracted?  Yes  No If yes, please provide DOH certification number(s): \_\_\_\_\_

**ATTACH DOH ANALYTE SHEET FOR EACH SUBCONTRACTED LAB\***

**ANALYSIS INFORMATION** (to be completed by lab) Date Sample(s) Received: 06/03/22

PWS ID (From Page 1): 6142734 Sample Number (From Page 1): \_\_\_\_\_ Lab Assigned Report # or Job ID: 22060202-002


Group(s) Analyzed & Results attached for compliance with Chapter 62-550, F.A.C. (Check all that apply):

- |   |  |   |  |  |   |
|---|--|---|--|--|---|
| <p><u>Inorganics</u></p> <input type="checkbox"/> All Except Asbestos<br><input checked="" type="checkbox"/> Partial<br><input type="checkbox"/> Nitrate<br><input type="checkbox"/> Nitrite<br><input type="checkbox"/> Asbestos | <p><u>Synthetic Organics</u></p> <input type="checkbox"/> All 30<br><input type="checkbox"/> All Except Dioxin<br><input type="checkbox"/> Partial<br><input type="checkbox"/> Dioxin Only | <p><u>Volatile Organics</u></p> <input type="checkbox"/> All 21<br><input type="checkbox"/> Partial | <p><u>Disinfection Byproducts</u></p> <input type="checkbox"/> Trihalomethanes<br><input type="checkbox"/> Haloacetic Acids<br><input type="checkbox"/> Chlorite<br><input type="checkbox"/> Bromate | <p><u>Radionuclides</u></p> <input type="checkbox"/> Single Sample<br><input type="checkbox"/> Qtrly Composite** | <p><u>Secondaries</u></p> <input type="checkbox"/> All 14<br><input type="checkbox"/> Partial |
|---|--|---|--|--|---|

## LAB CERTIFICATION

I, Dale Dixon / Tulay Tanrisever / Kara Peterson, Lab Director / Technical Director & QC Officer / QA Officer, do HEREBY CERTIFY  
 (Print Name) (Print Title)

that all attached analytical data are correct and unless noted meet all requirements of the National Environmental Laboratory Accreditation Conference (NELAC).

Signature:  Date: 6/21/2022

\* Failure to provide a valid and current Florida DOH lab certification number and a current Analyte Sheet for the attached analysis results will result in rejection of the report, possible enforcement against the public water system for failure to sample, and may result in notification of the DOH Bureau of Laboratory Services.  
 \*\* Please provide radiological sample dates & locations for each quarter.

**CONFIRMATION & NOTIFICATION IS REQUIRED WITHIN 24 HRS FOR NITRATE OR NITRITE MCL EXCEEDANCES  
 NON-DETECTS ARE TO BE REPORTED AS THE MDL WITH A "U" QUALIFIER. (Non-detects reported as "BDL" or with a "<" are not acceptable.)**

**COMPLIANCE DETERMINATION** (to be completed by DEP or DOH -- attach notes as necessary)

Sample Collection & Analysis Satisfactory:  Yes  No \_\_\_\_\_ Replacement Sample or Report Requested (circle or highlight group(s) above)

Person Notified: \_\_\_\_\_ Date Notified: \_\_\_\_\_ DEP/DOH Reviewing Official: \_\_\_\_\_

# Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

## LABORATORY CERTIFICATION INFORMATION (to be completed by lab – please type or print legibly)

Lab Name: Benchmark EnviroAnalytical, Inc. Florida DOH Certification #: E84167 Certification Expiration Date: 06/30/2022

**ATTACH CURRENT DOH ANALYTE SHEET\***

Address: 1711 12th Street East, Palmetto, FL 34221 Phone #: 941-723-9986

Were any analyses subcontracted?  Yes  No If yes, please provide DOH certification number(s): E83033

**ATTACH DOH ANALYTE SHEET FOR EACH SUBCONTRACTED LAB\***

**ANALYSIS INFORMATION** (to be completed by lab) Date Sample(s) Received: 06/03/22

PWS ID (From Page 1): 6142734 Sample Number (From Page 1): \_\_\_\_\_ Lab Assigned Report # or Job ID: 22060202-003

Group(s) Analyzed & Results attached for compliance with Chapter 62-550, F.A.C. (Check all that apply):

<u>Inorganics</u>	<u>Synthetic Organics</u>	<u>Volatile Organics</u>	<u>Disinfection Byproducts</u>	<u>Radionuclides</u>	<u>Secondaries</u>
<input type="checkbox"/> All Except Asbestos	<input type="checkbox"/> All 30	<input type="checkbox"/> All 21	<input type="checkbox"/> Trihalomethanes	<input checked="" type="checkbox"/> Single Sample	<input type="checkbox"/> All 14
<input type="checkbox"/> Partial	<input type="checkbox"/> All Except Dioxin	<input type="checkbox"/> Partial	<input type="checkbox"/> Haloacetic Acids	<input type="checkbox"/> Qtrly Composite**	<input type="checkbox"/> Partial
<input type="checkbox"/> Nitrate	<input type="checkbox"/> Partial		<input type="checkbox"/> Chlorite		
<input type="checkbox"/> Nitrite	<input type="checkbox"/> Dioxin Only		<input type="checkbox"/> Bromate		
<input type="checkbox"/> Asbestos					

## LAB CERTIFICATION

I, Dale Dixon / Tulay Tanrisever / Kara Peterson, Lab Director / Technical Director & QC Officer / QA Officer, do HEREBY CERTIFY  
(Print Name) (Print Title)

that all attached analytical data are correct and unless noted meet all requirements of the National Environmental Laboratory Accreditation Conference (NELAC).

Signature:  Date: 6/21/2022

\* Failure to provide a valid and current Florida DOH lab certification number and a current Analyte Sheet for the attached analysis results will result in rejection of the report, possible enforcement against the public water system for failure to sample, and may result in notification of the DOH Bureau of Laboratory Services.

\*\* Please provide radiological sample dates & locations for each quarter.

**CONFIRMATION & NOTIFICATION IS REQUIRED WITHIN 24 HRS FOR NITRATE OR NITRITE MCL EXCEEDANCES  
NON-DETECTS ARE TO BE REPORTED AS THE MDL WITH A "U" QUALIFIER. (Non-detects reported as "BDL" or with a "<" are not acceptable.)**

**COMPLIANCE DETERMINATION** (to be completed by DEP or DOH -- attach notes as necessary)

Sample Collection & Analysis Satisfactory:  Yes  No \_\_\_\_\_ Replacement Sample or Report Requested (circle or highlight group(s) above)

Person Notified: \_\_\_\_\_ Date Notified: \_\_\_\_\_ DEP/DOH Reviewing Official: \_\_\_\_\_

# Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

INORGANIC CONTAMINANTS  
62-550.310(1)

Report Number / Job ID: 22060202-001

PWS ID (From Page 1): 6142734

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Analysis Date	Analysis Time	DOH Lab Certification #
1040	Nitrate (as N)	10	mg/L							E
1041	Nitrite (as N)	1	mg/L							E
1005	Arsenic	0.010	mg/L	0.00069	U	SM3113B	0.00069	06/16/22	11:35	E84167
1010	Barium	2	mg/L							E
1015	Cadmium	0.005	mg/L							E
1020	Chromium	0.1	mg/L							E
1024	Cyanide	0.2	mg/L							E
1025	Fluoride	4.0	mg/L							E
1030	Lead	0.015	mg/L							E
1035	Mercury	0.002	mg/L							E
1036	Nickel	0.1	mg/L							E
1045	Selenium	0.05	mg/L							E
1052	Sodium	160	mg/L	50.8		200.7	0.034	06/14/22	13:35	E84167
1074	Antimony	0.006	mg/L							E
1075	Beryllium	0.004	mg/L							E
1085	Thallium	0.002	mg/L							E
1094	Asbestos	7 MFL	MFL							E

\*Results must be reported with appropriate qualifiers in accordance with Florida Administrative Code Rule 62-160, Table 1. Results qualified with A, F, H, N, O, T, Z, ?, \*, are unacceptable for compliance with 62-550. Results qualified with a J, Q, R, or Y must be accompanied by written justification and will be evaluated on a case by case basis. To avoid a monitoring violation, unacceptable results must be replaced with acceptable results from samples collected during the same monitoring period.

# Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

INORGANIC CONTAMINANTS  
62-550.310(1)

Report Number / Job ID: 22060202-002

PWS ID (From Page 1): 6142734

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Analysis Date	Analysis Time	DOH Lab Certification #
1040	Nitrate (as N)	10	mg/L							E
1041	Nitrite (as N)	1	mg/L							E
1005	Arsenic	0.010	mg/L	0.002	I	SM3113B	0.00069	06/16/22	11:41	E84167
1010	Barium	2	mg/L							E
1015	Cadmium	0.005	mg/L							E
1020	Chromium	0.1	mg/L							E
1024	Cyanide	0.2	mg/L							E
1025	Fluoride	4.0	mg/L							E
1030	Lead	0.015	mg/L							E
1035	Mercury	0.002	mg/L							E
1036	Nickel	0.1	mg/L							E
1045	Selenium	0.05	mg/L							E
1052	Sodium	160	mg/L	27.6		200.7	0.034	06/14/22	13:39	E84167
1074	Antimony	0.006	mg/L							E
1075	Beryllium	0.004	mg/L							E
1085	Thallium	0.002	mg/L							E
1094	Asbestos	7 MFL	MFL							E

\*Results must be reported with appropriate qualifiers in accordance with Florida Administrative Code Rule 62-160, Table 1. Results qualified with A, F, H, N, O, T, Z, ?, \*, are unacceptable for compliance with 62-550. Results qualified with a J, Q, R, or Y must be accompanied by written justification and will be evaluated on a case by case basis. To avoid a monitoring violation, unacceptable results must be replaced with acceptable results from samples collected during the same monitoring period.

## Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

RADIONUCLIDES  
62-550.310(6)

Report Number / Job ID: 22060202-003

PWS ID (From Page 1): 6142734

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	RDL	Analysis Error	Analysis Date	Analysis Time	DOH Lab Certification #
4000	Gross Alpha (Excl Uranium)	15	pCi/L	**				3				
4002	Gross Alpha (Incl Uranium)	***	pCi/L	1.3	U	900.0	1.3	3	1.0	06/14/22	10:11	E83033
4006	Combined Uranium**** (U-234, U-235, & U-238)	20	pCi/L					67				
		30	µg/L					1				
4020	Radium-226	5	pCi/L	0.5		903.1	0.2	1	0.2	06/17/22	09:51	E83033
4030	Radium-228			0.9	U	Ra-05	0.9	1	0.6	06/16/22	12:39	E83033

\*\* If the result exceeds 5 pCi/L, a measurement for radium-226 is required. Uranium is reported separately under Contam ID 4006.

\*\*\* If the results exceed 5 pCi/L, a measurement for radium-226 is required. If the results exceed 15 pCi/L, a measurement for Combined Uranium must be reported separately. The DEP/DOH will subtract the U value from the Gross Alpha (ID 4002) to determine compliance with MCL for Gross Alpha (Excl. U) of 15pCi/L. If the result for ID 4002 Gross Alpha (Including Uranium) does not exceed 15pCi/L, Combined Uranium need not be measured nor reported.

\*\*\*\* If using Uranium testing methods ASTM D5174 or EPA 200.8 only, then Analysis Error need not be reported.

**DATA QUALIFIERS THAT MAY APPLY:**

B = Results based upon colony counts outside the ideal range.

G1 = Accuracy standard does not meet method control limits but does meet lab control limits that are in agreement with USEPA generated data. USEPA letter available upon request.

G2 = Accuracy standard exceeds acceptable control limits. Duplicate and spike values are within control limits. Reported data are usable.

G3 = Precision measurement exceeded acceptable control limits. Standard and spike values are within control limits. Reported data are usable.

G4 = Spike recovery exceeds acceptable control limits. Standard and duplicate values are within control limits. Reported data are usable.

I = Reported value is between the laboratory MDL and the PQL.

J3 = Estimated value. Quality control criteria for precision and accuracy not met.

J4 = Estimated value. Sample matrix interference suspected.

J6 = Estimated value. SM5210B test replicates show more than 30% difference between high and low values, indicating potential presence of toxicity within the sample.

J (L1) = Estimated Value. Analyte recovery in the laboratory control sample (LCS) was above QC limits. Results for this analyte in associated samples may be biased high

K = Off-scale low. Value is known to be < the value reported.

L = Off scale high; reported concentration exceeds the highest standard.

ND = Not Detected at or above adjusted reporting limit.

Q = Sample held beyond accepted hold time.

QL-02 = The associated laboratory control sample exhibited high bias; since the result is ND, there is no impact.

QV-01 = The associated continuing calibration verification standard exhibited high bias; since the results is ND, there is no impact.

S3 = Surrogate recovery exceeded laboratory control limits. Analyte presence below reporting limits in associated samples.

U = Analyte analyzed but not detected at the value indicated.

V = Analyte detected in sample and method blank. Results for this analyte in associated samples may be biased high. Standard, Duplicate and Spike values are within control limits. Reported data are usable.

X = Value exceed MCL.

Y = Analysis performed on an improperly preserved sample. Data may be inaccurate

Z = Too many colonies were present (TNTC). The numeric value represents the filtration volume



Laboratory Scope of Accreditation

Attachment to Certificate #: E84167-54, expiration date June 30, 2022. This listing of accredited analytes should be used only when associated with a valid certificate.

State Laboratory ID: E84167

EPA Lab Code: FL00289

(941) 723-9986

E84167

Benchmark EnviroAnalytical, Inc.  
1711 12th Street East  
Palmetto, FL 34221

Matrix: Drinking Water

Analyte	Method/Tech	Category	Certification Type	Effective Date
1,1,1-Trichloroethane	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
1,1,2-Trichloroethane	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
1,1-Dichloroethylene	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
1,2,4-Trichlorobenzene	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
1,2-Dibromo-3-chloropropane (DBCP)	EPA 504.1	Synthetic Organic Contaminants	NELAP	4/20/2009
1,2-Dibromoethane (EDB, Ethylene dibromide)	EPA 504.1	Synthetic Organic Contaminants	NELAP	4/20/2009
1,2-Dichlorobenzene	EPA 524.2	Other Regulated Contaminants	NELAP	12/29/2015
1,2-Dichloroethane	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
1,2-Dichloropropane	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
1,4-Dichlorobenzene	EPA 524.2	Other Regulated Contaminants	NELAP	12/29/2015
Alkalinity as CaCO3	SM 2320 B	Primary Inorganic Contaminants	NELAP	5/25/2004
Aluminum	EPA 200.7	Secondary Inorganic Contaminants	NELAP	5/25/2004
Ammonia as N	EPA 350.1	Primary Inorganic Contaminants	NELAP	3/7/2011
Arsenic	SM 3113 B	Primary Inorganic Contaminants	NELAP	1/3/2002
Barium	SM 3113 B	Primary Inorganic Contaminants	NELAP	1/3/2002
Benzene	EPA 200.7	Primary Inorganic Contaminants	NELAP	5/25/2004
Beryllium	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
Boron	EPA 200.7	Primary Inorganic Contaminants	NELAP	5/25/2004
Bromate	EPA 300.1	Secondary Inorganic Contaminants	NELAP	3/7/2011
Bromide	EPA 300.0	Primary Inorganic Contaminants	NELAP	11/21/2008
Bromoacetic acid	EPA 552.2	Group I Unregulated Contaminants	NELAP	5/25/2004
Bromodichloromethane	EPA 524.2	Group II Unregulated Contaminants	NELAP	9/28/2005
Bromoform	EPA 524.2	Group II Unregulated Contaminants	NELAP	9/28/2005
Cadmium	EPA 200.7	Primary Inorganic Contaminants	NELAP	5/25/2004
Calcium	EPA 200.7	Primary Inorganic Contaminants	NELAP	5/25/2004
Carbon tetrachloride	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
Chlorate	EPA 300.1	Secondary Inorganic Contaminants	NELAP	11/21/2008
Chloride	EPA 300.0	Secondary Inorganic Contaminants	NELAP	5/25/2004
Chlorine	SM 4500-Cl G	Primary Inorganic Contaminants	NELAP	3/7/2011
Chlorite	EPA 300.1	Primary Inorganic Contaminants	NELAP	11/21/2008
Chloroacetic acid	EPA 552.2	Group I Unregulated Contaminants	NELAP	4/20/2009
Chlorobenzene	EPA 524.2	Other Regulated Contaminants	NELAP	12/29/2015
Chloroform	EPA 524.2	Group II Unregulated Contaminants	NELAP	9/28/2005
Chromium	EPA 200.7	Primary Inorganic Contaminants	NELAP	5/25/2004
cis-1,2-Dichloroethylene	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005

Clients and Customers are urged to verify the laboratory's current certification status with the Environmental Laboratory Certification Program.

Issue Date: 2/3/2022

Expiration Date: 6/30/2022



*Laboratory Scope of Accreditation*

Attachment to Certificate #: E84167-54, expiration date June 30, 2022. This listing of accredited analytes should be used only when associated with a valid certificate.

State Laboratory ID: E84167      EPA Lab Code: FL00289      (941) 723-9986

**E84167**  
**Benchmark EnviroAnalytical, Inc.**  
**1711 12th Street East**  
**Palmetto, FL 34221**

Matrix: **Drinking Water**

Analyte	Method/Tech	Category	Certification Type	Effective Date
Residue-filterable (TDS)	SM 2540 C	Secondary Inorganic Contaminants	NELAP	7/31/2007
Selenium	SM 3113 B	Primary Inorganic Contaminants	NELAP	2/2/2022
Silica as SiO2	EPA 200.7	Primary Inorganic Contaminants	NELAP	5/25/2004
Silver	EPA 200.7	Secondary Inorganic Contaminants	NELAP	5/25/2004
Sodium	EPA 200.7	Primary Inorganic Contaminants	NELAP	5/25/2004
Styrene	EPA 524.2	Other Regulated Contaminants	NELAP	12/29/2015
Sulfate	EPA 300.0	Primary Inorganic Contaminants,Secondary Inorganic Contaminants	NELAP	5/25/2004
Sulfide	SM 4500-S D/UV-VIS	Primary Inorganic Contaminants	NELAP	3/7/2011
Surfactants - MBAS	SM 5540 C	Secondary Inorganic Contaminants	NELAP	1/3/2002
Tetrachloroethylene (Perchloroethylene)	EPA 524.2	Other Regulated Contaminants	NELAP	12/29/2015
Thallium	EPA 200.9	Primary Inorganic Contaminants	NELAP	1/3/2002
Toluene	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
Total coliforms	SM 9223 B	Microbiology	NELAP	1/3/2002
Total coliforms	SM 9223 B /QUANT-TRAY	Microbiology	NELAP	3/7/2011
Total cyanide	EPA 335.4	Primary Inorganic Contaminants	NELAP	1/7/2021
Total haloacetic acids (HAA5)	EPA 552.2	Synthetic Organic Contaminants	NELAP	4/20/2009
Total nitrate-nitrite	EPA 300.0	Primary Inorganic Contaminants	NELAP	5/25/2004
Total nitrate-nitrite	EPA 353.2	Primary Inorganic Contaminants	NELAP	1/3/2002
Total organic carbon	SM 5310 B	Primary Inorganic Contaminants	NELAP	5/25/2004
Total trihalomethanes	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
trans-1,2-Dichloroethylene	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
Trichloroacetic acid	EPA 552.2	Group I Unregulated Contaminants	NELAP	10/14/2010
Trichloroethene (Trichloroethylene)	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
Turbidity	EPA 180.1	Secondary Inorganic Contaminants	NELAP	3/7/2011
UV 254	SM 5910 B	Primary Inorganic Contaminants	NELAP	11/16/2016
Vanadium	EPA 200.7	Secondary Inorganic Contaminants	NELAP	3/7/2011
Vinyl chloride	EPA 524.2	Other Regulated Contaminants	NELAP	9/28/2005
Xylene (total)	EPA 524.2	Other Regulated Contaminants	NELAP	12/29/2015
Zinc	EPA 200.7	Secondary Inorganic Contaminants	NELAP	5/25/2004

Clients and Customers are urged to verify the laboratory's current certification status with the Environmental Laboratory Certification Program.

Issue Date: 2/3/2022

Expiration Date: 6/30/2022



Laboratory Scope of Accreditation

Attachment to Certificate #: E83033-17, expiration date June 30, 2022. This listing of accredited analytes should be used only when associated with a valid certificate.

State Laboratory ID: E83033

EPA Lab Code: FL01113

(407) 382-7733

E83033

Florida Radiochemistry Services, Inc.  
5456 Hoffer Rd, Suite 201  
Orlando, FL 32812

Matrix: Drinking Water

Analyte	Method/Tech	Category	Certification Type	Effective Date
Gross Alpha	EPA 900.0	Radiochemistry	NELAP	6/28/2001
Gross Beta	EPA 900.0	Radiochemistry	NELAP	6/28/2001
Radium-226	EPA 903.0	Radiochemistry	NELAP	12/15/2003
Radium-226	EPA 903.1	Radiochemistry	NELAP	6/28/2001
Radium-228	EPA R-05	Radiochemistry	NELAP	6/28/2001
Uranium (activity)	EPA 908.0	Radiochemistry	NELAP	6/28/2001

Clients and Customers are urged to verify the laboratory's current certification status with the Environmental Laboratory Certification Program.

Issue Date: 7/1/2021

Expiration Date: 6/30/2022